

# Biological Control in Cooling Water Systems Using Non-Chemical Treatment Devices

April 2010

## Final Technical Report

April 1, 2008 - December 31, 2009

**Principal Author:  
Radisav D. Vidic**

**Contributing Authors:  
Scott M. Duda  
Janet E. Stout**

ASHRAE Project Number 1361-RP

Submitted to:

**ASHRAE  
1719 Tullie Circle  
Atlanta, GA 30329**

Submitted by:

**University of Pittsburgh  
Department of  
Civil and Environmental Engineering  
Pittsburgh, PA 15261-2294**



Full-scale and pilot-scale cooling towers



## Executive Summary

Microbial growth in cooling water systems causes corrosion, decreases energy efficiency, and has the potential to cause human infection. Control of microbial growth in these systems is typically achieved with the use of chemical biocides. Recently, non-chemical water treatment methods have seen increased use as an alternative. However, few objective studies with an untreated system as a reference are available to verify the efficacy of these devices to control microbial growth in cooling towers. Therefore, the specific objective of this investigation was to provide a controlled, independent, and scientific evaluation of several classes of non-chemical treatment devices (NCDs) for controlling biological activity in a model cooling tower system.

Five NCDs were evaluated for efficacy in reducing planktonic (bulk water) and sessile (biofilm) microbial populations within a pilot-scale cooling system. The devices included magnetic, pulsed electric field, electrostatic, ultrasonic, and hydrodynamic cavitation. Two model towers were designed and operated to simulate field conditions (e.g., heat load, residence time, liquid loading rate, evaporative cooling, blowdown and make-up system). One tower served as the untreated control (T1) while the NCD was installed on the second tower (T2). Each device trial was conducted over a 4-week period. Heterotrophic plate counts (HPC) were used to monitor biological growth in both planktonic and attached phase. Physicochemical monitoring included temperature, conductivity, pH, alkalinity, hardness, total dissolved solids (TDS), ORP, and chloride. Make-up water for each system was dechlorinated city tap water. According to information documented in the literature, the makeup water chemistry used in this study is representative of that found in many building cooling tower systems.

Under the experimental conditions used in this study, no statistically significant difference ( $p$  values in a  $t$ -test above 0.05) in planktonic and sessile microbial concentrations

(HPC) was observed between the control tower and a tower treated by any of the five NCDs evaluated in this study (i.e., biological and chemical parameters were comparable in T1 and T2 for all device trials).

Standard chemical treatment of pilot-scale cooling towers by the addition of free chlorine (positive control) was able to achieve appreciable reduction in both planktonic (2-3 orders of magnitude) and sessile microbial growth (3-4 orders of magnitude) in these towers. These positive controls were repeated three times throughout the study and the results clearly showed that free chlorine was able to control biological growth in every instance, even after heavy microbial colonization of model cooling towers.

The results of this study conducted under well-controlled conditions show that NCDs did not control biological growth under the conditions of the testing in the pilot scale cooling tower systems. As with any research project, the conclusions that can be drawn to full-scale applications are limited by the extent to which the variables possible in full-scale are understood and appropriately modeled against controls. The study can only properly conclude that the devices did not successfully control biological growth under the conditions tested. As with any protocol for biological control, it is prudent for building owners and engineers to consider taking water sample tests for all HVAC systems that require biological control. If the testing shows an issue, appropriate adjustment of technology or protocols followed by additional testing is important to prevent potential health or operating issues.

## TABLE OF CONTENTS

<b>1.0</b>	<b>INTRODUCTION .....</b>	<b>1</b>
<b>1.1</b>	<b>COOLING SYSTEM WATER TREATMENT.....</b>	<b>1</b>
<b>1.2</b>	<b>NON-CHEMICAL WATER TREATMENT.....</b>	<b>3</b>
<b>1.2.1</b>	<b>Magnetic Treatment .....</b>	<b>3</b>
<b>1.2.2</b>	<b>Pulsed-power and Electrostatic Treatment.....</b>	<b>5</b>
<b>1.2.3</b>	<b>Ultrasonic Cavitation Treatment .....</b>	<b>9</b>
<b>1.2.4</b>	<b>Hydrodynamic Cavitation Treatment .....</b>	<b>12</b>
<b>2.0</b>	<b>EXPERIMENTAL PROTOCOL .....</b>	<b>16</b>
<b>2.1</b>	<b>SPECIFIC OBJECTIVES .....</b>	<b>16</b>
<b>2.2</b>	<b>MATERIALS AND METHODS.....</b>	<b>17</b>
<b>2.2.1</b>	<b>Cooling Tower System Description.....</b>	<b>17</b>
<b>2.2.2</b>	<b>Device Trial Protocol.....</b>	<b>21</b>
<b>2.2.3</b>	<b>Chemical Disinfection Test Protocols .....</b>	<b>28</b>
<b>2.2.3.1</b>	<b>Pre-Device Trial Chlorination Test Protocol.....</b>	<b>29</b>
<b>2.2.3.2</b>	<b>ED/UD Chlorination Test.....</b>	<b>30</b>
<b>2.2.3.3</b>	<b>UD/HCD Chlorination Test.....</b>	<b>31</b>
<b>2.3</b>	<b>NON-CHEMICAL DEVICES.....</b>	<b>33</b>



2.3.1	Magnetic Device (MD).....	33
2.3.2	Pulsed Electric Field Device (PEFD) .....	34
2.3.3	Electrostatic Device (ED) .....	38
2.3.4	Ultrasonic Device (UD).....	39
2.3.5	Hydrodynamic Cavitation Device (HCD).....	40
<b>3.0</b>	<b>EXPERIMENTAL REPRODUCIBILITY.....</b>	<b>43</b>
3.1	MAKE-UP WATER QUALITY .....	44
3.1.1	Biological Parameters.....	45
3.1.2	Summary .....	46
3.2	T1 (CONTROL) CONDITIONS .....	48
3.2.1	T1 (Control) System Operation.....	48
3.2.2	Biological Parameters.....	50
3.2.3	Summary .....	53
<b>4.0</b>	<b>DEVICE TRIAL RESULTS AND DISCUSSION.....</b>	<b>55</b>
4.1	MAGNETIC DEVICE (MD) TRIAL .....	55
4.1.1	Tower System Operation .....	56
4.1.2	Biological Parameters.....	58
4.1.3	Summary .....	64
4.2	PULSED ELECTRIC FIELD DEVICE (PEFD) TRIAL 1/2.....	66
4.2.1	Tower System Operation .....	66
4.2.2	Biological Parameters.....	68
4.2.3	Summary .....	72
4.3	PULSED ELECTRIC FIELD DEVICE (PEFD) TRIAL 2/2.....	73

4.3.1	Tower System Operation .....	74
4.3.2	Biological Parameters.....	76
4.3.3	Summary .....	81
4.4	<b>ELECTROSTATIC DEVICE (ED) TRIAL .....</b>	<b>83</b>
4.4.1	Tower System Operation .....	83
4.4.2	Biological Parameters.....	85
4.4.3	Summary .....	91
4.5	<b>ULTRASONIC DEVICE (UD) TRIAL.....</b>	<b>92</b>
4.5.1	Tower System Operation .....	92
4.5.2	Biological Parameters.....	95
4.5.3	Summary .....	99
4.6	<b>HYDRODYNAMIC CAVITATION DEVICE (HCD) TRIAL.....</b>	<b>100</b>
4.6.1	Tower System Operation .....	100
4.6.2	Biological Parameters.....	102
4.6.3	Summary .....	106
4.7	<b>CHLORINATION TEST RESULTS.....</b>	<b>107</b>
4.7.1	Pre-Device Trial Chlorination Test.....	107
4.7.2	ED/UD Chlorination Test .....	110
4.7.3	UD/HCD Chlorination Test .....	111
4.8	<b>HPC ANALYSES USING ATP MICROBIAL EQUIVALENTS AND POUR PLATE METHOD .....</b>	<b>115</b>
5.0	<b>SUMMARY AND CONCLUSIONS .....</b>	<b>117</b>
6.0	<b>REFERENCES.....</b>	<b>121</b>

<b>APPENDIX A: SCALING INDICES CALCULATION &amp; INTERPRETATION .....</b>	<b>128</b>
<b>APPENDIX B : EXPERIMENTAL REPRODUCIBILITY .....</b>	<b>130</b>
<b>APPENDIX B.1 – MAKE-UP WATER QUALITY .....</b>	<b>130</b>
<b>APPENDIX B.2 – T1 (CONTROL) WATER QUALITY .....</b>	<b>134</b>
<b>APPENDIX C: MD TRIAL .....</b>	<b>141</b>
<b>APPENDIX C.1 – EXPERIMENTAL RESULTS.....</b>	<b>141</b>
<b>APPENDIX C.2 – STATISTICAL ANALYSES .....</b>	<b>152</b>
<b>APPENDIX C.3 - PHOTOGRAPHS OF TOWER SYSTEMS.....</b>	<b>157</b>
<b>APPENDIX D : PEFD TRIAL 1/2 .....</b>	<b>161</b>
<b>APPENDIX D.1 – EXPERIMENTAL RESULTS.....</b>	<b>161</b>
<b>APPENDIX D.2 – STATISTICAL ANALYSES OF CHEMICAL PARAMETERS</b>	<b>172</b>
<b>APPENDIX D.3 – PHOTOGRAPHS OF TOWER SYSTEMS.....</b>	<b>177</b>
<b>APPENDIX E : PEFD TRIAL 2/2.....</b>	<b>184</b>
<b>APPENDIX E.1 – EXPERIMENTAL RESULTS.....</b>	<b>184</b>
<b>APPENDIX E.2 – STATISTICAL ANALYSES.....</b>	<b>195</b>
<b>APPENDIX E.3 – PHOTOGRAPHS OF TOWER SYSTEMS .....</b>	<b>200</b>
<b>APPENDIX E.4 – BIOFILM SAMPLING COUPON COMPARISON .....</b>	<b>206</b>
<b>APPENDIX F : ED TRIAL.....</b>	<b>207</b>
<b>APPENDIX F.1 – EXPERIMENTAL RESULTS .....</b>	<b>207</b>
<b>APPENDIX F.2 – STATISTICAL ANALYSES.....</b>	<b>218</b>
<b>APPENDIX F.3 – PHOTOGRAPHS OF TOWER SYSTEMS .....</b>	<b>223</b>
<b>APPENDIX F.4 – BIOFILM SAMPLING COUPON COMPARISON.....</b>	<b>230</b>
<b>APPENDIX G : UD TRIAL .....</b>	<b>231</b>

<b>APPENDIX G.1 – EXPERIMENTAL RESULTS .....</b>	<b>231</b>
<b>APPENDIX G.2 – STATISTICAL ANALYSES .....</b>	<b>242</b>
<b>APPENDIX G.3 – PHOTOGRAPHS OF TOWER SYSTEMS.....</b>	<b>247</b>
<b>APPENDIX G.4 – BIOFILM SAMPLING COUPON COMPARISON.....</b>	<b>255</b>
<b>APPENDIX H : HCD TRIAL.....</b>	<b>256</b>
<b>APPENDIX H.1 – EXPERIMENTAL RESULTS .....</b>	<b>256</b>
<b>APPENDIX H.2 – STATISTICAL ANALYSES .....</b>	<b>267</b>
<b>APPENDIX H.3 – PHOTOGRAPHS OF TOWER SYSTEMS.....</b>	<b>272</b>
<b>APPENDIX H.4 – BIOFILM SAMPLING COUPON COMPARISON.....</b>	<b>280</b>

## **1.0 INTRODUCTION**

This section will provide a brief background for the investigation discussed in this report. First, the basic principles of cooling system water treatment will be discussed. Next, an introduction to several non-chemical treatment technologies will be provided. Each of the technologies discussed in this section was tested during this investigation. These included magnetic, pulsed-power, electrostatic, ultrasonic, and hydrodynamic cavitation treatment mechanisms.

### **1.1 COOLING SYSTEM WATER TREATMENT**

Disinfection is essential for the maintenance of an efficient cooling water system. Pathogens must be removed from industrial process waters to prevent spreading of pathogenic organisms and associated health problems. In addition, the presence of microorganisms in cooling water systems can lead to bacterially-induced corrosion of the infrastructure and inefficient heat transfer due to coating of surfaces with heavy microbial growth (biofilm). It is currently a standard practice to use chemical biocides as means of limiting microbial growth. The most popular of these chemical agents is free chlorine, which is utilized as a primary disinfectant in the United States as well as throughout the world.

The exclusive use of chemical disinfectants for water treatment has fallen out of favor in recent years for several reasons. Chemical disinfectants must be replenished regularly. Many biocidal agents are highly toxic and may cause serious health problems to those handling them.

As a result, safety training must be provided for workers who are responsible for the application of treatment chemicals. Extended use of chemical disinfectants can lead to the establishment of microbial resistance, which forces industries to regularly alternate the primary biocide [Gaines *et al.*, 2007]. Chemical disinfectants may also combine with other compounds present in treated or receiving waters to form disinfection byproducts (DBPs), which may have adverse ecological effects. In particular, the formation of toxic trihalomethanes in waters containing chlorine residual has been well-documented [Lee *et al.*, 2007].

Chemical water treatment has been the industry standard for control of biological growth. However, due to the limitations described above there has been significant interest in the use of non-chemical (physical) water treatment technologies. Physical non-chemical water treatment devices have been marketed since the late 19<sup>th</sup> century [Faunce & Cabell, 1890], but only recently have they seen widespread application. Magnetic treatment exhibited potential applicability for corrosion and scale control [Baker and Judd, 1996]. However, it has not been shown to effectively control microbial growth. Other physical water treatment technologies, including pulsed-power systems, electrostatic systems, ultrasonic systems, and hydrodynamic cavitation systems, have been developed and marketed by a variety of manufacturers over the past several decades. While the manufacturers of some devices claim that their products are capable of controlling scaling, corrosion, and microbial growth, only a limited amount of independently performed research has substantiated those claims [Baker & Judd, 1996; Kitzman *et al.*, 2003; Phull *et al.*, 1997; Vega-Mercado *et al.*, 1997].

The validity of claims regarding device efficiency must be evaluated using objective criteria. Studies that report anecdotal uncontrolled observations, experiments performed under laboratory conditions that do not simulate field conditions, or studies conducted or supported by

the device manufacturer have less scientific merit than controlled prospective studies conducted under conditions that do simulate typical cooling tower operation.

The investigation described in this report has been funded by the American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE) with the intention of providing an independent and unbiased study to determine if these non-chemical treatment devices can control biological growth in cooling tower systems.

## 1.2 NON-CHEMICAL WATER TREATMENT

### 1.2.1 Magnetic Treatment

Magnetic water conditioners have been applied to reduce scaling and corrosion in industrial systems for several decades. There are no claims, however, that magnetic devices control microbial growth in cooling tower systems. These devices function by allowing the water to pass through a fixed magnetic field. This field is purported to alter the water chemistry to prevent the formation of “hard” scales on cooling surfaces. These “hard” scales effect heat transfer and are difficult to remove. Factors which affect the ability of a magnetic water conditioner to prevent scale formation include “chemical properties of the water, strength and configuration of the magnetic field, thermodynamic properties of the water and fluid flow characteristics” [Quinn *et al.*, 1997].

All molecules can be classified as either polar or non-polar. “A non-polar molecule is one in which the center of gravity of the positive nuclei and the electrons coincide, while a polar

molecule is one in which they do not” [Quinn *et al.*, 1997]. As a result, molecules which maintain symmetry, such as the diatomic gases, are non-polar, while molecules which do not, such as water, are polar. When non-polar molecules are exposed to a magnetic field, displacement of molecular charges leads to the formation of an induced dipole. This induced dipole allows non-polar molecules to align themselves in the direction of the applied magnetic field. In addition, polar molecules also align themselves according to the magnetic field direction. According to Quinn *et al.* (1997), the capacity of a magnetic conditioner can be determined by the gauss strength, flux density, surface area of the exposure, the number of fields and the distance between alternating poles. In order for a fixed magnetic field to be effectively used for water conditioning, certain conditions must be met. These conditions are as follows [Quinn *et al.*, 1997]:

- The water path must be perpendicular to the magnetic lines of force.
- Water should first cut the south magnetic lines and then proceed to break wider and more dense alternating reversing polarity lines, until exiting the magnetic chamber through the single north pole flux path.
- Water must be under pressure and moving with the least amount of turbulence possible, just before entering and during its travel through the magnetic fields.

Under these conditions, several studies have indicated that magnetic conditioners are able to prevent the formation of scaling compounds. Calcium carbonate that is exposed to a magnetic field may be converted from the calcite form, which is responsible for scale formation, into the aragonite form, which exists as a “soft” precipitate that may easily be removed from cooling



surfaces. [Quinn *et al.*, 1997]. A study conducted by the National Aeronautics and Space Administration (NASA) in 1975 reported negligible corrosion rates for magnetically conditioned water, while chemically treated water was reported to have a corrosion rate between 1-50 mils/yr [Kuivinen, 1975]. Researchers have repeatedly verified that magnetic fields increase the potential of coagulation in waters containing at least moderate levels of hardness [Bogatin, 1999]. Later studies revealed that the efficiency of a magnetic treatment system was independent of the hardness of the water being treated [Gabrielli *et al.*, 2001].

### **1.2.2 Pulsed-power and Electrostatic Treatment**

Pulsed-power treatment, also referred to as pulsed electric field (PEF) treatment [Rieder *et al.*, 2008] or electropulse treatment [Danilenko *et al.*, 2005], involves the bombardment of the substance to be treated with pulses of electromagnetic energy. These pulses may inactivate microorganisms, including pathogens, present in the treated liquid. However, the optimal mechanism by which this process occurs has not been definitively established. The biocidal application of pulsed-power technology has been evaluated for use in the food processing industry [Feng *et al.*, 2004], as well as for cooling tower process water treatment [Opheim, 2001; Kitzman *et al.*, 2003].

Laboratory studies have demonstrated the efficacy of pulsed-power disinfection technology, particularly in food and beverage production. The work of Feng *et al.* (2004) demonstrated a high reduction in aerobic plate counts prepared from germinated brown rice in circulating water treated with pulsed-power. The reactions which produced this antimicrobial

effect, however, were found to be electrochemical, rather than physical. Additionally, this effect was observed in a closed system, as opposed to a cooling water system which allows for the intrusion of airborne bacteria and bacteria from incoming make-up water. Oil field reinjection water treatment using pulsed-power technology has also been investigated in laboratory settings, resulting in several log reduction of saprophytic, sulfate-reducing, and iron bacteria [Xin *et al.*, 2008]. However, these experiments were performed under batch conditions, as opposed to a field setting. Treatment times required for effective microbial reductions were long, with significant effects not appearing until nearly 15 minutes of continuous treatment.

Evidence of pulsed-power's ability to inactivate pathogens has also been claimed in several field studies. Application of pulsed-power systems on ice skating rink cooling towers in Connecticut demonstrated several log reduction of microorganisms (quantified using heterotrophic plate counts) both in bulk water and in biofilm coupon samples prepared from glass slides [Opheim, 2001]. These antimicrobial effects were observed after two months of treatment, and heterotrophic plate counts during the first two months of operation following installation ranged from  $10^3$  to  $10^6$  CFU/mL.

A similar investigation involved the application of a pulsed-power treatment system to evaporative coolers at Alcoa's Mt. Holly Works in Goose Creek, SC [Kitzman, 2003]. This study compared the efficacy of pulsed-power treatment at varying cooling tower cycles of concentration to chemical and hydrodynamic cavitation treatment. Pulsed-power treatment demonstrated average plate counts of aerobic and anaerobic planktonic bacteria of 65,000 CFU/mL and 85 CFU/mL, respectively and it appears that microbial control using this treatment system was more consistent than that observed using chemical treatment. It is important to note that the installation of the pulsed-power and hydrodynamic cavitation systems at Mt. Holly

Works included a cyclonic separator for solids removal. During the investigation, each of the three cooling towers received large quantities of airborne carbon dust from a nearby carbon silo. While the pulsed-power and hydrodynamic cavitation experimental towers were able to remove this additional carbon via sidestream filtration, the chemically treated tower had no means of filtration, and as a result turbidity levels in chemically treated tower (>120 NTU) were significantly higher than in the towers receiving physical water treatment (10-15 NTU). It is uncertain whether the observed antimicrobial effects of the physical water treatment systems were the result of the physical treatment mechanisms or the removal of large amounts of carbon via sidestream filtration. Additionally, although plate counts were lower in the tower with the pulsed-power device than in the chemically treated tower, none of the treatment methods produced plate counts below the industry standard of  $10^4$  CFU/mL.

Multiple mechanisms have been proposed for the inactivation of microorganisms by pulses of electromagnetic energy. It has been suggested that pulsed-power treatment can disrupt protective cellular structures in a mechanism known as electroporation. Laboratory studies documented that pulsed-power systems are capable of generating a transmembrane potential that is sufficient to cause electroporation [Zimmermann, 1986; Tsong, 1991]. The electromagnetic pulses lead to “[t]he bi-electrical breakthrough of the phosphorus lipid double layer in biological membranes,” rupturing the cell and causing death [Rieder *et al.*, 2008]. This mechanism is also supported by research which demonstrated the relative resistance of Gram-negative bacteria to pulsed-power treatment in comparison to Gram-positive bacteria [Min *et al.*, 2007]. This study attributed the resistance of Gram-negative bacteria to the presence of cell walls, and it also documented pulsed-power treatment resistance in bacterial spores and mold ascospores.

Laboratory investigations have verified that exposure to electromagnetic energy disrupts and weakens cellular membranes. The electromagnetic fields in these studies [Zimmermann, 1986; Tsong, 1991] were very strong (volts to kilovolts), and they were applied over very short distances and for relatively long exposure times (milliseconds – microseconds) in comparison to the conditions generated by commercially available pulsed-power treatment systems. The strengths of the applied fields in these studies were far higher than those produced by commercial treatment systems, and the distance of exposure was comparatively short (cm). While these investigations have demonstrated that the induction of electroporation is possible through the application of pulses of electromagnetic energy, it has not been demonstrated that the electromagnetic exposures generated by commercially available treatment systems are powerful enough to produce these effects.

Another hypothesis regarding the mechanism for inactivation of microorganisms by pulsed-power treatment proposes that free radicals ( $\text{OH}^\cdot$ ,  $\text{ClO}^\cdot$ ) are formed in water treated with electromagnetic bombardment [Vega-Mercado *et al.*, 1997; Oshima *et al.*, 1997]. Further investigation of this theory confirmed the formation of hydroxyl radicals upon exposure to electromagnetic pulses [Feng *et al.*, 2000]. As a result, hybridization of pulsed-power systems with low-dose chemical disinfectant feeds have been proposed, as the electromagnetic pulses have demonstrated the ability to increase free chlorine concentrations [Abderahmane *et al.*, 2008]. This indicates that the antimicrobial effects of pulsed-power treatment systems may be the result of electrochemical reactions, and that their mechanism of operation may not be strictly physical. While both the electroporation mechanism and the free radical formation mechanism have been substantiated with supporting laboratory research, it has not yet been determined which may be effective for microbial inactivation in field conditions.

The mechanisms of operation for electrostatic treatment systems are essentially identical to that involved in the operation of pulsed-power treatment systems. The primary difference is that electrostatic systems apply a static electric field, rather than pulses of energy. The claims of the manufacturers of these devices also include scaling, corrosion, and microbial control [Huchler, 2002]. However, there is no published literature indicating that the application of relatively weak static electric fields for a very short exposure time over a relatively large distance is capable of producing any antimicrobial effects.

### **1.2.3 Ultrasonic Cavitation Treatment**

The use of ultrasonic energy to inactivate microorganisms has been under investigation for several years. The first studies, attempting to utilize ultrasound as means of microbial inactivation, date back to 1929, when the technology was originally considered to be too energy intensive for commercial applications [Harvey & Loomis, 1929]. However, significant advances have been made in the field of ultrasonic technology over the past several decades, and it is now being re-evaluated as a potential disinfection agent. The use of ultrasound alone for disinfection remains energy-intensive, especially for high volume applications, and a number of studies have been conducted to evaluate the disinfection capacity of ultrasound in combination with other disinfection technologies [Joyce, 2003].

The interaction of ultrasonic energy with water results in cavitation process through a process known as sonication. Several processes resulting from the collapse of these cavitation bubbles are responsible for bacterial inactivation [Mason & Joyce *et al.*, 2003]:

- Forces due to surface resonance of the bacterial cell are induced by cavitation. Pressures and pressure gradients resulting from the collapse of gas bubbles which enter the bacterial solution on or near the bacterial cell wall can cause cellular damage. Bacterial cell damage results from mechanical fatigue, over a period of time, which depends on frequency.
- Shear forces induced by microstreaming occur within bacterial cells.
- Chemical attack due to the formation of radicals ( $H^{\bullet}$  and  $OH^{\bullet}$ ) during cavitation in the aqueous medium can also cause cellular damage. These radicals attack the chemical structure of the bacterial cell wall and weaken the cell wall to the point of disintegration.
- Among the final products of the sonochemical degradation of water is hydrogen peroxide ( $H_2O_2$ ), which is a strong bactericide.

Bench-scale investigations of the application of both low- (20-40 kHz) and high- (0.5-0.85 MHz) frequency ultrasonic energy to bacterial mediums have indicated that ultrasound may be responsible for both the death of bacteria and the disruption of cellular agglomerations [Mason & Joyce *et al.*, 2003]. These two processes can also counteract, resulting in no net biocidal effect. However, tests involving the use of an ultrasonic treatment unit to decontaminate 20 L of bacterial suspension contained within a flow loop have demonstrated a kill efficiency of near 85% [Mason & Duckhouse *et al.*, 2003].

Several studies have investigated the application of ultrasound for the disinfection of both drinking water and wastewater. Some of these investigations have evaluated ultrasound as a stand-alone treatment process [Furuta *et al.*, 2004; Hua & Thompson, 2000; Scherba *et al.*, 1991]

or in combination with other treatment technologies. Hybrid disinfection systems combining ultraviolet treatment with ultrasonic pretreatment generated coliform reductions of 3.3 to 3.7 log units, whereas ultraviolet treatment alone generated reductions of 2.5 log units [Blume & Neis, 2004]. Treatment with an ultrasonic horn combined with 5 mg/L H<sub>2</sub>O<sub>2</sub> dosing was able to generate a 15-minute disinfection percentage of 90% for fecal coliform removal, while 5 mg/L H<sub>2</sub>O<sub>2</sub> dosing alone was only able to produce a disinfection percentage of 9% and treatment with the ultrasonic horn alone was only able to produce a disinfection percentage of 47% [Jyoti & Pandit, 2003]. A system combining an ultrasonic horn with 0.5 mg/L ozone dosing was able to produce a 99.9% disinfection efficiency for heterotrophic plate count bacteria after 15 minutes of treatment, while 15 minute stand-alone treatment regimens of 0.5 mg/L ozone dosing and ultrasonic horn treatment produced heterotrophic plate count bacteria removal percentages of 46% and 50%, respectively [Jyoti & Pandit, 2004].

While research has demonstrated that microbial inactivation is possible through the application of ultrasonic energy, it has not successfully demonstrated that this technology may be applied to cooling system process water. The treatment times utilized in the studies performed by Jyoti & Pandit were long (15 minutes) compared to the very short treatment times required for cooling system process water. Since ultrasonic bombardment produces no residual, it may not be effective in controlling the microbial population of a cooling water system which receives large quantities of airborne material at various points throughout the system during operation. Some form of residual treatment is likely necessary in order to prevent microbial fouling from occurring, and as a result ultrasonic treatment systems alone may not be capable of significant microbial control in cooling water systems.

#### 1.2.4 Hydrodynamic Cavitation Treatment

When fluids are subjected to sudden high pressure changes, very small vapor bubbles may form within the fluid in a process known as cavitation. These bubbles quickly collapse, leading to extremely high local temperatures, pressures, and fluid velocities. The implosion of these small bubbles of fluid vapor within a liquid may lead to inactivation of surrounding organisms. This process of fluid vapor bubble formation as a result of “fluctuations in fluid pressure” is known as hydrodynamic cavitation [Gaines, 2007], and it has been proposed as a possible method of disinfection for potable water, wastewater, and industrial process water.

The efficacy of hydrodynamic cavitation disinfection has been demonstrated by a number of laboratory researchers. A group of investigators from India recently demonstrated the biocidal effect of hydrodynamic cavitation on zooplankton, achieving disinfection efficiency of approximately 80% [Sawant, 2008]. Additionally, elimination of *Legionella pneumophila* bacteria using a laboratory-scale hydrodynamic cavitation treatment system has been observed [Stout, 2002]. Hydrodynamic cavitation systems were able to generate a fecal coliform disinfection efficiency of 89% after 60 minutes of treatment [Jyoti & Pandit, 2003]. This treatment time is far longer than may be utilized by a cooling water treatment system, however.

Field studies involving the application of hydrodynamic cavitation treatment systems for cooling tower make up water have also demonstrated positive results with regards to the control of microbial populations. A group of researchers funded by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) investigated the biocidal capabilities of a hydrodynamic cavitation system installed on a cooling tower located in an automotive test lab [Gaines, 2007]. This system was capable of sustaining heterotrophic plate count values



below approximately  $10^4$  CFU/mL for over 2 months. However, several HPCs in excess of  $10^4$  CFU/mL were observed during the investigation. Field application of a hydrodynamic cavitation treatment system was also performed alongside pulsed-power treatment testing at Mt. Holly Works in Goose Creek, SC [Kitzman, 2003]. In this study, the hydrodynamic cavitation device was able to successfully maintain an average aerobic plate count of 95,500 CFU/mL and an average anaerobic plate count of 87 CFU/mL in its cooling water system. However, the installation of this system was accompanied by the installation of cyclonic separator for solids removal. Since the systems during this investigation received large amounts of airborne carbon fines from a nearby carbon silo, and the chemically-treated tower in this comparative study had no form of filtration, a conclusion may not be made whether or not the observed reduction in microbial activity in the system treated by hydrodynamic cavitation was the result of the physical treatment process or the removal of high levels of excess carbon through filtration.

Several mechanisms for the inactivation of microorganisms via hydrodynamic cavitation have been proposed. Studies have demonstrated that cavitation may result in the formation of free radicals when applied to aqueous solutions [Kalumuck *et al.*, 2003]. These hydrogen, hydroxyl, and hydrogen peroxide radicals have the potential to eliminate pathogens, but only in the area directly surrounding the bubble which collapses [Gaines, 2007]. The collapse of these small fluid vapor bubbles also releases high pressure pulses (up to 1450 psia), shear forces, and shock waves which are capable of causing nearby cells to rupture [Brennen, 1995]. Brennen's work has demonstrated that extremely high temperatures (as high as 8540 °F) occur for a few microseconds at the interface between the liquid and the vapor bubble during collapse. These temperatures may also lead to the death of nearby microorganisms [Gaines, 2007]. Additionally, when vapor bubble collapse occurs asymmetrically (i.e. near a surface), jets of fluid with

extremely high velocities are formed, as well as eddies with large amounts of energy [Naude & Ellis, 1961; Benjamin & Ellis, 1966]. These high fluid velocities may also be responsible for cellular inactivation.

The development of hydrodynamic cavitation disinfection systems, much like that of pulsed-power systems, must direct future efforts towards determining which inactivation mechanisms to exploit. While microorganism inactivation has been documented via several pathways, researchers must determine which pathway allows for the most efficient disinfection. Several hydrodynamic cavitation systems are commercially available for use as a primary form of disinfection, relying on asymmetric bubble collapse, pressure shock waves, and extreme local temperatures for microbial inactivation. However, systems which employ the use of hydrodynamic cavitation in combination with a low dose of chemical disinfectant and ultrasonic cavitation technologies are also under development.

Researchers from the University of Mumbai in India have investigated a number of hybrid hydrodynamic cavitation disinfection systems, coupling this treatment technology with ultrasonic cavitation, ozone dosing, and hydrogen peroxide dosing [Jyoti & Pandit, 2003; Jyoti & Pandit, 2004]. The combination of hydrodynamic cavitation with these disinfection technologies demonstrated a synergistic effect. Hydrodynamic cavitation coupled with 5 mg/L H<sub>2</sub>O<sub>2</sub> dosing generated 90% removal of fecal coliforms after 60 minutes, compared to just 21% removal produced after 60 minutes of 5 mg/L H<sub>2</sub>O<sub>2</sub> dosing alone [Jyoti & Pandit, 2003]. When hydrodynamic cavitation treatment alone was employed during this study, a fecal coliform disinfection efficiency of 89% was observed after 60 minutes, indicating that the addition of hydrodgen peroxide did little to increase the disinfection capacity of the cavitation device. Hydrodynamic cavitation coupled with 0.5 mg/L dosing of ozone generated a fecal coliform

disinfection efficiency of 80% after 15 minutes of treatment, compared to disinfection efficiencies of 68% and 57% observed after 15 minutes of 0.5 mg/L ozone dosing and hydrodynamic cavitation treatment, respectively [Jyoti & Pandit, 2004]. However, the treatment times utilized during these studies are longer than is practical for cooling water treatment.

The application of hydrodynamic cavitation disinfection systems requires continued research for optimization of efficiency. The use of hybrid systems which couple hydrodynamic cavitation with other processes (both chemical and physical) should be further investigated, as the results of some preliminary hybrid process studies [Jyoti & Pandit, 2003; Jyoti & Pandit, 2004] have demonstrated potentially high disinfection efficiencies. Additionally, different hydrodynamic cavitation system designs must be compared to determine which means of inducing cavitation produces the strongest biocidal effect. The ability of hydrodynamic cavitation systems to eliminate *Legionella* has been demonstrated in the laboratory, but further field research is necessary to verify these findings. Additionally, hydrodynamic cavitation systems may affect the heat transfer efficiency of the water being treated, a subject which warrants further investigation in order to be substantiated [Gaines, 2007]. Like ultrasonic cavitation treatment, hydrodynamic cavitation does not produce any form of residual treatment.

## **2.0 EXPERIMENTAL PROTOCOL**

The following section will provide a detailed outline of the project performance. The objectives of the investigation will be described, and the materials and methods used for the completion of the study will be presented. This section will include a description of all parameters monitored during each experiment, frequency and method of measurement, and specific instrumentation used for sample analysis. In addition, a description of each non-chemical treatment device evaluated during this investigation will be provided.

### **2.1 SPECIFIC OBJECTIVES**

The primary objective of this investigation was to evaluate the ability of five (5) non-chemical water treatment devices to significantly reduce the microbial population within a pilot-scale cooling water system. This objective was accomplished in a well-controlled study in which two identical cooling water systems were operated simultaneously. One tower received treatment from the non-chemical device being tested, while the other tower received no treatment for the duration of the experimental trial. Each device was activated at the beginning of the trial and allowed to operate for the duration of the experiment (4 weeks). In addition, the performance of non-chemical devices for the control of biological growth in pilot-scale cooling

towers was compared to standard chemical treatment protocol (i.e., chlorination) that was performed several times during this study as positive control (Section 4.7.) for experimental validation.

## 2.2 MATERIALS AND METHODS


### 2.2.1 Cooling Tower System Description

Two pilot-scale model cooling tower systems were used to evaluate the performance of each device. The two model cooling towers used in this study were designed to be identical. A schematic outlining the cooling system setup for each tower is shown in **Figure 1**.

In each pilot-scale system, water is stored in a 60 gal. holding tank prior to being pumped at a rate of 7 gpm by a 2 hp centrifugal pump into a stainless steel heating bath. The system flow rate is controlled by the use of a side stream placed immediately after the pump discharge. This sidestream returns a portion of the flow back to the 60 gal. holding tank. The rate of return flow is controlled by a needle valve, allowing the tower operator to manually adjust the system flow rate to approximately 7 gpm.

Immediately prior to entering the heating bath, the flow of water is split into two paths, and each flow path continues into a coil of 1/2" OD copper tubing. The two coils (approximately 105 ft. and 44 ft.) wrap around a 15 kW immersion heater, and the entire heating apparatus is surrounded by a stainless steel box containing dechlorinated water. The box is sealed by a lid made of 1/2 in. thick plexiglass in order to minimize evaporative losses. The immersion heater is

controlled by a thermostat, which was adjusted throughout the experimental trials to maintain a water bath temperature of approximately 120°F. This heating bath temperature provides enough thermal energy to elevate the temperature of the system water to 95-100°F.



**Figure 1 - Pilot-Scale Cooling System Schematic**

Once the system water passes through the two copper coils, the flow paths are combined.

The flow is then diverted through a sampling rack containing a series of sampling coupons. The

sampling coupons were 5.61 cm<sup>2</sup> stainless steel washers which were scrubbed and autoclaved at 121°F prior to installation in the experimental towers. These coupons were installed at the beginning of each device trial, and they were used to quantify biofilm growth within each of the cooling tower systems. Coupons were installed parallel to the direction of flow.

Upon exiting the sampling rack, the system flow passes through a number of sensors for data collection. Flow passes past a pH probe, an ORP probe, a conductivity probe, and a thermometer designed to record the water temperature prior to tower entrance. Each of these probes is connected to an AquaTrac Multiflex data collection system, which records data values at 1-hour intervals. The flow then passes through a flow meter to ensure that system flow rate of 7 gpm is maintained. Immediately prior to tower entrance, the flow passes over an additional conductivity meter. This conductivity meter is connected to a blowdown control system which uses conductivity readings to control when the tower goes through blowdown based on a user-defined blowdown conductivity setpoint. The setpoint is chosen based on the make-up water conductivity, and it was selected to produce 4-5 cycles of concentration in the cooling tower system.

Flow enters each of the cooling towers by way of a 110° full cone square spray nozzle. This allows the flow to be distributed evenly over the surface of the CF1200 packing (Brentwood Industries) which is installed in each tower. The height of the packing in each tower is adjusted so that the spray from the nozzle contacts the packing at its uppermost edge, diverting flow through the interior of the packing rather than down the side wall of the tower. A total of three units of packing (1 ft<sup>3</sup> each) were installed vertically in each tower system, for a total packing height of 3 ft.

Once the water has travelled through the packing, it is deposited into a 20 gal. sump. To ensure an even flow distribution across the packing, water flow was measured at several points across the packing's cross sectional area (**Table 1**). In order to minimize water losses from splashing, screening was placed around the perimeter of each towers' support legs.

**Table 1 - Water flow (gpm) distribution across packing**

A	B	C
D	E	F
G	H	I

Packing Measurement Locations (Cross-Sectional View)

	A	B	c	D	E	F	G	H	I
T1	0.465	0.343	0.375	0.655	0.396	0.417	0.517	0.480	0.306
T2	0.422	0.322	0.338	0.449	0.475	0.549	0.581	0.607	0.602

Upon entering the sump, the water temperature decreased to 85-90°F, thereby maintaining a temperature differential across the packing of approximately 10°F. This cooling is accomplished by a variable frequency axial fan placed at the top of the tower, above the water entrance. The rate of airflow generated by this fan is controlled by a potentiometer to produce the desired 10°F temperature differential. A distribution of the airflow across the width of the tower is shown in **Table 2**. The 20 gal. sump is connected to the 60 gal. holding tank via a 2 in. diameter PVC pipe, and as water travels through the system it is pulled from the 20 gal. sump back into the 60 gal. holding tank, completing the cooling water cycle.




Make-up water used for all experiments in this study was dechlorinated City of Pittsburgh tap water. Dechlorination was accomplished by passing the water through a fixed-bed activated carbon adsorber [Loret *et al.*, 2005]. The cylindrical activated carbon adsorber had a height of 6 ft. and a diameter of 12 in. The column contained 33 L of activated carbon (TIGG 5DC 0830, coconut shell based, 8 x 30 mesh size, activity = 1000; manufactured by TIGG Corporation), and the flow rate through the column during make-up water generation was maintained at or below 3 gpm in order to ensure a minimum contact time of 3 min. Make-up water for each cooling tower was stored in four 125-gal polyethylene tanks to provide enough water for two days of tower operation (approximate tank residence time = 48 hrs). In between device trials, the carbon column was flushed by running water through it at twice the flow rate necessary for chlorine removal (> 6 gpm) for a minimum of 1 hr.

### **2.2.2 Device Trial Protocol**

For each device trial, a control tower and a test tower were utilized. The control tower (T1) received no treatment during the testing process, while the device tower (T2) received treatment from the device being evaluated. The device was activated at the beginning of the study, and it was not turned off until the investigation had been completed. For the remainder of this report, the control tower in each device trial will be referred to as T1 (Control), and the device tower will be referred to as T2 (Device). Lights in both the shower room containing the two test towers and the locker room containing the make-up water storage tanks were kept on

throughout the duration of each device trial. No algal growth was observed in either of the towers or the make-up water storage tanks during any of the device trials or chlorination tests.

**Table 2 - Airflow distribution across tower. Highlighted value indicates operating airflow rates**



Fan Potentiometer Setting	Airflow Velocity (ft/s)		
	1	2	3
10	900	1020	810
9	678	920	720
8	691	800	503
7	660	760	330
6	545	680	215

A total of five (5) non-chemical water treatment devices were tested over the course of this investigation. A device testing schedule is shown in Table 3. Before the beginning of each device trial, several measures were taken to ensure consistent starting conditions. Each tower received 4 gal. of dilute acetic acid and 250 mL of 5.25% sodium hypochlorite solution, and the towers were allowed to operate for several hours in order to eliminate any residual microorganisms present in the system and to remove scale formed during the previous trial. Both towers and their corresponding sumps and holding tanks were scrubbed with 5% acetic acid to remove as much scale as possible. Each system was drained completely using a shop vacuum,

and refilled with clean make-up water. The draining and refilling process was repeated a minimum of 2 times for each tower prior to the beginning of a new device trial. Make-up water storage tanks were also drained and refilled prior to the beginning of a new device trial. Device trials began less than 24 hours after the final refilling of both the tower systems and the make-up water storage tanks. Additionally, the plastic packing in each of the towers was replaced prior to the initialization of a new test. The new packing was installed after the tower had been drained and rinsed to reduce the amount of residual solid material which it collected.

**Table 3 – Non-chemical device testing schedule**

<b>Device Name Abbreviation</b>	<b>Treatment Technology</b>	<b>Test Date Range(s)</b>	<b>Total Days of Testing</b>	<b>Phase I Completed</b>	<b>Phase II Completed</b>
MD	Magnetic	2/11/09 - 3/2/09, 3/13/09 - 4/20/09	56	YES	NO
PEFD	Pulsed Electric Field	5/2/09 - 5/30/09, 6/12/09 - 7/10/09	58	YES	NO
ED	Static Electric Field	7/18/09 - 8/15/09	29	YES	NO
UD	Ultrasound	9/2/09 - 9/30/09	29	YES	NO
HCD	Hydrodynamic Cavitation	10/27/09 - 11/24/09	29	YES	NO

In order to maximize the cooling potential of the packing, each tower underwent a “seasoning” process prior to trial onset. This process was in accordance with the packing manufacturer’s specifications. To season the packing, each tower was allowed to operate with a heat load for approximately 1 hour. Following this period of operation, each tower system was shut off, allowing heated water deposited on the packing surface to evaporate, leaving a thin layer of deposited minerals on the packing surface. This process was repeated a minimum of two times prior to the beginning of each device trial, and the entire process occurred over

approximately 3 days. Each tower system was drained and replenished following the final seasoning of the packing.

Throughout the course of the study, water temperature measurements were taken at regular intervals to determine both the temperature of the water entering the tower system and the water in the sump. Measurements of the water temperature entering each of the tower systems were taken every hour using an AquaTrack MultiFlex data logging device. A manual reading of this temperature for each tower system was recorded on a daily basis. Sump temperature measurements were taken every 15 minutes using a portable thermologger (Omega Scientific). Additionally, manual sump temperature measurements were taken daily using a handheld thermometer.

A number of physical, chemical, and biological parameters were monitored during the performance of each device trial. The parameters measured, as well as their corresponding frequencies of measurement, are shown in Table 4. Immediately following this table is a description of the protocol used for biofilm sampling. A picture of the biofilm sampling coupon setup is shown in **Figure 2**.


**Table 4 – Physical, chemical, and biological parameters analyzed during investigation**

<b>Parameter</b>	<b>Source</b>	<b>Frequency of Measurement</b>	<b>Standard Method</b>	<b>Device</b>
<b>Temperature Entering Tower</b>	Tower	Continuous	-	AquaTrac Multiflex
<b>Sump Temperature</b>	Tower	Continuous	-	Digital Thermometer
<b>pH</b>	Make-up and Tower	Daily	-	Fisher Accumet pH meter Model 25
<b>ORP</b>	Tower	Daily	-	Fisher Accumet pH meter Model 25 with ORP selective electrode
<b>Conductivity</b>	Make-up and Tower	Continuous	Method 2510	Sybron-Barnstead Conductivity Bridge (Model PM-70CB)
<b>Alkalinity</b>	Make-up and Tower	Daily	Method 2320 B	-
<b>TDS</b>	Tower	Daily	Method 2540	-
<b>TDS</b>	Make-up	Monthly	Method 2540	-
<b>Chloride</b>	Make-up and Tower	Weekly	Ion Chromatography	Dionex 4500 Ion Chromatograph with conductivity detector
<b>Chlorine</b>	Make-up	Weekly	DPD Method	Hach DR 2010 Spectrophotometer
<b>Calcium Hardness</b>	Tower	Daily	Method 3111 B, Method 2340 B	Perkin Elmer 1100B atomic absorption spectrophotometer
<b>Magnesium Hardness</b>	Tower	Daily	*	*
<b>Total Hardness</b>	Tower	Daily	*	*
<b>Calcium Hardness</b>	Make-up	Monthly	*	*
<b>Magnesium Hardness</b>	Make-up	Monthly	*	*
<b>Total Hardness</b>	Make-up	Monthly	*	*
<b>Planktonic Heterotrophic Plate Count</b>	Make-up and Tower	Bi-weekly	Method 9215	-
<b>Sessile Heterotrophic Plate Count</b>	Tower	Weekly	Method 9215 (See below for procedure)	-
<b>ATP</b>	Make-up and Tower	Bi-weekly	[QGA Quick-Reference Guide, 2007]	LuminUltra Technologies Ltd. Quench-Gone Aqueous (QGA) ATP test kit

## Biofilm Sampling Protocol

**\*\*Close valves to bypass coupon rack\*\***

1. Put on gloves
2. Unscrew coupon holder from rack and remove
3. Swab bottom of coupon before unscrewing
4. Hold coupon over sterile conical tube and unscrew nut
5. Release coupon into 5 mL conical tube – bottom side down
6. Swab top of coupon and add 10 mL of sterile water to tube
7. Place swab into tube and agitate vigorously to remove attached material from swab. Cut or break swab and leave in the tube
8. Transport sample to lab as soon as possible
9. Vortex for 30 sec before testing the sample liquid. Process for HPC using appropriate dilution scheme
10. Total CFU recovered is calculated by multiplying CFU x 10 mL sample volume
11. Divide total CFU by surface area of the coupon ( $5.61 \text{ cm}^2$ ). Report coupon results as  $\text{CFU}/\text{cm}^2$
12. Save coupon and sterilize for reuse



**Figure 2 – Diagram of biofilm sampling coupon setup**

Bulk water samples were collected using sterilized sampling bottles. Biofilm samples were collected using the protocol described below. All biological samples were kept chilled during transport to the laboratory. Upon arrival, samples were shaken thoroughly and subject to a series of dilutions. The dilutions used were determined using pre-device trial testing, which indicated the levels of microbial growth to be expected in each of the towers, as well as in the make-up water.

A series of three dilutions was plated for each bulk water and biofilm sample. Ten-fold dilutions were accomplished by transferring 1.0 mL of sample water to a test tube containing 9.0 mL of sterilized deionized water. Hundred-fold dilutions were accomplished by transferring 0.1 mL of sample water into a test tube containing 9.9 mL of sterilized deionized water. The range of dilutions used for make-up water analysis was  $10^{-2} - 10^{-4}$  for this investigation, while the bulk water tower dilution range was  $10^{-3} - 10^{-5}$  and the biofilm sample dilution range was  $10^{-4} - 10^{-6}$ . Fresh sterilized pipette tips were used for each volumetric transfer during the dilution process. Dilutions were plated according to Standard Method 9215 pour plate protocol.

The measurement of cellular ATP was performed using a test kit manufactured by LuminUltra™ Technologies Ltd. This test kit was used to measure relative light units (RLUs) passing through a sample. By comparing the measured number of RLUs to a standard of a known concentration of ATP, it was possible to determine the concentration of ATP present in each tower system biological sample. The following equation was used to calculate cellular ATP (cATP) [QGA Quick-Reference Guide, 2007]:

$$cATP \left( \frac{pg}{mL} \right) = \frac{RLU_{Measured}}{RLU_{UltraCheck}} \times \frac{10000}{Sample\ Volume\ (mL)}$$

In this equation,  $RLU_{UltraCheck}$  refers to the measured RLUs passing through a standard of known ATP concentration. For all measurements, a sample volume of 50 mL was used. Cellular ATP was used to determine the number of microbial equivalents present in each sample for comparison with heterotrophic plate counts. This was done using the following equation [QGA Quick-Reference Guide, 2007]:

$$Microbial\ Equivalents\ \left(\frac{\#}{mL}\right) = c_{ATP}\ \left(\frac{pg}{mL}\right) \times 1000$$

### 2.2.3 Chemical Disinfection Test Protocols

During the course of investigating the effectiveness of NCDs for the control of biological growth in cooling towers, three chlorination tests were performed. These tests, which involved the addition of chlorine to the device tower (T2), are essential to provide scientifically defensible evidence that industry-tested disinfection methods are capable of controlling microbial growth in the experimental system operated in this study. Demonstrating the effectiveness of these disinfection tests indicates that the comparison between accepted and experimental treatment mechanisms is valid.

The selection of free chlorine as a positive control was based on common practice in cooling water treatment and a previous study where several chemical biocides, including free chlorine, were evaluated in model cooling towers that simulated real-world cooling tower operational conditions [Thomas *et al.*, 1999]. The Thomas *et al.* investigation was performed



using a series of cross-flow cooling tower cells. Prior to the performance of disinfection trials, the researchers demonstrated that the tower cells were capable of generating and maintaining a heterotrophic bacterial population  $>10^6$  CFU/mL after 48 hrs of operation. In the first phase of the Thomas et. al. study, the chlorine treatment protocol (0.5-1.5 ppm as free residual oxidant) reduced planktonic heterotrophic bacteria by at least 3 orders of magnitude (99.9%) and reduced heterotrophic bacteria in biofilms by 3-4 orders of magnitude (99.9+%) compared to controls. This study demonstrated that chlorination may be used as an effective means of biological control when applied to a model cooling tower system, and its application to a pilot-scale system can produce results which directly reflect those observed in full-scale cooling systems.

### **2.2.3.1 Pre-Device Trial Chlorination Test Protocol**

The first chlorination test was performed prior to the beginning of the device trials. During this test, both T1 (Control) and T2 (Device) operated untreated from 1/15/09 – 1/22/09. After samples were taken on 1/22, a spike dose of chlorine (80 mL of 5.25% sodium hypochlorite supplied by Fisher Scientific) was added to each of the towers, resulting in an initial chlorine dose of approximately 14 mg/L. Following this spike dose, chlorine stock solution was pumped into each tower system to maintain a chlorine concentration of approximately 1 mg/L for 3 days. For this chlorination test, the stock solution was prepared by adding 60 mL of 5.25% sodium hypochlorite solution per gallon of dechlorinated water, resulting in a free chlorine concentration of 832 mg/L.

For the first day of chlorination, chlorine stock solution was pumped into each tower at a rate of 5 mL/min. Flow rates for the 2<sup>nd</sup> and 3<sup>rd</sup> days of chlorination were approximately 3 mL/min and 2 mL/min, respectively, as a result of decreased chlorine demand due to microbial inactivation. Overall, the total volume of chlorine stock solution added to each tower during this 3-day test was 14.4 L, corresponding to a total chlorine mass added to each tower of approximately 12 g. The average makeup water consumption rate for each tower was approximately 130 gal/day and the average initial chlorine feed for each tower can be estimated at approximately 8 mg/L. Considering that the chlorine residual in each tower was maintained at approximately 1 mg/L, the disinfectant demand for this experimental system heavily colonized with microbial growth can be estimated at approximately 7 mg/L.

### **2.2.3.2 ED/UD Chlorination Test**

The second chlorination test was performed immediately after the ED trial and immediately before the towers were prepared for the UD trial. During this chlorination test, T2 (Device) received chemical treatment, while T1 (Control) remained untreated. Chlorination began on 8/21 after biological samples were taken, and it was performed for three days. The sodium hypochlorite purchased from Fischer Scientific was consumed during the cleaning processes following the MD and PEFD device trials, and new sodium hypochlorite solution had to be purchased. The sodium hypochlorite solution used for this chlorination test was 6.0% household bleach.

The chlorination process began with a spike dose of chlorine (80 mL of 6.0% sodium hypochlorite), resulting in an initial chlorine dose of approximately 16 mg/L. This shock dose was followed by a steady flow of chlorine stock solution in order to maintain a free chlorine concentration of approximately 1 mg/L. The stock solution was prepared by adding 52 mL of 6.0% sodium hypochlorite per gallon of dechlorinated water for an approximate concentration of 832 mg/L. The flow rate of chlorine stock solution on days 1, 2, and 3 of chlorination were 5 mL/min, 3 mL/min, and 2 mL/min, respectively. Overall, the total volume of chlorine stock solution added to each tower during this 3-day test was 14.4 L, corresponding to a total chlorine mass added to each tower of approximately 12 g. The average makeup water consumption rate for each tower was approximately 130 gal/day and the average initial chlorine feed for each tower can be estimated at approximately 8 mg/L. Considering that the chlorine residual in each tower was maintained at approximately 1 mg/L, the disinfectant demand for this experimental system heavily colonized with microbial growth can be estimated at approximately 7 mg/L.

### **2.2.3.3 UD/HCD Chlorination Test**

The third chlorination test was performed immediately following the UD trial and immediately before the towers were prepared for the HCD trial. Chlorination of T2 (Device) began on 10/1 following biological sampling, and it was performed using a steady dose of chlorine stock solution. The sodium hypochlorite solution used for this chlorination test was 6.0% household bleach manufactured by Target Corporation. The stock solution was prepared by adding 52 mL

of 6.0% sodium hypochlorite per gallon of dechlorinated water for an approximate concentration of 832 mg/L.

No shock dose of chlorine was used for this test, but instead a gradual increase in chlorine concentration was performed over a period of 5 days until the residual concentration reached 1 mg/L. The flow rate of chlorine stock solution on day 1 was approximately 8 mL/min. The flow rate was decreased to 6 mL/min on day 2, 5 mL/min on day 3, 3 mL/min on day 4, and 2 mL/min on day 5. Overall, the total volume of chlorine stock solution added to each tower during this 5-day test was 34.6 L, corresponding to a total chlorine mass added to each tower of approximately 29 g (in the absence of an initial shock dose of chlorine). The average makeup water for each tower was approximately 130 gal/day and the average initial chlorine feed for each tower can be estimated at approximately 11.4 mg/L. Considering that the chlorine residual in each tower was maintained at approximately 1 mg/L, the disinfectant demand for this experimental system heavily colonized with microbial growth can be estimated at approximately 10.4 mg/L. While this demand was higher than the previous 2 chlorination tests, this may be attributed to the fact that no initial shock dose of chlorine was applied during this test.

## 2.3 NON-CHEMICAL DEVICES

### 2.3.1 Magnetic Device (MD)

The magnetic device evaluated in this investigation consists of a 13” flow-through cylinder which exposes water to 4 alternating magnetic poles. A diagram of the device is shown in **Figure 3**. Since the device utilizes fixed magnetic fields to condition the water, it requires protection from electromagnetic fields generated by high-voltage electronic devices. In order to prevent any interference with the MD by the 3-phase centrifugal pump used to pump water through the cooling system, a lead shield was installed around the device during the testing period.





Figure 3 – Magnetic device (MD) diagram [Lin & Nativ, 1988]

The MD is marketed as a scale-inhibiting water conditioner. The manufacturer does not claim that the device is capable of microbiological control. According to the manufacturer, the device operates by keeping mineral ions, such as calcium and magnesium in suspension, thereby preventing them from forming scale on cooling surfaces [Cho, 2002]. Instead, mineral compounds form in suspension, leading to the formation of a precipitate, which is easily removed from cooling system surfaces. This reduction in scale formation leads to increased system operational efficiency, while at the same time reducing water and energy consumption.


### **2.3.2 Pulsed Electric Field Device (PEFD)**

The pulsed-power (electrostatic) non-chemical treatment device evaluated in this investigation is composed of two primary components: the signal generator and the treatment module. The signal generator is housed in a stainless steel box, and it contains all of the system's replaceable parts. LEDs installed in the front of the box are used to ensure proper operation, while ventilation slits on both sides of the unit allow for fan-powered cooling of the interior electronics. A power connection is also included in the signal generator, and it operates at a voltage of 115V / 60Hz. The treatment module, which consists of a 1" diameter PVC cylindrical flow-through reactor, is connected to the signal generator via an umbilical cable. A diagram of the treatment module is shown in **Figure 4**.



**Figure 4 – Pulsed electric field device (PEFD) treatment module diagram [PEFD Technical Manual, 2008]**

Operation of the pulsed electric field device involves the application of “pulsed, high-frequency electric fields into flowing water” [PEFD Technical Manual, 2008]. The characteristic waveform generated by the system’s signal generator is shown in **Figure 5**. According to the manufacturer, the device is capable of controlling scale formation, equipment corrosion, microbial populations, and algal growth in a cooling water system.



**Figure 5 – PEFD characteristic waveform [PEFD Technical Manual, 2008]**

The PEFD manufacturer claims that scaling is controlled via the interaction between the pulsating electromagnetic field produced by the signal generator and suspended particles in the water. According to the literature provided by the manufacturer, the PEFD “activates the suspended particles by removing the static electric charge on their surface” [PEFD Technical Manual, 2008]. By removing this electric charge, interactions between molecules found in water lead to the formation of a powdery calcium carbonate precipitate, as opposed to the formation of a thick calcium carbonate scale on system surfaces. The precipitated calcium carbonate may then be removed either through filtration or normal tower blowdown.

Biological control by PEFD is proposed to occur by two separate pathways. The first is encapsulation, where the precipitate formed as a result of the interaction between suspended particles clusters around microorganisms which are present in the cooling water system. Bacteria normally would repel these particles due to their static charge. However, by removing this static charge the PEFD allows for these suspended particles to collect around microbes, encasing them and effectively inactivating them by preventing any further microbial reproduction from occurring. The second pathway by which microbial control is proposed to occur is electroporation, which involves a physical rupturing of the membrane of planktonic bacteria. The “high frequency, pulsing action of the PEFD electric fields” leads to the formation of holes within the outer membrane of microorganisms which pass through the treatment module [PEFD Technical Manual, 2008]. As a result of this membrane damage, microorganisms spend the remainder of their 1-2 day lifespan repairing external cellular damage, eliminating their reproductive capacity and effectively rendering them inactive. The combined effect of encapsulation and electroporation is suggested to lead to a reduction in total bacterial counts in systems which utilize the PEFD.



In addition to the control of planktonic microbial population, it is proposed that the PEFD is also capable of biofilm formation prevention. This control may result from the interaction between planktonic and sessile microorganisms in cooling water systems. Planktonic bacteria generate specific nutrients which are then absorbed and utilized by sessile bacteria. The elimination of planktonic bacteria via encapsulation and electroporation greatly reduces the concentration of these nutrients present in the system's water supply. As a result, the sessile microbial population present in the system is claimed to be greatly reduced.

Corrosion control by the PEFD is a result of the prevention of scale formation and the reduction of the sessile and planktonic microbial populations within the system water. The formation of calcium carbonate precipitates is thought to act as a preventive measure against corrosion, acting as a "cathodic corrosion inhibitor," which "greatly slows the corrosion process by blocking the reception of electrons that are thrown off by the corrosion process" [PEFD Technical Manual, 2008]. Several microorganisms which commonly populate cooling water systems generate corrosive byproducts, such as hydrogen sulfide. By controlling the reproduction of these organisms, the PEFD may be able to reduce the concentrations of these corrosive byproducts, reducing the overall corrosion rate of the system water. As a result, the device manufacturer claims that both localized and uniform corrosion rates are significantly decreased by the application of their device.

The PEFD was installed in the cooling tower system used in this study according to the manufacturer's specifications. The treatment module was placed directly after the centrifugal pump and immediately before the heat bath. According to the manufacturer, the treatment module may also be placed directly after the heat exchanger but before the entrance of water into the cooling tower.

### 2.3.3 Electrostatic Device (ED)

The ED is an electrostatic treatment device designed to “control scaling, inhibit corrosion, [and] minimize biological fouling without chemical additives” [Environmentally Sustainable Cooling Tower Treatment, 2008]. The device was composed of a 1” flow-through reactor vessel as shown in **Figure 6**.



**Figure 6 – Electrostatic device (ED) photograph**

The technology by which the ED operates is similar in principle to that employed by the PEFD. While the PEFD bombards the water with pulses of electromagnetic energy, the ED exposes the water in the reactor chamber to a steady electrostatic field. Mineral ions are kept in suspension through the application of this field. This field increases molecular collisions between suspended particles, causing them to form precipitates which may easily be removed from cooling systems rather than hard scale on system surfaces. This process removes ions from

solution, which allows for the dissolution of scale which has already formed [Environmentally Sustainable Cooling Tower Treatment, 2008]. Possible mechanisms for the control of biological growth in the system would be very similar to those described for the PEFD.

#### **2.3.4 Ultrasonic Device (UD)**

The UD operates by diverting water from the cooling system sump or holding tank through a venturi and into an ultrasonic treatment cell. Once the flow velocity has been increased by passing through the venturi, air is introduced into the water stream. According to the manufacturer, the vacuum pressure generated by the venturi during normal operation should be between 0.4 and 0.75 bar below atmospheric pressure [UD Operation Manual, 2008]. The water/air mixture then enters an ultrasonic treatment chamber containing 6 ceramic transducers. Upon exiting the treatment cell, the water passes through a basket filter prior to discharge back into the cooling system sump.

The ultrasonic device was installed according to the manufacturer's specifications, and a representative from the manufacturer approved the final installation. A sidestream was constructed for the application of this device, with the sidestream intake positioned near the outlet end of the 60 gallon storage tank and the outflow positioned near the storage tank's inlet. A diagram of the ultrasonic device is shown in **Figure 7**.




Figure 7 – Ultrasonic device (UD) diagram [UD Operation Manual, 2008]


### 2.3.5 Hydrodynamic Cavitation Device (HCD)

Operation of the HCD involves the diversion of water from the cooling system sump or holding tank into the device, where treatment is administered and the water is returned to the sump from which it was initially withdrawn. Water drawn from the system sump enters a pressure-equalization chamber. The flow of water is then split into two separate streams and each of these streams enters a vortex nozzle. This nozzle “...impart[s] a specific rotation and velocity to the water streams” [HCD Technology: A Primer, 2008] to create a conical flow path for each of the streams, and these streams are forced to collide in a low-pressure stabilizing chamber.

The collision of these two conical streams creates a vacuum region which results in the formation of cavitation bubbles. In turn, the collapse of these bubbles generates local regions of high shearing forces, temperatures, and pressures, leading to microbial inactivation. Additionally, "...the hydrogen-bonding molecular arrays of water are broken down, thereby allowing entrapped gasses, such as CO<sub>2</sub>, to be released and off-gassed to [the] atmosphere." [HCD Technology: A Primer, 2008].

The manufacturer of the HCD claims that the device is capable of controlling biological growth and scaling, in addition to corrosion protection. Case studies of similar system operation provided by the manufacturer indicate that bacterial plate counts of < 10,000 CFU/mL and levels of *Legionella* below detectable limits may be achieved by proper system operation [Scappatura, 2002]. Additionally, the systems described in these case studies provided a visible reduction in system scaling, while at the same time reducing mild steel corrosion rates to < 2.5 MPY and copper corrosion rates to < 0.3 MPY [Scappatura, 2002]. As a result, the system was able to reduce blowdown volumes by over 70% [Scappatura, 2002].

The HCD was installed according to the manufacturer's specifications, and a representative from the manufacturer approved the final installation. The sidestream used for the ultrasonic device trial was reused. In order to allow for adequate CO<sub>2</sub> degassing, the outlet end of the sidestream was cut so that water was expelled above the sump water surface level. Plastic sheeting was installed around the sidestream outlet in order to minimize water losses from splashing. A diagram of the HCD reaction chamber provided by the manufacturer is shown in **Figure 8.**



**Figure 8 – Hydrodynamic cavitation device (HCD) reaction chamber diagram**

### **3.0 EXPERIMENTAL REPRODUCIBILITY**

Each of the five non-chemical water treatment devices was tested for a minimum of 4 weeks. Some tests were repeated due to operational problems. Additionally, chlorination tests were performed between some device trials in order to demonstrate that the microbial population in the towers could be controlled using a traditional approach (i.e. chemical treatment). The chemical parameter values collected during each investigation were used to calculate 3 different scaling indices. The calculation and interpretation of these indices are outlined in Appendix A.

The make-up water quality and performance of T1 (Control) throughout the course of the entire investigation were monitored in order to ensure similar conditions of operation for each individual device trial. These data were compared using statistical analyses to verify that operating conditions were not biased for any of the experimental device trials. This comparison provides evidence of experimental reproducibility by demonstrating consistent and realistic operating conditions over the course of the investigation.

The reproducibility of this investigation is governed by two main factors: make-up water quality and conditions in T1 (Control). In order to verify that each experimental device operated under similar conditions during its respective device trial, it is necessary to analyze the make-up water entering each of the two tower systems for similarity during each device trial. Additionally, it is necessary to demonstrate that control conditions were essentially constant over

the duration of the entire experiment. Data figures and tables demonstrating experimental reproducibility in terms of physical/chemical parameters of make-up water and T1 (Control) operating conditions are included in Appendix B.

### 3.1 MAKE-UP WATER QUALITY

Both chemical and biological characteristics of the make-up water were monitored regularly over the course of the experiment. Chemical parameters of make-up water quality are shown in Appendix B.1, while the average values for the measured physical and chemical make-up water parameters are shown in **Table 5**. Detailed monthly measurements are shown in **Figure B1 – Figure B4** of Appendix B and summarized in **Table B1**.

**Table 5 – Average values for make-up water**


<b>Make-up Water Summary Table</b>		
	<b>Average</b>	<b>Standard Deviation</b>
<b>Conductivity (mS/cm)</b>	0.307	0.039
<b>pH</b>	7.33	0.22
<b>Alkalinity (mg/L as CaCO<sub>3</sub>)</b>	26	5
<b>Calcium Hardness (mg/L as CaCO<sub>3</sub>)</b>	28	7.3
<b>Magnesium Hardness (mg/L as CaCO<sub>3</sub>)</b>	24	5.9
<b>Total Hardness (mg/L as CaCO<sub>3</sub>)</b>	52	11
<b>TDS (mg/L)</b>	208	25
<b>Chloride (mg/L)</b>	37	4
<b>Free Chlorine (mg/L)</b>	0.017	0.009
<b>Copper (mg/L)</b>	ND	-
<b>Iron (mg/L)</b>	ND	-
<b>Sulfate (mg/L)</b>	40.7	6.3
<b>Phosphate (mg/L)</b>	1.15	0.32
<b>Planktonic HPC (CFU/mL)</b>	2.66E+04	6.13E+04



### 3.1.1 Biological Parameters

Average planktonic HPC in make-up water for each device trial are summarized in **Figure 9**.

**Figure 10** shows the variation in planktonic HPC in the make-up water for each trial. A comparison of these parameters demonstrates that, while fluctuations in both the biological and chemical composition of the make-up water were observed over the course of the experiment, these fluctuations did not alter conditions to an extent which would have adversely affected experimental reproducibility.



**Figure 9 – Average make-up water planktonic microbial population (HPC) during each device trial. Error bars represent range of observed values (maximum and minimum)**




Figure 10 – Make-up water planktonic microbial populations (HPC) for each device trial

### 3.1.2 Summary

The average heterotrophic plate count for the make-up water over the course of the entire investigation was  $10^{4.4}$  CFU/mL. While this value is higher than the EPA mandatory potable water quality standard ( $< 500$  CFU/mL or  $< 10^{2.7}$  log CFU/mL), it does not demonstrate an excessive or unrealistic level of microbial activity in the make-up water. Planktonic heterotrophic plate count values for a variety of potential make-up water sources are shown in **Table 6**. The water sources highlighted in this table include household taps, which may be used as make-up water sources in small-scale cooling systems, as well as potential natural make-up

water sources for large-scale cooling systems such as lakes and harvested rainwater. **Table 6** indicates that, while the average make-up water planktonic microbial population used in this study exceeds potable water quality standards, it is comparable to other potential make-up water sources.

**Table 6 – Concentrations of heterotrophic plate count (HPC) bacteria in various water sources**

<b>Water Source</b>	<b>HPC Planktonic Bacteria Count (log CFU/mL)</b>	<b>Reference(s)</b>
Drinking water from household taps (<1 mi. from treatment plant), New Jersey	Range = 1.0 – 4.0+	LeChevallier <i>et al.</i> , 1987
Tuscon, AZ household tap	Average = 3.5	Pepper <i>et al.</i> , 2004
Tuscon, AZ household tap	Range = 1.0 – 4.7 Average = 4.0	Chaidez & Gerba, 2004
Warm tap water, hospital building	Average = 4.8	Sheffer <i>et al.</i> , 2005
Rainwater harvesting system, Seoul, Korea	Range = 3.2 – 3.3	Amin & Han, 2009
Hot water systems, Copenhagen, Denmark	Average = 4.0+	Ovesen <i>et al.</i> , 1994; Bagh <i>et al.</i> , 2002
Hot water tank, apartment building, Copenhagen, Denmark	Range = 4.8 – 5.0	Bagh <i>et al.</i> , 2003
Michigan freshwater lakes (bulk water)	Average = 3.5	Jones <i>et al.</i> , 1991
16 community taps and 5 industrial process water basins	Range = 2.7 – 6.0	Jousimies-Somer <i>et al.</i> , 1993
Cooling tower water (basins)	Range = 3.0 – 7.0	Bentham, R.H., 1993
Drinking water distribution systems, Durham and Raleigh, NC	Range = <1.0 – 4.0+	Zhang & DiGiano, 2002
Drinking water distribution systems, Irvine and Garden Grove, CA	Range = <2.0 – 3.4+	Ridgway & Olson, 1982
<b>ASHRAE Project 1361-RP cooling tower make-up water</b>	<b>Range = 2.3 – 5.6 Average = 4.4</b>	

## 3.2 T1 (CONTROL) CONDITIONS

Because the T1 (Control) tower was operated under similar conditions during all device trials except for PEFD Trial 2/2, the data collected from T1 (Control) during each individual device trial may be consolidated and analyzed in order to determine whether or not operating conditions were comparable between the trial. Complete data collected throughout the T1 (Control) tests are shown in Appendix B.2.

### 3.2.1 T1 (Control) System Operation

Average values for all of the experiments with T1 (Control) are shown in **Table 7**. The target temperature differential throughout the investigation was 10 °F, while a temperature differential of approximately 9-13 °F was maintained for all NCD tests. The only exception was the test conducted with the MD, where operational problems with the heating unit in T1 (Control) resulted in a slightly larger temperature differential.

**Table 7 – Average values for T1 (Control)**

	<b>T1 (Control)</b>	
	<b>Average</b>	<b>Standard Deviation</b>
<b>Temperature Entering Tower (°F)</b>	99.3	3.1
<b>Sump Temperature (°F)</b>	88.3	3.2
<b>Daily Make-up Water Consumption (gal)</b>	115	7
<b>Daily Blowdown (gal)</b>	17	6
<b>Temperature Differential (°F)</b>	11.0	1.5
<b>Conductivity (mS/cm)</b>	1.174	0.215
<b>pH</b>	8.64	0.10
<b>Alkalinity (mg/L as CaCO<sub>3</sub>)</b>	113	21
<b>Calcium Hardness (mg/L as CaCO<sub>3</sub>)</b>	205	88
<b>Magnesium Hardness (mg/L as CaCO<sub>3</sub>)</b>	122	47
<b>Total Hardness (mg/L as CaCO<sub>3</sub>)</b>	328	111
<b>TDS (mg/L)</b>	853	165
<b>LSI</b>	1.23	0.29
<b>RSI</b>	6.19	0.52
<b>PSI</b>	7.30	0.56
<b>Planktonic HPC (CFU/mL)</b>	6.77E+05	1.02E+06
<b>Sessile HPC (CFU/cm<sup>2</sup>)</b>	2.57E+06	3.66E+06

Throughout each of the trials, the average temperature entering the tower was 99.3 °F and the average sump temperature was 88.3 °F. The temperature entering the tower ranged between 95-105 °F, while the sump temperature ranged between 80-98 °F. This high range of fluctuation observed in the sump was due to large temperature changes caused by make-up water feeding. Since the make-up water was acquired from a cold water faucet and stored at room temperature, it maintained significantly lower temperature than the bulk water. As a result, when make-up water feeding occurred, the most profound impact on tower system temperature was observed in the sump, where the make-up water was discharged.

The average conductivity for all device trials (excluding PEFD Trial 2/2) was 1.174 mS/cm. Conductivity values were higher during PEFD Trial 2/2 in order to achieve a higher

cycles of concentration. The average pH throughout the entire investigation was 8.64, with T1 (Control) maintaining an equilibrium pH in the range of 8.40 – 8.80.

The average alkalinity and hardness in T1 (Control) were 113 and 328 mg/L as CaCO<sub>3</sub>, respectively. The average LSI for T1 (Control) was 1.23, indicating that conditions were strongly scale forming. The average RSI was 6.19, indicating stable conditions in T1 (Control), while the average PSI was 7.30, indicating moderate scale-forming conditions. A combined analysis of these three indices indicates that conditions in T1 (Control) were mildly to moderately scale-forming for the duration of the investigation.

### 3.2.2 Biological Parameters

The average planktonic microbial population (enumerated by heterotrophic plate count using a pour plate method) for each device trial is shown in **Figure 11**. Throughout each device trial, a planktonic population of between  $10^5$  –  $10^6$  CFU/mL was maintained in the control tower, with the HCD trial generating average microbial counts slightly lower than  $10^5$  CFU/mL. The average planktonic heterotrophic plate count over the course of the six device trials was 677,000 CFU/mL, fulfilling the goal outlined in the original scope of work of maintaining a control microbial population on the order of magnitude of  $10^5$  CFU/mL. **Figure 12** depicts variations in planktonic HPC throughout each NCD trial. Since the project scope of work target of  $10^5$  CFU/mL in the control tower was achieved, no additional microbial seeding of the make-up water was employed for any of the device trials or chlorination tests.




Figure 11 – T1 (Control) average planktonic microbial populations for each device trial




Figure 12 – T1 (Control) planktonic microbial population (HPC) for each device trial

A statistical analysis was used to compare the planktonic heterotrophic plate counts in T1 (Control) for each of the device trials. The results of this statistical analysis are shown in **Table 8**. This analysis indicates that there is a slight difference between HPC data in T1 (Control) for the MD trial and the UD trial. However, the observed differences were less than 1 log value. Ambient temperature changes resulting from changing seasons over the course of the experiment may account for some of the observed difference between early device trials and later ones. During each device trial, T1 (Control) maintained a microbial population in excess of  $10^5$  CFU/mL, as was outlined in the initial scope of work for this project.

The sessile microbial population in T1 (Control) over the course of the entire study is shown in **Figure 13** with an average sessile heterotrophic plate count of  $2.6 \times 10^6$  CFU/cm<sup>2</sup>. A paired t-test was used to compare the T1 (Control) heterotrophic plate count data among different device trials. The resulting p-value of 0.438 indicates that there was no statistically significant difference between the sessile heterotrophic plate counts observed in T1 (Control) during each of the 6 device trials.


**Table 8 – Pairwise comparisons of planktonic HPC in T1 (Control)**

Level	n	Mean	S.E.
2	7	5.985537	.1613863
3	9	5.809726	.1770747
4	9	5.374876	.1545532
5	8	5.54703	.1012947
6	9	5.332011	.1676016
7	9	5.564345	.0430838

**Note:**

- Level 2 is MD
- Level 3 is PEFD (Trial 1/2)
- Level 4 is PEFD (Trial 2/2)
- Level 5 is ED
- Level 6 is UD
- Level 7 is HCD





**Figure 13 – T1 (Control) combined sessile microbial population**

### 3.2.3 Summary

Conditions in T1 (Control) were approximately the same for each of the six device trials. Temperature fluctuations were the result of changes in the ambient outdoor temperature over the course of the investigation. Fluctuations in chemical parameters, such as conductivity, pH, and alkalinity, were the result of changes in make-up water quality. Total hardness data showed the largest fluctuation over the course of the investigation, which was significantly reduced by the preparation of new standards for hardness measurements. Scaling index calculations indicate

that mild to moderate scaling potential was maintained in T1 (Control) throughout the investigation. Planktonic microbial populations above  $10^5$  CFU/mL and sessile microbial populations above  $10^6$  CFU/cm<sup>2</sup> were maintained in T1 (Control) over the course of each device trial.

Another very important measure of reproducibility that was achieved in this study is discussed in Section 4.7, where the results of three separate chlorination tests are presented. It is important to note that the chlorination tests demonstrated not only the reproducibility of the experimental investigations conducted in this study but also the effectiveness of a conventional chemical biofouling control approach for pilot-scale cooling systems.

## **4.0 DEVICE TRIAL RESULTS AND DISCUSSION**

The following section provides the results from each individual device trial. These include operational, chemical, and biological parameters. Biological data are provided in the following sections, while chemical and operational data are provided in the corresponding appendices.

### **4.1 MAGNETIC DEVICE (MD) TRIAL**

The investigation of the magnetic device began on 3/13/09 and lasted until 4/20/09. The heating systems in T1 (Control) and T2 (Device) had to be rewired on 3/29/09 due to electrical problems. Additionally, a solenoid valve malfunction led to a pause in the operation of T1 (Control) from 4/11 – 4/15. Data collected during the test with magnetic device are shown in Appendix C. Operational and chemical data for the make-up water and each of the two system towers are included in Appendix C.1. Statistical analyses of the chemical and water consumption data collected during this investigation are shown in Appendix C.2. This analysis contains data from an earlier trial run which was terminated due to operational problems. Photographs of each of the tower systems before and after the test of the magnetic device are shown in Appendix C.3.

#### 4.1.1 Tower System Operation

Tower system operational data for the MD trial are shown in **Figure C1-C19**. The temperature differential (**Figure C1**) observed for each tower was between 9-15 °F over the course of the experiment. Operational problems with the heating system of T1 (Control) led to erratic temperature differentials in the second half of the test period. Make-up water consumption rates (**Figure C2**) were similar for the two towers over the course of the experiment (T1 (Control) average = 115 gal/day, T2 (Device) Average = 115 gal/day), while blowdown levels (**Figure C3**) were higher for T2 (Device) than for T1 (Control) (T1 (Control) average = 12 gal/day, T2 (Device) Average = 18 gal/day). The pause in operation experienced by T1 (Control) from 4/11 – 4/15 led to the difference between observed make-up water feed rates and blowdown levels. Based on manufacturer’s explanation regarding the mechanism by which the magnetic device decreases scaling, reduced surface bleed and cumulative water consumption are to be expected in the device tower (T2).

Tower temperatures for T1 (Control) remained in the range of 87-105°F, as is shown on **Figure C4**. This temperature range offers neither an advantage nor a disadvantage for the planktonic and sessile microbial populations present in the tower. The slightly higher tower temperatures observed in T1 (Control) towards the end of the trial period may be responsible for the higher planktonic microbial populations observed on 4/10, 4/17, and 4/20. However, during this period the temperature range of T2 (Device) was approximately 95-107 °F, as is shown in **Figure C5**. The behavior of both towers’ temperature profiles is comparable, and may be directly linked to changes in ambient temperature (**Figure C6**) and relative humidity (**Figure C7**) during the course of the experiment. Any temperature effects on microbial growth would have been observed in both T1 (Control) and T2 (Device).

Average values and standard deviations for all parameters measured during this investigation are presented in **Table 9**. Additional chemical data collected during this investigation are shown in **Figure C8 – Figure C16**. The fluctuations in these measurements during the beginning portion of the experiment, as well as following periods of non-operation, indicate that several days of tower operation are required in order to achieve steady state operation. Conductivity measurements were somewhat erratic during the experiment, as can be seen in **Figure C8**. The blowdown controllers were reset at various times throughout the course of the experiment to achieve approximately 4-5 cycles of concentration. However, improper calibration of the conductivity data collection probes may have resulted in the collection of seemingly disparate data.

**Table 9 – Average values for MD trial**

	<b>T1 (Control)</b>		<b>T2 (Device)</b>	
	<b>Average</b>	<b>Standard Deviation</b>	<b>Average</b>	<b>Standard Deviation</b>
<b>Temperature Entering Tower (°F)</b>	93.4	5.5	97.9	3.4
<b>Sump Temperature (°F)</b>	85.0	3.7	84.9	3.1
<b>Daily Make-up Water Consumption (gal)</b>	113	36	115	27
<b>Daily Blowdown (gal)</b>	12	8	18	9
<b>Conductivity (mS/cm)</b>	0.867	0.155	0.819	0.146
<b>pH</b>	8.56	0.08	8.61	0.10
<b>ORP (mV)</b>	257	22	258	36
<b>Alkalinity (mg/L as CaCO<sub>3</sub>)</b>	134	13	133	16
<b>Calcium Hardness (mg/L as CaCO<sub>3</sub>)</b>	230	183	257	158
<b>Magnesium Hardness (mg/L as CaCO<sub>3</sub>)</b>	67	25	78	14
<b>Total Hardness (mg/L as CaCO<sub>3</sub>)</b>	300	189	349	159
<b>TDS (mg/L)</b>	632	179	672	144
<b>LSI</b>	1.12	0.44	1.19	0.46
<b>RSI</b>	6.31	0.81	6.19	0.84
<b>PSI</b>	7.17	0.76	6.86	0.76
<b>Planktonic HPC (CFU/mL)</b>	1.60E+06	1.42E+06	6.79E+05	6.79E+05
<b>ATP Microbial Equivalents (MEQs/mL)</b>	1.02E+06	1.06E+06	1.02E+06	5.94E+05
<b>Sessile HPC (CFU/cm<sup>2</sup>)</b>	1.21E+06	1.17E+06	2.68E+06	1.53E+06

Chloride measurements for each tower are shown in **Table C1**, and these measurements indicate that the cycles of concentration for this run were slightly higher than 5 for each of the towers. Somewhat erratic results for some of the chemical parameters measured towards the end of the experimental run may be the result of the fact that sampling was performed at different times before and after make-up water addition and blowdown, which provided different dilution factors.


Using the chemical data collected during this investigation, three scaling indices were calculated for each of the towers. Both towers produced comparable values for each of the scaling indices analyzed. The Langelier Saturation Index value observed was approximately 1.12 for T1 (Control) and 1.19 for T2 (Device) (**Figure C17**), indicating that the water in each tower had strong scaling potential. The Ryznar Stability Index value observed was approximately 6.31 for T1 (Control) and 6.19 for T2 (Device) (**Figure C18**), indicating that T1 (Control) had a slight tendency to dissolve scale, while T2 (Device) was neutral with regards to scale formation. The average Puckorius Scaling Index value observed for T1 (Control) was 7.17, and for T2 (Device) it was 6.86 (**Figure C19**), indicating that the water in each tower had high scale-dissolving potential. Based on a comparison of the observed values of these three indices, it may be concluded that the water in each tower maintained comparable moderate scaling potential over the course of the experiment.

#### **4.1.2 Biological Parameters**

Analysis of the biological data collected during the second evaluation of the magnetic device indicates that the magnetic device offers little to no control of planktonic and sessile microbial populations.

Observations of the biological population present in each tower (**Figure 14 - Figure 16**) indicate that each tower contained comparable levels of microbial activity both in the bulk water and in the system biofilms throughout the course of the experiment. No planktonic biological sample was taken from T1 on 4/6 since the tower was not operational.

The planktonic heterotrophic plate counts observed in each of the tower systems throughout the MD trial are shown in **Figure 14**. This figure reveals that the heterotrophic plate count in T1 (Control) was higher than that of T2 (Device) on 7 out of the 10 days for which data are available for both tower systems. However, there was less than 1 log value difference on each of these 7 days. A statistical analysis of the heterotrophic plate count data is shown in **Table 10**, and this analysis indicates that the observed difference between the plate counts for T1 (Control) and T2 (Device) was not statistically significant. At no point during the device trial did T2 (Device) maintain a microbial population below the industry standard of  $10^4$  CFU/mL.



**Figure 14 – Planktonic microbial populations (heterotrophic plate count) for MD trial**

**Table 10 – Planktonic HPC statistical analysis for MD trial**

(Planktonic heterotrophic plate counts were transformed to Log 10 data and compared using a paired t-test. Log 10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.15**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
logt1	10	5.984324	.1690709	.5346493	5.601859	6.366789
logt2	10	5.845376	.1338754	.4233512	5.542529	6.148223
diff	10	.1389484	.0879725	.2781936	-.0600592	.3379561

mean(diff) = mean(logt1 - logt2) t = 1.5795  
 Ho: mean(diff) = 0 degrees of freedom = 9  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.9257 Pr(|T| > |t|) = 0.1487 Pr(T > t) = 0.0743

**Based on the results of this paired t-test, there was no significant difference in planktonic heterotrophic plate counts between T1 (Control) and T2 (Device).**



Relatively high levels of microbial activity were observed in the make-up water throughout the course of this experiment. The make-up water heterotrophic biological population was between 200 – 80,000 CFU/mL, with an average value of 25,000 CFU/mL, which would have resulted in high levels of microbial seeding during periods of make-up water addition to the system. As discussed in Section 3, the make-up water used for the experiment was dechlorinated using an activated carbon column. After passing through the column, the make-up water was then stored in four 125-gallon tanks. While the tanks received fresh water on daily basis, this storage period allowed for microbial growth to occur, resulting in the high levels of make-up water microbial activity.

The planktonic microbial population in each tower system was also monitored by measuring the cellular ATP. Measured ATP concentrations were converted to microbial equivalents as previously described in this report, and these measurements are shown in **Figure 15**. The observed planktonic microbial population was higher in T2 (Device) than in T1 (Control) on 7 of the 10 days for which data are available for both tower systems. In each instance, this difference is less than 1 log value. A statistical analysis of the microbial populations enumerated by ATP measurement is shown in **Table 11**. This analysis indicates that the differences between the microbial populations observed in T1 (Control) and T2 (Device) using ATP measurements are not statistically significant.




Figure 15 – Planktonic microbial populations (ATP measurement) for MD trial

Table 11 – Planktonic ATP statistical analysis for MD trial


(Planktonic ATP microbial equivalent levels were transformed to Log 10 data and compared using a paired t-test. Log10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.95**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
logatp	10	5.851842	.1426523	.4511063	5.52914	6.174544
logatp2	10	5.858571	.0978048	.3092859	5.637321	6.079821
diff	10	-.006729	.1022969	.3234912	-.2381406	.2246827
mean(diff) = mean(logatp - logatp2)					t = -0.0658	
Ho: mean(diff) = 0					degrees of freedom = 9	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.4745		Pr( T  >  t ) = 0.9490		Pr(T > t) = 0.5255		

**Based on the results of this paired t-test, there was no significant difference in ATP microbial equivalent levels between T1 (Control) and T2 (Device).**

The sessile microbial populations observed in each tower system throughout the course of this device trial are shown in **Figure 16**. This figure reveals that the sessile microbial population was higher in T2 (Device) than in T1 (Control) on 4 out of 5 sampling days. Sessile heterotrophic plate counts for T2 (Device) were in excess of  $10^6$  CFU/cm<sup>2</sup> on 4 out 5 sampling days. A statistical analysis of the sessile heterotrophic plate counts for each tower system is shown in **Table 12**. This analysis reveals that no statistically significant difference between sessile heterotrophic plate counts in T1 (Control) and T2 (Device) was observed.



**Figure 16 – Sessile microbial population for MD trial**

**Table 12 – Sessile HPC statistical analysis for MD trial**

(Sessile heterotrophic plate counts (**Figure 16**) were transformed to Log 10 data and compared using a paired t-test. Log10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.09**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
logbio1	5	5.851804	.2483899	.5554167	5.162163	6.541445
logbio2	5	6.299068	.2094168	.4682702	5.717634	6.880502
diff	5	-.4472639	.2008155	.4490371	-1.004817	.1102893

mean(diff) = mean(logbio1 - logbio2)	t = -2.2272
Ho: mean(diff) = 0	degrees of freedom = 4
Ha: mean(diff) < 0	Ha: mean(diff) != 0
Pr(T < t) = 0.0449	Pr( T  >  t ) = 0.0899
	Ha: mean(diff) > 0
	Pr(T > t) = 0.9551

**Based on the results of this paired t-test, there was no significant difference in sessile heterotrophic plate counts between T1 (Control) and T2 (Device).**

Since the magnetic device was unable to demonstrate any significant control over the microbial population (both planktonic and sessile) in the experimental towers, the experiment was terminated before conducting the second phase (colonization of the system followed by device installation).

### 4.1.3 Summary

The results presented in this report demonstrate that the magnetic device did not significantly reduce biological activity compared to the “control” tower. Planktonic heterotrophic plate counts, ATP measurements, and sessile heterotrophic plate counts from T1 (Control) and T2

(Device) showed no significant differences at any point during the investigation. Tower operational conditions were comparable throughout the course of the device trial

## 4.2 PULSED ELECTRIC FIELD DEVICE (PEFD) TRIAL 1/2

The first investigation of the PEFD began on 5/2/09 and it continued uninterrupted until 5/30/09. Data collected during this investigation are included in Appendix D. Operational data collected during this investigation are shown in Appendix D.1. Statistical analyses of the chemical data analyzed during the investigation are shown in Appendix D.2. Photographs of the system before and after the test are shown in Appendix D.3.

### 4.2.1 Tower System Operation

Tower system operational data for this device trial are shown in **Figure D1 – Figure D19**. A temperature differential of approximately 9-13 °F was maintained for each tower throughout the majority of the investigation (**Figure D1**). Since temperature differential calculations were determined using manual temperature readings, it is likely that the low observed temperature differentials (< 10 °F) were the result of measurements being taken soon after the towers received make-up water. Receiving make-up water cools down the sump temperature significantly, and this may have led to the low measured temperature differentials. The quantity of make-up water consumed by each tower throughout the course of the investigation was approximately the same (**Figure D2**). T1 (Control) exhibited higher blowdown volumes initially (**Figure D3**), and T2 (Device) gradually approached the blowdown rate exhibited by Tower 1 as the experiment progressed. Tower temperature profiles are shown in **Figure D4** (T1) and **Figure D5** (T2), with fluctuations occurring as a result of changing ambient conditions such as temperature (**Figure D6**) and relative humidity (**Figure D7**).

Average values and standard deviations for all parameters measured during this investigation are shown in **Table 13**. Chemical data collected during the course of this experiment are shown in **Figure D8 – Figure D16**. Continuous conductivity data collected during the investigation are shown in **Figure D8**. The conductivity observed in T1 (Control) was slightly higher than that observed in T2 (Device) for the duration of the experiment. Although both blowdown controllers were set at identical values (1.20 mS/cm), the blowdown controller for T2 (Device) was not functioning properly. As a result, the conductivity levels which triggered blowdown in T2 (Device) were lower than the setpoint, resulting in a lower overall conductivity. This trend may also be observed with the continuous pH monitoring of the systems (**Figure D9**). Make-up water conductivity ranged from 0.284 – 0.312 mS/cm, while the make-up water pH ranged from 6.82 – 7.53 (**Figure D11**).

**Table 13 – Average values for PEFD (Trial 1/2)**

	<b>T1 (Control)</b>		<b>T2 (Device)</b>	
	<b>Average</b>	<b>Standard Deviation</b>	<b>Average</b>	<b>Standard Deviation</b>
<b>Temperature Entering Tower (°F)</b>	102.0	2.1	100.7	3.8
<b>Sump Temperature (°F)</b>	90.7	2.4	88.9	3.5
<b>Daily Make-up Water Consumption (gal)</b>	111	24	109	28
<b>Daily Blowdown (gal)</b>	20	10	15	8
<b>Conductivity (mS/cm)</b>	1.057	0.045	0.948	0.038
<b>pH</b>	8.61	0.09	8.45	0.04
<b>ORP (mV)</b>	228	12	197	64
<b>Alkalinity (mg/L as CaCO<sub>3</sub>)</b>	132	10	117	10
<b>Calcium Hardness (mg/L as CaCO<sub>3</sub>)</b>	266	43	250	36
<b>Magnesium Hardness (mg/L as CaCO<sub>3</sub>)</b>	206	27	185	21
<b>Total Hardness (mg/L as CaCO<sub>3</sub>)</b>	472	65	436	52
<b>TDS (mg/L)</b>	980	74	934	64
<b>LSI</b>	1.42	0.15	1.18	0.10
<b>RSI</b>	5.71	0.05	6.09	0.19
<b>PSI</b>	6.70	0.16	6.94	0.17
<b>Planktonic HPC (CFU/mL)</b>	1.23E+06	1.54E+06	5.50E+05	4.63E+05
<b>ATP Microbial Equivalentents (MEQs/mL)</b>	9.98E+05	6.92E+05	9.65E+05	4.49E+05
<b>Sessile HPC (CFU/cm<sup>2</sup>)</b>	3.19E+06	3.91E+06	1.95E+06	1.78E+06

Chloride measurements for each tower are shown in **Table D1**, and these measurements indicate that T1 (Control) was operating at near 6.5 cycles of concentration, while T2 (Device) was operating at near 6 cycles of concentration. These values are higher than the target cycles of concentration (4-5), which is most likely due to the erratic nature of the make-up conductivity and the collection of solids on the conductivity probes which are used to control blowdown.

The chemical parameters measured during this investigation were used to calculate 3 scaling indices commonly used in the water treatment industry: The Langelier Saturation Index (LSI), the Ryznar Stability Index (RSI), and the Puckorius Scaling Index (PSI). At equilibrium, T1 (Control) had an average LSI value of approximately 1.42, while T2 (Device) had an LSI value of 1.18 (**Figure D17**). These values suggest that the water in each tower system had strong scaling potential. The RSI values for T1 (Control) and T2 (Device) at equilibrium were 5.71 and 6.09, respectively, indicating that T1 (Control) had slight scale formation potential and T2 (Device) was neutral with regards to scaling potential (**Figure D18**). The equilibrium PSI values for T1 (Control) and T2 (Device) were 6.70 and 6.94, respectively, also indicating moderate scale-dissolving potential (**Figure D19**). A combined analysis of each of these scaling indices indicates that the towers were operating under very similar conditions.

#### **4.2.2 Biological Parameters**

Biological data collected during this investigation are shown in **Figure 17 – Figure 19**. Analysis of this data indicates that the device did not exhibit any significant biocidal effects. No significant reduction in planktonic or sessile microbial activity was observed in T2 (Device). Biological data



collected during this device trial were combined with data from PEFD Trial 2/2, and the statistical analyses performed using this combined data are discussed in Section 4.3.2.

Heterotrophic plate counts for each of the towers systems were measured throughout the course of the device trial, and these measurements are shown in **Figure 17**. Although T2 (Device) demonstrated lower planktonic heterotrophic plate count values on 7 out of 9 of the biological sampling days, the observed differences between the plate counts from T1 (Control) and T2 (Device) were less than 1 log value. On each sampling day, the microbial population in T2 (Device) was higher than the industry standard of  $10^4$  CFU/mL.






Figure 17 – Planktonic microbial populations (HPC) for PEFD (Trial 1/2)

Microbial populations were also enumerated using measurement of cellular ATP, and the results of these measurements are shown in **Figure 18**. ATP concentrations were converted to microbial equivalents according to the equation previously discussed in this report. Microbial equivalent levels were comparable in each tower system throughout the device trial.



**Figure 18 – Planktonic microbial population (ATP measurement) for PEFD (Trial 1/2)**

The sessile microbial populations for each tower system over the course of the device trial are shown in **Figure 19**. Each tower system maintained a comparable level of sessile microbial activity, and all measured heterotrophic plate counts were in excess of  $10^5$  CFU/cm<sup>2</sup>. This indicates that the device did not have a significant effect on sessile microbial growth.



**Figure 19 – Sessile microbial population for PEFD (Trial 1/2)**

The make-up water contained a heterotrophic biological population between 1,000 – 440,000 CFU/mL during this device trial, with an average value of approximately 67,000 CFU/mL. One sampling date (5/27/09) demonstrated a make-up water microbial population higher than that observed in either of the two tower systems (440,000 CFU/mL). It is likely that this high microbial count was the result of sample contamination since microbial equivalent levels measured using cellular ATP were comparable on this sampling day to other values observed during this device trial. Excluding this outlier, the make-up water contained an observed biological range of 1,000 – 59,000 CFU/mL and an average heterotrophic population of approximately 20,000 CFU/mL. Make-up water biological growth was allowed to occur without any means of biocidal control. No artificial microbial seeding was performed on the make-up water during this or any of the device trials.

Since no significant planktonic or sessile microbial control was observed in this test, Phase II of the device trial (colonization of towers followed by device activation) was not performed. However, an additional Phase I test was performed at a higher cycle of concentration to determine if this would have an effect on biological control using the PEFD. The manufacturer's literature indicates that precipitation of scale helps to remove microorganisms from the system, which may not have occurred to a significant extent during this trial due to the low value of cycles of concentration.

#### **4.2.3 Summary**

No biological control resulting from the installation of the PEFD was observed during this trial. According to the manufacturer's literature, this could have been the result of insufficient cycles of concentration employed in this test since the conductivity of the device tower was not as high as is normally encountered in industrial cooling systems. Additional concerns regarding relative humidity and temperature levels in the shower room containing the tower systems and the consistency of the heating units were also addressed prior to the performance of this second device trial. Flexible ducting was installed on the top of each tower system in order to funnel tower exhaust air directly into the ventilation system. Additionally, the fan belt for the roof fan controlling the shower room ventilation system was replaced. These modifications improved ventilation in the shower room, minimizing air recirculation.

### 4.3 PULSED ELECTRIC FIELD DEVICE (PEFD) TRIAL 2/2

The second investigation of the pulsed electric field device began on 6/12, and it was completed on 7/10. This investigation was performed to determine if higher scaling index would improve biological control in the cooling tower. The primary parameter altered during the second investigation was the blowdown conductivity setpoint. In the previous investigation of the pulsed electric field device, the blowdown conductivity setpoint was chosen to establish a steady state of 4-5 cycles of concentration which results in stable scale forming index. For the second pulsed electric field device investigation, the set point was raised to establish a steady state of 6-7 cycles of concentration. The increased cycles of concentration were verified by total dissolved solids, conductivity, and chloride measurements, although calcium hardness and alkalinity of the make-up water decreased during this device trial in comparison to PEFD Trial 1/2 (See Appendix B.1, **Table B1**).

An electrical failure caused T2 (Device) to go offline on 6/21. T2 (Device) went back online on 6/23 following the installation of a new pump, and it remained online for the duration of the investigation. All data collected during this investigation is included in Appendix E. Operational and chemical data collected during this investigation are shown in Appendix E.1, and statistical analyses of the data collected during both device trials (PEFD Trials 1/2 and 2/2) are shown in Appendix E.2. Photographs of each tower system before and after the device trial are shown in Appendix E.3. Photographs of the last two biofilm sampling coupons taken from each tower during this investigation are shown in Appendix E.4.

### 4.3.1 Tower System Operation

Tower operational data are shown in **Figure E1 – Figure E19**. The temperature differentials for each tower over the course of the device trial are shown in **Figure E1**, illustrating that a temperature differential of 9-13°F was maintained in each tower throughout the investigation. The differential in T1 (Control) was approximately 1°F lower than that observed in T2 (Device). **Figure E2** demonstrates that make-up water consumption levels were comparable in T1 (Control) and T2 (Device) during this test, as indicated by the similar slopes of make-up consumption volume over time. **Figure E3** demonstrates that T1 (Control) and T2 (Device) maintained comparable cumulative blowdown levels throughout the course of the experiment.

Observation of the temperature profiles for T1 (Control) (**Figure E4**) and T2 (Device) (**Figure E5**) indicate that the two towers were operating under steady and consistent conditions for the majority of the experimental run. Tower operation was halted on 6/22 – 6/23 for T2 (Device) due to operational failure. Fluctuations in the temperature profiles of each tower are the result of changes in ambient conditions such as temperature (**Figure E6**) and relative humidity (**Figure E7**). Ambient relative humidity in the shower room was decreased for this experimental run by the installation of two dehumidifiers and flexible ducting connecting each tower's air outlet directly to the ceiling-mounted exhaust duct.

Average values and standard deviations for the parameters measured during this investigation are shown in **Table 14**. Chemical parameters measured throughout the course of this experiment are shown in **Figure E8 – Figure E16**. Values for these parameters were consistently higher during the second trial than were observed during the first trial. Continuous conductivity data are shown in

**Figure E8**, and continuous pH data are shown in **Figure E9**. T1 (Control) maintained a pH of approximately 8.71, while T2 (Device) maintained a pH of approximately 8.73. Measurements of conductivity and pH indicate that the operating conditions of each tower were nearly identical for the duration of the experimental trial. The blowdown setpoint on each tower was set to a value of 2.10 mS/cm based on the chemical characteristics of the incoming make-up water (**Figure E11**).

**Table 14 – Average values for PEFD (Trial 2/2)**

	<b>T1 (Control)</b>		<b>T2 (Device)</b>	
	<b>Average</b>	<b>Standard Deviation</b>	<b>Average</b>	<b>Standard Deviation</b>
<b>Temperature Entering Tower (°F)</b>	96.4	1.0	98.6	1.8
<b>Sump Temperature (°F)</b>	85.6	1.7	86.8	1.6
<b>Daily Make-up Water Consumption (gal)</b>	105	23	96	7
<b>Daily Blowdown (gal)</b>	8	6	8	8
<b>Conductivity (mS/cm)</b>	1.980	0.102	1.908	0.203
<b>pH</b>	8.71	0.03	8.73	0.06
<b>ORP (mV)</b>	196	7	246	22
<b>Alkalinity (mg/L as CaCO<sub>3</sub>)</b>	123	10	114	16
<b>Calcium Hardness (mg/L as CaCO<sub>3</sub>)</b>	173	3	167	7
<b>Magnesium Hardness (mg/L as CaCO<sub>3</sub>)</b>	198	11	192	21
<b>Total Hardness (mg/L as CaCO<sub>3</sub>)</b>	371	11	361	81
<b>TDS (mg/L)</b>	1411	67	1329	155
<b>LSI</b>	1.24	0.05	1.24	0.13
<b>RSI</b>	6.24	0.08	6.25	0.21
<b>PSI</b>	7.35	0.12	7.40	0.25
<b>Planktonic HPC (CFU/mL)</b>	4.12E+05	5.00E+05	1.17E+06	2.24E+06
<b>ATP Microbial Equivalents (MEQs/mL)</b>	4.59E+05	4.12E+05	6.08E+05	1.96E+05
<b>Sessile HPC (CFU/cm<sup>2</sup>)</b>	2.07E+06	5.44E+05	1.89E+06	6.14E+05

Three scaling indices were calculated using the chemical parameters observed during this investigation, and these indices may be used to quantify the scaling potential of each tower's water supply. The Langelier Saturation Index for each tower was approximately 1.24 at equilibrium,


indicating that the water in each tower system had strong scaling potential (**Figure E17**). Equilibrium values of the Ryznar Stability Index for each tower were approximately 6.24 for T1 (Control) and 6.25 for T2 (Device) (**Figure E18**), indicating that the water in each system was stable. However, the Puckorius Scaling Index values were approximately 7.35 for T1 (Control) and 7.40 for T2 (Device) at equilibrium, indicating moderate scale-dissolving potential (**Figure E19**). These indices provide conflicting information regarding whether or not the water in each tower system is scale-forming or scale-dissolving.

#### 4.3.2 Biological Parameters

Observation of the biological population present in each tower (**Figure 20 – Figure 22**) indicates that each tower maintained comparable levels of microbial activity both in the bulk water and in system biofilms throughout the course of the experiment. No significant reduction in microbial activity was observed in the tower with the device. Both towers maintained planktonic microbial populations in excess of acceptable industry standards ( $10^4$  CFU/mL).

Planktonic heterotrophic plate counts for each tower system over the course of the device trial are shown in **Figure 20**. The microbial population was higher in T2 (device) than in T1 (Control) on 7 of the 9 sampling days. On 6/20, the heterotrophic plate count in T2 (Device) was approximately 1 log value higher than in T1 (Control). This was the largest observed difference between the planktonic microbial populations of the two tower systems. A statistical analysis of the combined planktonic heterotrophic plate count data from PEFD Trial 1/2 and Trial 2/2 is shown in **Table 15**. This analysis indicates that the observed difference between the planktonic heterotrophic plate counts for T1 (Control) and T2 (Device) was not statistically significant.





**Figure 20 – Planktonic microbial population enumerated by heterotrophic plate count for PEFD (Trial 2/2)**

**Table 15 – Planktonic HPC statistical analysis for PEFD Trial 1/2 and PEFD Trial 2/2**

(Planktonic heterotrophic plate counts were transformed to Log 10 data and compared using a paired t-test. Log 10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**Combined Runs (p = 0.92)**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
t1sump10	18	5.592301	.1256143	.5329365	5.327278	5.857324
t2sump10	18	5.602987	.1161657	.4928494	5.357899	5.848075
diff	18	-.0106858	.1051676	.4461884	-.2325701	.2111985

mean(diff) = mean(t1sump10 - t2sump10) t = -0.1016  
 Ho: mean(diff) = 0 degrees of freedom = 17

Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.4601 Pr(|T| > |t|) = 0.9203 Pr(T > t) = 0.5399

**The results of this t-test indicate that there was no significant difference between planktonic heterotrophic plate counts recorded for each of the tower systems during both device trials.**

The concentration of microorganisms present in the make-up water during this investigation was comparable to that observed during the first pulsed electric field device trial. This is a result of the combination of make-up water dechlorination and storage. Although high microbial concentrations in the make-up water most likely led to constant seeding of microorganisms, no difference in planktonic heterotrophic plate counts between T1 (Control) and T2 (Device) was observed, indicating that the non-chemical device did not have an effect on the growth of planktonic microorganisms in the cooling tower.

The microbial population in each of the two tower systems was also enumerated using the measurement of cellular ATP. The concentration of ATP was used to calculate microbial equivalents according to the equation described previously in this report. ATP microbial equivalent measurements are shown in

**Figure 21.** The observed microbial population was higher in T2 (Device) than in T1 (Control) on 6 of the 8 sampling days. A statistical analysis using ATP data from both PEFD Trial 1/2 and Trial 2/2 is shown in **Table 16**. This analysis shows that the observed difference between the microbial populations of T1 (Control) and T2 (Device) during PEFD Trial 1/2 and Trial 2/2 was not statistically significant.




Figure 21 – Planktonic microbial population (ATP measurement) for PEFD (Trial 2/2)

Table 16 – Planktonic ATP statistical analysis for PEFD (Trial 2/2)


(Planktonic ATP microbial equivalent levels were transformed to Log 10 data and compared using a paired t-test. Log10 transformed data was normally distributed, Wilks-Shapiro test for normality)

p = 0.041

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]		
atpt110	17	5.755866	.0761582	.3140084	5.594418	5.917315	
atpt210	17	5.859539	.0463398	.1910637	5.761303	5.957775	
diff	17	-.1036723	.0467444	.1927319	-.2027659	-.0045787	
mean(diff) = mean(atpt110 - atpt210)						t =	-2.2179
Ho: mean(diff) = 0						degrees of freedom =	16
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0			
Pr(T < t) = 0.0207		Pr( T  >  t ) = 0.0414		Pr(T > t) = 0.9793			

The results of this t-test indicate that there was no significant difference between planktonic ATP microbial equivalent levels recorded for each of the tower systems during both device trials.

Sessile heterotrophic plate counts for each of the two tower systems over the course of the device trial are shown in **Figure 22**. The sessile microbial populations in the two tower systems were comparable and each tower system maintained a sessile microbial population in excess of  $10^6$  CFU/cm<sup>2</sup> throughout the trial. A statistical analysis was conducted using the sessile heterotrophic plate counts from both device trials, and the results are shown in **Table 17**. This analysis indicates that the observed difference between the sessile microbial populations in T1 (Control) and T2 (Device) during PEFD Trial 1/2 and Trial 2/2 was not statistically significant.



**Figure 22 – Sessile microbial population for PEFD (Trial 2/2)**

**Table 17 – Sessile HPC statistical analysis for PEFD Trial 1/2 and Trial 2/2**

(Sessile heterotrophic plate counts were transformed to Log 10 data and compared using a paired t-test. Log 10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.126**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
t1bio10	9	6.264815	.1293026	.3879078	5.966643	6.562988
t2bio10	9	6.170275	.1344017	.4032052	5.860344	6.480206
diff	9	.0945397	.0552943	.165883	-.0329692	.2220487

mean(diff) = mean(t1bio10 - t2bio10)	t = 1.7098	
Ho: mean(diff) = 0	degrees of freedom = 8	
Ha: mean(diff) < 0	Ha: mean(diff) != 0	Ha: mean(diff) > 0
Pr(T < t) = 0.9372	Pr( T  >  t ) = 0.1257	Pr(T > t) = 0.0628

**The results of this t-test indicate that there was no significant difference between sessile heterotrophic plate counts recorded for each of the tower systems during both device trials.**

The make-up water contained a heterotrophic biological population between 1,400 – 90,000 CFU/mL during this device trial, with an average value of approximately 18,000 CFU/mL. Make-up water biological growth was allowed to occur without any means of biocidal control since water was dechlorinated prior to usage. No artificial microbial seeding was performed on the make-up water during this or any of the device trials.

### 4.3.3 Summary

The results presented in this report demonstrate that the pulsed electric field non-chemical device did not significantly reduce biological activity compared to the “control” tower. Two device trials were performed at different cycles of concentration. Planktonic heterotrophic plate counts

and ATP measurements from T1 (Control) and T2 (Device) showed no significant difference at any point during either of the device trials. The same behavior was observed for sessile heterotrophic plate counts in two tower systems during both device trials.

## 4.4 ELECTROSTATIC DEVICE (ED) TRIAL

The evaluation of the static electric field device began on 7/18 and it continued until 8/15. A malfunction in the make-up feed solenoid valve on T2 (Device) occurred on 8/2. As a result, T2 (Device) was turned off for several hours while the valve was replaced. This malfunction also led to a dilution of the water in T2 (Device). All data collected during this trial is included in Appendix F. Operational and chemical data collected during this investigation are shown in Appendix F.1, and statistical analyses of the chemical data are shown in Appendix F.2. Photographs of the tower systems taken before and after the device trial are shown in Appendix F.3, and photographs of biofilm coupon taken during the investigation are shown in Appendix F.4. After the trial period for the static electric field device had ended, a chlorination test was performed on T2 (Device) and these results are discussed in Section 4.7 of this report.

### 4.4.1 Tower System Operation

Operational and chemical data collected during this device trial are shown in **Figure F1 – Figure E19**. Throughout the course of the investigation, a temperature differential 9.8 – 11.6 °F was maintained for T1 (Control), while the temperature differential of 11 – 14 °F was maintained for T2 (Device) (**Figure F1**). **Figure F2** demonstrates that make-up water consumption levels were comparable in Tower 1 (Control) and Tower 2 (Device) during this test. This is indicated by the similar slopes of the two data sets. **Figure F3** demonstrates that T1 (Control) and T2 (Device) maintained comparable cumulative blowdown levels throughout the course of the experiment. Temperature profiles for each tower are

shown in **Figure F4** (T1) and **Figure F5** (T2). Fluctuations in the temperatures of each tower were the result of changes in ambient temperature (**Figure F6**) and relative humidity (**Figure F7**).

Average values for the parameters measured during this device trial are shown in **Table 18**. Examination of the continuous conductivity data (**Figure F8**) shows evidence of a blowdown valve malfunction in the T2 (Device) system on 7/29, resulting in a sudden spike followed by a dramatic drop in conductivity. Make-up water was unable to enter the tower, and a large amount of water evaporated from the system, thereby increasing the conductivity of system water. Once the valve was replaced, make-up water diluted the system volume, decreasing the overall system conductivity. Continuous pH data collected during the test (**Figure F9**) reveal that the average pH of T1 (Control) was approximately 8.58, while the average pH of T2 (Device) was approximately 8.64. A malfunction in the make-up feed valve of T1 (Control) on 7/30 diluted the system water, decreasing the pH significantly. Make-up water conductivity and pH are shown in **Figure F11**.

Three scaling indices were calculated using the chemical parameters observed during this investigation, and these indices may be used to quantify the scaling potential in each tower. Both towers produced comparable values for each of the scaling indices analyzed. The Langelier Saturation Index for T1 (Control) was approximately 0.96, and for T2 (Device) it was approximately 1.04, indicating that the water in each tower system had moderate scaling potential (**Figure F17**). Equilibrium values of the Ryznar Stability Index (**Figure F18**) were approximately 6.66 and 6.56 for T1 (Control) and T2 (Device), respectively, indicating that the water has slight scale-dissolving potential. Puckorius Scaling Index values were approximately 7.35 for T1 (Control) and 7.40 for T2 (Device) at equilibrium, which indicates moderate scale-dissolving tendency (**Figure F19**). A



combined analysis of these three indices indicates that each tower system contained water with mild scaling potential.

**Table 18 – Average parameter values for ED trial**


	T1 (Control)		T2 (Device)	
	Average	Standard Deviation	Average	Standard Deviation
Temperature Entering Tower (°F)	100.3	1.6	100.950	2.1
Sump Temperature (°F)	89.3	1.5	88.3	1.9
Daily Make-up Water Consumption (gal)	116	27	102	36
Daily Blowdown (gal)	19	9	18	11
Conductivity (mS/cm)	1.217	0.072	1.184	0.109
pH	8.58	0.08	8.64	0.08
ORP (mV)	190	31	195	34
Alkalinity (mg/L as CaCO <sub>3</sub> )	86	10	88	11
Calcium Hardness (mg/L as CaCO <sub>3</sub> )	153	10	152	10
Magnesium Hardness (mg/L as CaCO <sub>3</sub> )	105	8	99	9
Total Hardness (mg/L as CaCO <sub>3</sub> )	257	15	251	18
TDS (mg/L)	793	93	773	87
LSI	0.96	0.15	1.04	0.43
RSI	6.66	0.22	6.56	0.72
PSI	7.49	0.24	7.51	0.20
Planktonic HPC (CFU/mL)	3.89E+05	2.79E+05	4.99E+05	3.66E+05
ATP Microbial Equivalents (MEQs/mL)	5.72E+05	1.33E+05	7.44E+05	2.43E+05
Sessile HPC (CFU/cm <sup>2</sup> )	1.43E+06	6.05E+05	1.60E+06	5.49E+05

#### 4.4.2 Biological Parameters

Observation of the biological population present in each tower (**Figure 23 – Figure 25**) indicates that each tower contained comparable levels of microbial activity both in the bulk water and in system biofilms throughout the course of the experiment. No significant reduction in microbial activity was observed in the tower treated with the static electric field device.

A chlorination test was performed on 8/22 in tower T2 (Device), resulting in a significant reduction in planktonic and sessile microbial activity observed in this tower on 8/23. The results of this chlorination test will be discussed together with other chlorination tests conducted throughout this study in Section 4.7 of this report.

Heterotrophic plate counts for each tower system over the course of the device trial are shown in **Figure 23**. The microbial population in T2 (Device) was higher than T1 (Control) on 6 of the 9 sampling days. Both towers maintained planktonic microbial populations in excess of acceptable industry standards (approximately  $10^4$  CFU/mL). A statistical analysis of the heterotrophic plate counts measured during the device trial is shown in **Table 19**. This analysis indicates that the observed difference between the heterotrophic plate counts in T1 (Control) and T2 (Device) was not statistically significant.



**Figure 23 – Planktonic microbial population (HPC) for ED trial**

**Table 19 – Planktonic HPC statistical analysis for ED trial**


(Planktonic heterotrophic plate counts were transformed to Log 10 data and compared using a paired t-test. Log 10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.31**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
t1sump10	8	5.54703	.1012947	.2865046	5.307507	5.786554
t2sump10	8	5.630686	.1184785	.3351079	5.350528	5.910843
diff	8	-.0836552	.0769271	.2175826	-.2655589	.0982484
mean(diff) = mean(t1sump10 - t2sump10)				t = -1.0875		
Ho: mean(diff) = 0				degrees of freedom = 7		
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.1564		Pr( T  >  t ) = 0.3129		Pr(T > t) = 0.8436		

**The results of this t-test indicate that there was no significant difference between planktonic heterotrophic plate counts recorded for each of the tower systems during both device trials**

The microbial population in each tower was also enumerated by measuring the concentration of cellular ATP present in each tower system and converting this measurement to microbial equivalents using the equation described previously in this report. The microbial equivalents for each tower system during this device trial are shown in **Figure 24**. T2 (Device) maintained higher microbial population than T1 (Control) on 6 of the 8 sampling dates. A statistical analysis of this data is shown in **Table 20**. This analysis shows that the observed difference between the microbial equivalents in T1 (Control) and T2 (Device) was not statistically significant.



**Figure 24 – Planktonic microbial population (ATP measurement) for ED trial**

**Table 20 – Planktonic ATP statistical analysis for ED trial**

(Planktonic ATP microbial equivalent levels were transformed to Log 10 data and compared using a paired t-test. Log 10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.05**


Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
t1atp10	7	5.756859	.0397657	.10521	5.659556	5.854162
t2atp10	7	5.85979	.0605656	.1602416	5.711591	6.007989
diff	7	-.1029312	.0420996	.111385	-.2059451	.0000828

mean(diff) = mean(t1atp10 - t2atp10) t = -2.4449  
 Ho: mean(diff) = 0 degrees of freedom = 6

Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.0251 Pr(|T| > |t|) = 0.0501 Pr(T > t) = 0.9749

**The results of this t-test indicate that there was no significant difference between planktonic ATP microbial equivalent levels recorded for each of the tower systems during both device trials.**

The sessile heterotrophic plate counts for each tower system throughout the course of the device trial are shown in **Figure 25**. The sessile microbial populations in each tower system were comparable for the duration of the trial. Each tower system maintained a sessile microbial population in excess of  $10^5$  CFU/cm<sup>2</sup>. A statistical analysis of sessile heterotrophic plate counts shown in **Table 21** reveals that the observed difference between the sessile heterotrophic plate counts for T1 (Control) and T2 (Device) was not statistically significant.



**Figure 25 – Sessile microbial population for ED trial**

**Table 21 – Sessile HPC statistical analysis for ED trial**

(Sessile heterotrophic plate counts were transformed to Log 10 data and compared using a paired t-test. Log 10 transformed data was normally distributed, Wilks-Shapiro test for normality)

**p = 0.46**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
t1bio10	4	6.064831	.0968112	.1936224	5.756734	6.372927
t2bio10	4	6.148427	.1027606	.2055213	5.821397	6.475457
diff	4	-.0835965	.0995033	.1990065	-.4002603	.2330673
mean(diff) = mean(t1bio10 - t2bio10)					t = -0.8401	
Ho: mean(diff) = 0					degrees of freedom = 3	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.2313		Pr( T  >  t ) = 0.4625		Pr(T > t) = 0.7687		

**The results of this t-test indicate that there was no significant difference between sessile heterotrophic plate counts recorded for each of the tower systems during both device trials.**

The make-up water contained a heterotrophic biological population between 1,300 – 20,000 CFU/mL during this device trial, with an average value of approximately 4,400 CFU/mL. Make-up water biological growth was allowed to occur without any means of biocidal control since water was dechlorinated prior to usage. No artificial microbial seeding was performed on the make-up water during this or any of the device trials.

Phase I consisted of operating both the control and device towers for 4 weeks, with the non-chemical treatment device activated at the beginning of the investigation. This phase was completed for the static electric field treatment device. Since no microbial control was demonstrated during Phase I, Phase II was not initiated for this device. Phase II was to be conducted after a 2-week period during which each tower was allowed to operate with no treatment to achieve significant biological activity. The device would then be activated to determine whether or not any existing biological

growth in the device tower may be removed through the application of this non-chemical treatment device.

#### **4.4.3 Summary**

The results presented in this report demonstrate that the static electric field non-chemical device did not significantly reduce biological activity compared to the “control” tower. Planktonic heterotrophic plate counts and ATP measurements from T1 (Control) and T2 (Device) showed no significant difference at any point during the investigation. The same trend was observed for sessile heterotrophic plate counts in the two tower systems.

## 4.5 ULTRASONIC DEVICE (UD) TRIAL

The investigation of the ultrasonic non-chemical treatment device began on 9/2 and continued uninterrupted until 9/30. Data collected during this investigation is shown in Appendix G. Operational and chemical data from this investigation are included in Appendix G.1, and statistical analyses of the chemical parameters are included in Appendix G.2. Appendix G.3 contains photographs of each tower system before and after the device trial. Appendix G.4 contains photographs of biofilm sampling coupons taken from each tower system throughout the course of the investigation.

### 4.5.1 Tower System Operation

Tower operational and chemical data is shown in **Figure G1 – Figure G19**. Average values for the parameters measured during this device trial are contained in **Table 22**. The temperature differential for each tower system over the course of the experiment is shown in **Figure G1**. Calculation of the temperature differential was performed by subtracting the manual sump temperature reading from the manual reading of the temperature entering each tower system. The tower systems were designed with a target temperature differential of approximately 10 °F. **Figure G1** indicates that T1 (Control) operated with a temperature differential of 9.0 – 11.3 °F, while T2 (Device) operated with a temperature differential of 10.2 – 13.2 °F. The difference in temperature differentials between the two tower systems was due to differing performance efficiencies of the heating elements and axial cooling fans installed in each system.



Table 22 – Average parameter values for UD trial

	T1 (Control)		T2 (Device)	
	Average	Standard Deviation	Average	Standard Deviation
Temperature Entering Tower (°F)	100.6	2.4	102.5	3.0
Sump Temperature (°F)	90.1	2.8	90.3	3.3
Daily Make-up Water Consumption (gal)	123	27	121	27
Daily Blowdown (gal)	19	9	25	12
Conductivity (mS/cm)	1.334	0.149	1.335	0.167
pH	8.71	0.06	8.78	0.05
ORP (mV)	197	33	185	27
Alkalinity (mg/L as CaCO <sub>3</sub> )	102	14	98	11
Calcium Hardness (mg/L as CaCO <sub>3</sub> )	175	15	176	17
Magnesium Hardness (mg/L as CaCO <sub>3</sub> )	124	21	126	22
Total Hardness (mg/L as CaCO <sub>3</sub> )	299	36	302	39
TDS (mg/L)	915	115	914	128
LSI	1.22	0.13	1.30	0.11
RSI	6.27	0.21	6.19	0.17
PSI	7.49	0.24	7.51	0.20
Planktonic HPC (CFU/mL)	3.81E+05	4.06E+05	2.04E+05	1.98E+05
ATP Microbial Equivalents (MEQ <sub>s</sub> /mL)	9.00E+05	7.71E+05	5.52E+05	7.33E+05
Sessile HPC (CFU/cm <sup>2</sup> )	7.74E+06	7.69E+06	1.43E+07	2.27E+07

Both towers were supplied with make-up water from the same source. Make-up water consumption rates for each tower system (**Figure G2**) were nearly identical throughout the test, as indicated by the similar slopes produced by the cumulative consumption curves. Cumulative blowdown volumes for each tower system (**Figure G3**) indicate that T2 (Device) had more frequent blowdowns than T1 (Control). This is most likely because temperatures in T1 (Control) (**Figure G4**) were lower than those in T2 (Device) (**Figure G5**), resulting in more evaporation and more frequent blowdowns in T2 (Device) due to increased conductivity. Fluctuations in tower temperatures were the result of changes in ambient temperature (**Figure G6**) and relative humidity (**Figure G7**).

Chemical data collected during this investigation are shown in Appendix G (**Figure G8 – Figure G16**). The continuous conductivity data (**Figure G8**) shows two significant increases in the tower system conductivities. On 9/14, the blowdown conductivity setpoint was changed from 1200  $\mu\text{S}/\text{cm}$  to 1400  $\mu\text{S}/\text{cm}$ , increasing peak conductivity levels in both tower systems. On 9/22, the blowdown conductivity setpoint was raised from 1400  $\mu\text{S}/\text{cm}$  to 1500  $\mu\text{S}/\text{cm}$ , again increasing peak conductivity levels for each system. Changes in the blowdown conductivity setpoint were made based on the increasing conductivity of the make-up water used in this trial (**Figure G11**). The blowdown conductivity setpoint was adjusted to be approximately 4 times the conductivity of the incoming make-up water in order to establish 4-5 cycles of concentration. Continuous pH data for the tower system are shown in **Figure G10**, indicating that the average pH in T1 (Control) at equilibrium was approximately 8.71, while the average equilibrium pH for T2 (Device) was approximately 8.78. Inflows of make-up water were associated with steep drops in tower pH. Following the periods of make-up water feeding, the pH steadily increased as system water evaporated.

Chloride concentration measurements collected in this investigation (**Table G1**) indicate that each system was operating at 5-6 cycles of concentration throughout the course of the testing. This is slightly higher than the target of 4-5 cycles of concentration. Conductivity was used to establish the cycles of concentration in each tower. The chloride ion is a more sensitive indicator of cycles of concentration due to its relative inertness, and as a result the cycles of concentration determined using chloride measurements tend to be higher than those determined using conductivity.


Values for three scaling indices were calculated using the chemical data collected during this investigation. The Langelier Saturation Index (**Figure G17**) was approximately 1.22 for T1 (Control) and 1.30 for T2 (Device), indicating strong scaling potential. The equilibrium Ryznar Stability Index

(**Figure G18**) for T1 (Control) was 6.27, while for T2 (Device) it was approximately 6.19, indicating little to no scaling potential in either of the tower systems. The Puckorius Scaling Index (**Figure G19**) was approximately 7.49 for T1 (Control) and 7.51 for T2 (Device), indicating moderate scale-dissolving potential.


#### 4.5.2 Biological Parameters

Biological data collected during this trial with ultrasonic device are shown in **Figure 26 – Figure 28**. The planktonic and sessile microbial populations were comparable in each of the two towers for the duration of this trial. There was no observed reduction in microbial activity in T2 (Device). A chlorination test was performed beginning on 10/2. The last data point (10/4) is excluded from the discussion of the data collected in this trial and the results of this chlorination test will be discussed together with other chlorination tests conducted throughout this study in Section 4.7 of this report.


The planktonic heterotrophic plate counts for each tower system during this device trial are shown in **Figure 26**. Each tower system had heterotrophic plate counts higher than the industrial standard of  $10^4$  CFU/mL. T2 (Device) maintained a lower microbial population on 6 of the 9 sampling dates. If the non-chemical device reduced the average tower microbial concentrations, it should have been reflected in a significant difference between microbial counts for T1 (Control) and T2 (Device). However, no statistically significant difference between the microbial counts was observed in the two towers. A paired t-test was used to compare log 10 planktonic heterotrophic plate



**Figure 26 – Planktonic microbial population (HPC) for UD trial**



**Figure 27 – Planktonic microbial population (ATP measurement) for UD trial**



**Figure 28 – Sessile microbial population for UD trial**

counts for each tower system, resulting in a p value of 0.449. This indicates that the observed difference between the planktonic heterotrophic plate counts in T1 (Control) and T2 (Device) was not statistically significant.

Planktonic microbial populations in each tower were also enumerated by converting measured cellular ATP concentrations to microbial equivalents using the equation previously discussed in this report. The planktonic microbial equivalent values determined in this fashion are shown in **Figure 27**. While T2 (Device) maintained a lower microbial population throughout the device trial, the difference between T1 (Control) and T2 (Device) was less than 1 log value. A paired t-test was performed using the log 10 microbial equivalent data from this device trial, resulting in a p-value of  $p = 0.063$ . This

indicates that the observed difference between the microbial populations in T1 (Control) and T2 (Device) was not statistically significant.

Sessile heterotrophic plate counts from T1 (Control) and T2 (Device) were also comparable throughout the course of this investigation (**Figure 28**). A paired t-test was performed using the log 10 sessile heterotrophic plate counts, resulting in a p-value of  $p = 0.469$ . This indicates that the observed difference between the sessile heterotrophic plate counts in T1 (Control) and T2 (Device) was not statistically significant.

The make-up water contained a heterotrophic biological population between 1,800 – 120,000 CFU/mL during this device trial, with an average value of approximately 23,000 CFU/mL. Make-up water biological growth was allowed to occur without any means of biocidal control since water was dechlorinated prior to usage. No artificial microbial seeding was performed on the make-up water during this or any of the device trials.

Since no sessile or planktonic microbial control was demonstrated during Phase I, the device investigation was terminated without performing the Phase II testing. Phase I consisted of operating both the control and device towers for 4 weeks, with the non-chemical treatment device activated at the beginning of the investigation. This phase was completed for the ultrasonic treatment device. Phase II was to be conducted after a 2 week period during which each tower was allowed to operate with no treatment. The device would then be activated to determine whether or not any existing biological growth in the device tower may be removed through the application of non-chemical treatment.

### 4.5.3 Summary

The results presented in this report demonstrate that the ultrasonic non-chemical device did not significantly reduce biological activity compared to the “control” tower. Planktonic heterotrophic plate counts and ATP measurements from T1 (Control) and T2 (Device) showed no statistically significant difference at any point during the investigation. The same trend was observed for sessile heterotrophic plate counts from each tower system.

## 4.6 HYDRODYNAMIC CAVITATION DEVICE (HCD) TRIAL

The evaluation of the hydrodynamic cavitation treatment device began on 10/27, and it continued uninterrupted until 11/24. All data collected during this investigation is included in Appendix G. Operational and chemical data figures and tables for this investigation are shown in Appendix G.1, and statistical analyses of the chemical data are included in Appendix G.2. Photographs of each of the two tower systems before and after the device trial are included in Appendix G.3, and photographs of biofilm sampling coupons are provided in Appendix G.4.

### 4.6.1 Tower System Operation

Tower operational and chemical data are shown in **Figure G1 - Figure G19**. After three days of operation, the temperature differential for each tower system was 10 – 11.6 °F (**Figure G1**), which was near the target differential of 10 °F. T2 (Device) consumed 443 gal. more make-up water than T1 (Control) over the course of the experiment (**Figure G2**), but cumulative blowdown volumes for the two towers were comparable (**Figure G3**). T2 (Device) most likely consumed more make-up water than T1 (Control) due to increased splashing within the system holding tank caused by the discharge from the non-chemical device recirculation loop.

Tower temperature profiles are shown in **Figure G4** (T1) and **Figure G5** (T2). The heater installed in the T2 (Device) tower system was not operating at full capacity from 10/31 to 11/19. As a result, average tower temperatures were lower in T2 (Device) than in T1 (Control) during this period. Over the course of the experiment, the average temperature entering T1 (Control) was 99.8 °F, while the average temperature entering T2 (Device) was 95.5 °F. The



difference in temperature between the two towers was not severe enough to have a significant impact on microbial growth rates.

Average values and standard deviations for all parameters measured during this investigation are shown in **Table 23**. These values were calculated using the data collected after the first blowdown occurred in each of the towers. Chemical data collected during this investigation are shown in **Figure G8 - Figure G16**.

**Table 23 – Average values and standard deviations for HCD trial**

	T1 (Control)		T2 (Device)	
	Average	Standard Deviation	Average	Standard Deviation
Temperature Entering Tower (°F)	99.8	1.1	95.5	3.2
Sump Temperature (°F)	89.1	1.3	84.9	3.3
Daily Make-up Water Consumption (gal)	124	27	139	32
Daily Blowdown	23	10	23	10
Conductivity (mS/cm)	1.364	0.091	1.385	0.080
pH	8.75	0.04	8.67	0.05
ORP (mV)	180	22	181	23
Alkalinity (mg/L as CaCO <sub>3</sub> )	115	8	115	6
Calcium Hardness (mg/L as CaCO <sub>3</sub> )	201	10	191	14
Magnesium Hardness (mg/L as CaCO <sub>3</sub> )	102	11	99	10
Total Hardness (mg/L as CaCO <sub>3</sub> )	303	16	290	21
TDS (mg/L)	929	66	920	51
LSI	1.36	0.07	1.21	0.10
RSI	6.02	0.10	6.24	0.15
PSI	7.21	0.11	7.35	0.14
Planktonic HPC (CFU/mL)	9.56E+04	4.50E+04	1.24E+05	9.03E+04
ATP Microbial Equivalents (MEQs/mL)	3.81E+05	1.12E+05	5.65E+05	3.03E+05
Sessile HPC (CFU/cm <sup>2</sup> )	6.37E+05	3.37E+05	2.10E+06	9.48E+05


Three scaling indices were calculated using the chemical parameters measured during this device trial. The Langelier Saturation Index (**Figure G17**) was approximately 1.36 for T1 (Control) at equilibrium, and the equilibrium value for T2 (Device) was approximately 1.21. These values indicate that each system had mild scaling potential. The Ryznar Stability Index (**Figure G18**) was 6.02 for T1 (Control) and 6.24 for T2 (Device) at equilibrium, while the equilibrium values of the Puckorius Scaling Index (**Figure G19**) for T1 (Control) and T2 (Device) were 7.21 and 7.35, respectively. All of these scaling index values indicate mild scaling potential in both T1 (Control) and T2 (Device).

#### **4.6.2 Biological Parameters**

Biological data collected during this investigation are included in **Figure 29 – Figure 31**. Based on these data, there was no observed biocidal effect as a result of the device installation. T1 (Control) and T2 (Device) demonstrated comparable sessile and planktonic microbial growth throughout the device trial.


Planktonic heterotrophic plate counts for each tower system over the course of the device trial are shown in **Figure 29**. Neither T1 (Control) nor T2 (Device) maintained planktonic microbial levels below the industry standard ( $10^4$  CFU/mL). The average planktonic heterotrophic plate count for T1 (Control) was  $9.56 \times 10^4$  CFU/mL with a standard deviation of  $4.50 \times 10^4$  CFU/mL, while the average value for T2 (Device) was  $1.24 \times 10^5$  CFU/mL with a standard deviation of  $9.03 \times 10^4$  CFU/mL. A paired t-test was performed using the log 10 heterotrophic plate count data from this device trial, resulting in a p-value of 0.513. This

indicates that the observed difference between the planktonic microbial populations of T1 (Control) and T2 (Device) was not statistically significant.




**Figure 29 – Planktonic microbial population enumerated by heterotrophic plate count for HCD trial**

The planktonic microbial population in each tower system was also enumerated by converting cellular ATP measurements to microbial equivalents using the equation described previously in this report. The planktonic microbial equivalents for each tower system during the course of this device trial are shown in **Figure 30**. The microbial population was higher in T2 (Device) than T1 (Control) on 7 of the 9 sampling dates. A paired t-test was performed using the log 10 microbial equivalent data, resulting in a p-value of  $p = 0.058$ . This indicates that the observed difference between the microbial populations observed in T1 (Control) and T2 (Device) was not statistically significant.



**Figure 30 – Planktonic microbial population enumerated by ATP measurement for HCD trial**

The average sessile heterotrophic plate count (**Figure 31**) for T1 (Control) was  $6.37 \times 10^5$  CFU/cm<sup>2</sup> with a standard deviation of  $3.37 \times 10^5$  CFU/cm<sup>2</sup>, while for T2 (Device) the average was  $2.10 \times 10^6$  CFU/cm<sup>2</sup> with a standard deviation of  $9.48 \times 10^5$  CFU/cm<sup>2</sup>. T2 (Device) maintained a higher sessile microbial population than T1 (Control) on 3 of the 4 sampling dates. A paired t-test was performed using the log 10 sessile heterotrophic plate count data from this device trial, resulting in a p-value of 0.058. This indicates that the observed difference between the sessile microbial populations in T1 (Control) and T2 (Device) was not statistically significant. Since no significant difference in the sessile and planktonic microbial populations was observed between T1 (Control) and T2 (Device), the investigation was terminated following the completion of Phase I. Phase II was not completed for this treatment device.



**Figure 31 – Sessile microbial population for HCD trial**

The make-up water contained a heterotrophic biological population between 8,000 – 60,000 CFU/mL during this device trial, with an average value of approximately 23,000 CFU/mL. Make-up water biological growth was allowed to occur without any means of biocidal control since water was dechlorinated prior to usage. No artificial microbial seeding was performed on the make-up water during this or any of the device trials.

### 4.6.3 Summary

The results presented in this report demonstrate that the hydrodynamic cavitation non-chemical device did not reduce planktonic or sessile microbial populations compared to the “control” tower. Heterotrophic plate counts for both planktonic and sessile microbial populations were comparable for T1 (Control) and T2 (Device). In addition, ATP measurements showed no significant microbial reduction in the device tower system when compared to the control tower system.

## 4.7 CHLORINATION TEST RESULTS

Over the course of the investigation, 3 separate chlorination tests were performed to demonstrate effective chemical microbial control. The first chlorination test was performed from 1/15/09 – 1/26/09. The second chlorination was performed immediately following the ED trial (8/14/09 – 8/23/09), and the third was performed immediately following the UD trial (9/27/09 – 10/4/09).

The selection of free chlorine as a positive control was based on common practice in cooling water treatment and a previous study where several chemical biocides, including free chlorine, were evaluated in model cooling towers that simulated real-world cooling tower operational conditions (Thomas et al., 1999). A detailed description of both the results of the Thomas et al. study and the protocol used for each chlorination test during this investigation is included in Section 2.2.3 of this report.

### 4.7.1 Pre-Device Trial Chlorination Test

The first chlorination test was performed prior to the beginning of the device trials. During this test, both T1 (Control) and T2 (Device) operated untreated from 1/15 – 1/22. After samples were taken on 1/22, a spike dose of chlorine was added to each of the towers. Following this spike dose, chlorine stock solution was pumped into each tower system to maintain a chlorine concentration of approximately 1 mg/L. The planktonic microbial population enumerated by heterotrophic plate count is shown in **Figure 32**, while ATP enumeration is shown in **Figure 33**. Each tower demonstrated a 2-3 log reduction in planktonic microbial activity within 3 days from the beginning of chlorination. The sessile microbial population is shown in **Figure 34**.

Chlorination produced a 4-5 log reduction in sessile microbial activity in each of the tower systems. Make-up water heterotrophic plate counts observed during this chlorination test were comparable to those observed during the device trials which followed.






Figure 32 – Pre-device trial chlorination test planktonic microbial population enumerated by HPC






**Figure 33 – Pre-device trial chlorination test planktonic microbial population enumerated by ATP**




**Figure 34 – Pre-device trial chlorination test sessile microbial population**

#### 4.7.2 ED/UD Chlorination Test

The second chlorination test was performed immediately after the ED trial and before the towers were prepared for the UD trial. During this chlorination test, T2 (Device) received chemical treatment, while T1 (Control) remained untreated. Chlorination began on 8/21 after biological samples were taken. The chlorination process began with a spike dose of chlorine, followed by a steady flow of chlorine stock solution in order to maintain a free chlorine concentration of approximately 1 mg/L. The planktonic microbial population is shown enumerated by HPC in **Figure 35** and enumerated by ATP in **Figure 36**. Make-up water heterotrophic plate counts observed during this chlorination test were comparable to those observed during each device trial.



**Figure 35 – ED/UD chlorination test planktonic microbial population enumerated by HPC**




**Figure 36 – ED/UD chlorination test planktonic microbial population enumerated by ATP**

The planktonic microbial population experienced a 2 log reduction within 2 days of the beginning of chlorination. The sessile microbial population is shown in **Figure 37**. Chlorination resulted in a 4 log reduction in the sessile microbial population.


### 4.7.3 UD/HCD Chlorination Test

The third chlorination test was performed immediately following the UD trial and immediately before the towers were prepared for the HCD trial. Chlorination of T2 (Device) began on 10/1 following biological sampling, and it was performed using a steady dose of chlorine stock solution. No shock dose of chlorine was used for this test, but instead a gradual increase in chlorine concentration was performed over a period of 5 days until the concentration reached 1 mg/L. The planktonic microbial population enumerated by HPC is shown in **Figure 38** and


enumerated by ATP in **Figure 39**. Make-up water heterotrophic plate counts observed during this chlorination tests were comparable to those observed during all other device trials.



**Figure 37 – ED/UD chlorination test sessile microbial population**




**Figure 38 – UD/HCD chlorination test planktonic microbial population enumerated by HPC**



**Figure 39 – UD/HCD chlorination test planktonic microbial population enumerated by ATP**

The HPC enumeration of the planktonic microbial population showed an increase in microbial activity following chlorination, rather than a decrease. This result is contradictory to the results of the previous chlorination tests. Tower planktonic heterotrophic plate count increased from  $4.0 \times 10^4$  CFU/mL to  $1.2 \times 10^5$  CFU/mL. Sessile heterotrophic plate counts decreased from  $3.2 \times 10^6$  CFU/cm<sup>2</sup> to  $6.2 \times 10^3$  CFU/cm<sup>2</sup> (**Figure 40**). The observed 3 log reduction in the sessile microbial population of T2 (Device) following chlorination indicates that biomass was effectively removed from surfaces within the system. The results in Fig 38 could be due to entrainment of biomass from the surfaces as a result of removal during chlorination. This effect is often observed in field situation: an effective biocide treatment causes release of biomass from surfaces into the recirculating water which results in very high but transient planktonic counts. In the previous chlorination tests, the initial shock dose of chlorine would

have effectively oxidized this material, but the lower chlorine dose used during this particular test were unable to effectively oxidize the majority of this material during three days of operation.



**Figure 40 – UD/HCD chlorination test sessile microbial population**

## 4.8 HPC ANALYSES USING ATP MICROBIAL EQUIVALENTS AND POUR PLATE METHOD


While standard plating practices allow for accurate enumeration of planktonic microbial populations in water samples, these methods generally require a minimum of three days in order to process the sample. Microbial population enumeration via ATP measurement, however, is a simple process which may be completed in approximately one hour. As a result, it is highly desirable to establish the practical utility of the ATP method in terms of its ability to accurately quantify the planktonic microbial population in cooling water samples.

In order to determine whether the ATP measurement offers a valid alternative to traditional plating techniques, heterotrophic plate count data and ATP microbial equivalent data from the entire investigation were compared. This comparison indicated that all heterotrophic plate counts and ATP microbial equivalent measurements collected in this study had a coefficient of correlation of  $R^2 = 0.37$ .

The observed correlation between ATP microbial equivalents and HPC CFU/mL values is quite low. This weak correlation is most likely due to the inclusion of all experimental data, even those that were later discarded. For example, a device trial that was performed with MD at the beginning of this study had to be interrupted due to numerous operational problems. The ATP measurements taken from this period were included in this comparative analysis although they demonstrate a far weaker correlation with HPC measurements than was observed during the six device trials discussed in this report. As a result, these data were removed and the comparative analysis was performed a second time. Excluding the data from this failed device trial, a correlation of  $R^2 = 0.77$  was observed between ATP microbial equivalents and HPC

measurements taken from the tower systems. These results indicate that ATP measurement offers a fast means of estimating planktonic activity in a given water sample for microbial populations in excess of  $10^5$  CFU/mL. However, traditional plating techniques should be used when accurate measurements are required.

The correlation between ATP microbial equivalents and HPC measurements in the system make-up water was also analyzed. A graph comparing these data is shown in **Figure 41**. The correlation observed between the two data sets was relatively low, and make-up water microbial equivalent levels were generally on the order of 1 log value higher than those determined using heterotrophic plate counts. Based on this comparison, it may be concluded that ATP measurement does not offer a reliable estimation of microbial populations when the HPC values are below  $10^4$  CFU/mL. However, it is possible that water samples with lower microbial populations require larger sample volume during analysis in order to produce accurate results (the sample volume for both the systems water and the make-up water was 50 mL).



**Figure 41 –HPC vs. ATP measurement of planktonic microbial population in make-up water**



## 5.0 SUMMARY AND CONCLUSIONS

Many facilities managers are faced with increasing pressure to utilize “green” technologies for the operation of cooling systems. The goal is to increase efficiency and reduce water consumption. One choice they often face is whether to continue to use conventional chemical water treatment or to use non-chemical water treatment devices as an alternative. There are many different non-chemical devices commercially available today. In order to make an informed decision, objective evidence of the efficacy of these non-chemical devices for cooling water management is needed.

Very limited objective and relevant information is available to verify the efficacy of these non-chemical devices to control microbial growth in cooling towers in the field, which is an essential element in the efficient operation of a cooling tower. Review of the literature reveals few controlled studies on the efficacy of non-chemical devices, and none that were performed under conditions that simulate normal cooling tower operation. Therefore, this study was designed to provide a controlled, independent, scientific evaluation of a variety of classes of non-chemical devices in a model cooling tower operated to simulate typical cooling tower operation.

This study examined the efficacy of five (5) NCDs to control the planktonic and sessile microbial populations in a pilot-scale cooling tower system. The model towers were operated according to specifications from ASHRAE and were representative of typical operation of a

cooling tower, including cycles of concentration, temperature differential, and water chemistry. The make-up water was dechlorinated using an activated carbon filter, a method that has been used previously to produce dechlorinated water for disinfection studies. The use of dechlorinated city tap water was specified to eliminate any antimicrobial effects of chlorine in the make-up water. It would be expected that without chlorine the microbial concentrations in this water would be higher than chlorinated water. However, the concentrations of HPC bacteria that we observed in the make-up water were not unlike the average microbial counts in tap water observed by other investigators.

Under the controlled experimental conditions used in this study, none of the devices were shown to control microbial growth. There was no statistically significant difference in the concentration of HPC observed between the control tower and a tower treated by any of the five NCDs evaluated in this study (i.e., biological and chemical parameters were comparable in T1 and T2 for all device trials). The p-values calculated from t-tests comparing planktonic HPC results for the experimental and control towers were 0.81, 0.92, 0.60, 0.45, and 0.51 for the magnetic, pulsed electric field, electrostatic, ultrasonic, and hydrodynamic cavitation device trials, respectively. The p-values from t-tests comparing sessile HPC results for the experimental and control towers were 0.04, 0.13, 0.43, 0.47, and 0.06 for the magnetic, pulsed electric field, electrostatic, ultrasonic, and hydrodynamic cavitation device trials, respectively.

Repeated chemical treatment of the pilot-scale cooling towers using an industry accepted chemical biocide of known efficacy (chlorine) achieved significant reduction (i.e., three orders of magnitude) in microbial growth in these towers. These “positive control” experiments demonstrated that the model system, when treated with an active biocide, was capable of reflecting this antimicrobial effect.

In addition to not being able to achieve significant reduction in planktonic or sessile microbial activity in the experimental device tower system (T2 (Device)) when compared to the control tower system (T1 (Control)), planktonic microbial levels in the experimental device tower (T2 (Device)) were consistently higher than recommended industry standard of  $10^4$  CFU/mL. Furthermore, microbial levels in the Device tower (T-2) were never lower than those observed in the incoming make-up water, further demonstrating that no biological control was demonstrated by these five NCDs under the experimental conditions used in this study.

The findings of this study are not in agreement with previous research published by non-chemical device manufacturers and some reports from independent researchers on these same devices. These studies reported reductions in microbial populations, which were not observed in this study. Therefore, it is important to review the reasons for differing outcomes.

The scientific peer-reviewed literature offers little in the way of reports that verify the antimicrobial effects of many non-chemical devices. For example, electroporation is one of the mechanisms that has been suggested as the basis for an antimicrobial effect from devices such as those using static or pulsed power. While electroporation is effectively used in molecular biology to disrupt cell membranes, it should be noted that the electromagnetic fields used in these applications include high energy (volts to kilovolts), are applied across very short distances (centimeters), and for long exposure times. The conditions applied in the field application of static or pulsed power devices and in the present study produce exposures of considerably less energy and are applied over greater distances and shorter exposure time.

Comparison between HPC analysis by pour plate method and ATP measurements revealed that the ATP measurement offers a fast means of estimating planktonic activity in a water sample containing microbial populations in excess of  $10^5$  CFU/mL. On the other hand,

ATP measurement does not offer a reliable estimation of microbial populations when the HPC values are below  $10^4$  CFU/mL. It is possible that water samples with lower microbial populations require larger sample volume during analysis in order to produce accurate results.

In conclusion, none of the NCDs evaluated in this study demonstrated significant biological control in model cooling tower system operated under realistic process conditions that may be encountered in the field. However, this study still offers several opportunities for continued investigation of non-chemical treatment devices. The effects of residual chlorine in the incoming make-up water were not analyzed during this investigation, and the effect of some non-chemical water treatment devices may be augmented by the presence of chlorine. In addition, the combined effects of chemical (e.g., oxidizing and non-oxidizing biocides) and physical treatment technologies on the control of biological growth in cooling towers may offer significant advantages. Combining hydrodynamic cavitation as well as ultrasonic cavitation with chemical disinfection has been shown to achieve significant kill of different microorganisms and the use of such hybrid systems (both chemical and physical) certainly warrants further investigation.

The results from this study show that effective microbial control in cooling water systems may not be achieved using a non-chemical device as the sole method of water treatment. Consequently, equipment operators, building owners and engineers should consider taking more frequent water sample tests for their systems that rely on NCD devices for biological control. If the testing shows an issue, one possible measure is to add chemical treatment capability to their system.

## 6.0 REFERENCES

- Abderahmane, S., A. Himour, and L. Ponsonnet. 2008. "Inactivation of *E. Coli* and *Pseudomonas aeruginosa* by Electrochlorination Under Bipolar Pulsed Polarization." *Materials Science & Engineering: C*. Vol 28, Issue 5/6, pp. 901-905.
- Amin, Muhammad Tahir, and Mooyoung Han. 2009. "Roof-harvested rainwater for potable purposes: application of solar disinfection (SODIS) and limitations." *Water Science & Technology*. 60.2, 419 – 431.
- Bagh, Lene Karen, Hans-Jørgen Albrechtsen, Erik Arvin, and Kaj Ovesen. 2004. "Distribution of bacteria in a domestic hot water system in a Danish apartment building." *Water Research*. 38(1), 225-235.
- Bagh, Lene Karen, H-J Albrechtsen, and E. Arvin. 2002. "Biofilm formation in a hot water system." *Water Science & Technology*. 46(9), 95-101.
- Baker, J.S., Judd, S.J. 1996. "Magnetic Amelioration of Scale Formation." *Wat. Res.* 30, pp 247-260.
- Benjamin, T.B., and A.T. Ellis. 1966. "The Collapse of Cavitation Bubbles and the Pressures Thereby Produced Against Solid Boundaries." *Phil. Trans. Roy. Soc.* London. Ser. A 260, 221-240.
- Bentham, R. H. (1993). "Environmental factors affecting the colonization of cooling towers by *Legionella* spp in South Australia." *International Biodeterioration and Biodegradation* **31**: 55-63.
- Blume, T., and U. Neis. 2004. "Improved wastewater disinfection by ultrasonic pre-treatment." *Ultrasonic Sonochemistry*. Vol. 11, Pp. 333–336.
- Bogatin, J. 1999. "Magnetic Treatment of Irrigation Water: Experimental Results and Application Conditions." *Environmental Science & Technology*, 33, 8. Pp. 1280-1285.
- Brennen, C.E. 1995. *Cavitation and Bubble Dynamics*. New York: Oxford University Press.

- Chaidez, Cristobal, and Charles P. Gerba. 2004. "Comparison of the microbiologic quality of point-of-use (POU)-treated water and tap water." *International Journal of Environmental Health Research*. 14(4), 253-260.
- Cheremisinoff, Nicholas P. and Paul N. Cheremisinoff. *Cooling Towers: Selection, Design, and Practice*. Ann Arbor, MI: Ann Arbor Science Publishers, Inc., 1981.
- Cho, Young I. 2002. "Efficacy of physical water treatments in controlling calcium scale accumulation in recirculating open cooling water system." ASHRAE Research Project 1155-TRP.
- Danilenko, N.B., G.G. Savel'ev, N.A. Yavorovskii, M.B. Khaskel'berg, T. A. Yurmazova, and V. V. Shamanskii. 2005. "Water Purification to Remove As(V) by Electropulse Treatment of an Active Metallic Charge." *Russian Journal of Applied Chemistry*. Vol. 78, No. 10, pp. 1631-1635.
- "Environmentally Sustainable Cooling Tower Treatment." 2008. ED Fact Sheet. Kansas City, KS.
- Feng, Chuanping, Norio Sugiura, and Takaaki Maekawa. 2000. "Study on the Electrochemical Treatment of Wastewater, Fundamental Experiments For Developing the Treatment Equipment." The XIV Memorial CIGR World Congress 2000, pp. 1306-1311.
- Feng, Chuanping, Keitaro Suzuki, Shuyun Zhao, Norio Sugiura, Satoru Shimada, and Takaaki Maekawa. 2004. "Water Disinfection by Electrochemical Treatment." *Bioresource Technology*. 94, 21-25.
- Faunce, A., and S. Cabell. 1890. U.S. Patent 48,579.
- Furuta, M., Yamaguchi, M., Tsukamoto, T., Yim, B., Stavarche, C.E., Hasiba, K., and Maeda, Y. 2004. "Inactivation of *Escherichia coli* by ultrasonic irradiation." *Ultrasonic Sonochemistry*. Vol. 11, Pp. 57-60.
- Gabrielli, C., R. Jaouhari, G. Maurin and M. Keddam. 2001. "Magnetic water treatment for scale prevention." *Wat. Res.* Vol. 35, No. 13, pp. 3249-3259.
- Gaines, W.A., C. Bailey, B.R. Kim, T. Loch, A.R. Drews, and S. Frenette. 2007. "Controlling Cooling Tower Water Quality by Hydrodynamic Cavitation." LB-07-028. *ASHRAE Transactions*, Vol. 113, Pt. 2., Pp 250-260.
- Harvey, E.N, and A. L. Loomis. 1929. "The destruction of luminous bacteria by high frequency sound waves." *Journal of Bacteriology*. Vol 17, Pp. 373-379.
- Hua, I., and J. Thompson. 2000. "Inactivation of *Escherichia coli* by sonication at discrete ultrasonic frequencies." *Water Resources*. Vol. 34, Pp. 3888-3893.

- Jones, Garth W., Liza Baines, and Fred J. Genthner. 1991. "Heterotrophic bacteria of the freshwater neuston and their ability to act as plasmid recipients under nutrient deprived conditions." *Microbial Ecology*. Vol. 22, No. 1, 15-25.
- Jousimies-Somer, Hannele R., Sirkku Waarala, and Marja-Liisa Väisänen. "Recovery of *Legionella* spp. from water samples by four different methods." *Legionella: Current Status and Emerging Perspectives*. Eds. James M Barbaree, Robert F. Breiman, and Alfred P. Dufour. Washington, D.C.: American Society for Microbiology, 1993. 200-201. Print.
- Joyce, E. 2003. "The effects of ultrasound in combination with UV radiation or electrolysis on the bacterial decontamination of potable water." Ph.D. Thesis, Coventry University.
- Jyoti, K.K., and A.B. Pandit. 2003. "Hybrid Cavitation Methods For Water Disinfection." *Biochem. Eng. Journal*. 14, 9-17.
- Jyoti, K.K., and A.B. Pandit. 2004. "Ozone and Cavitation For Water Disinfection." *Biochem. Eng. Journal*. 18, 9-19.
- Kalumuck, K.M., G.L. Chahine, C. Hsiao, and J. Choi. 2003. "Remediation and Disinfection of Water Using Jet Generated Cavitation." Fifth International Symposium on Cavitation. November 1-4, Osaka, Japan.
- Kitzman, Kevin A., Edward F. Maziarz, Bobby Padgett, Charles D. Blumenschein, and Alan Smith. "Chemical vs. Non-Chemical Cooling Water Treatments – A Side-by-side Comparison." IWC-03-22. Presented at the International Water Conference, October 2003.
- Kuivinen, David E. 1975. "Comparing Corrosion Rates of Steel Corrosion coupons in Magnetically Treated Water and in a Water System Utilizing Corrosion Inhibitors." National Aeronautics and Space Administration, Lewis Research Center, Cleveland.
- LeChevallier, Mark W., Timothy M. Babcock, and Ramon G. Lee. 1987. "Examination and Characterization of Distribution System Biofilms." *App. And Env. Microbio*. 53(12), Pp. 2714-2724.
- Lee, J., D. Lee, and J. Sohn. 2007. "An Experimental Study For Chlorine Residual and Trihalomethane Formation With Rechlorination." *Water Sci. Tech*. 55, 307-313.
- Lin, I. J., and S. Nadiv. 1988. "Membrane Performance Under the Influence of Magnetic Pretreatment." *Magnetic Separation News*. Vol. 2, 137-143.

- Loret, J.F., F. Robert, V. Thomas, A.J. Cooper, W.F. McCoy, and Y. Levi. 2005. "Comparison of Disinfectants for Biofilm, Protozoa, and Legionella Control." *J. Water and Health*, 03.4, 423-433.
- Mason, T. J., H. Duckhouse, E. Joyce, and J.P. Lorimer. 2003. "Uses of ultrasound in the biological decontamination of water." 5<sup>th</sup> World Congress on Ultrasonics (WCU). Paris, France, September 7-10.
- Mason, T.J., E. Joyce, S.S. Phull, and J.P. Lorimer. 2003. "Potential uses of ultrasound in the biological decontamination of water." *Ultrasonics Sonochemistry*. Vol. 10, Pp. 319-324.
- Min, S., G.A. Evrendilek, and H.Q. Zhang. 2007. "Pulsed Electric Fields: Processing System, Microbial and Enzyme Inhibition, and Shelf Life Extension of Foods." *IEEE Trans Plasma Sci.* 35, 59-73.
- Naude, C.F., and A.T. Ellis. 1961. "On the Mechanism of Cavitation Damage by Nonhemispherical Cavities in Contact with a Solid Boundary." *ASME J. Basic Eng.* 83, 648-656.
- Opheim, Dennis. 2001. "Biological Control in Cooling Towers Treated with Pulsed-Power Systems." IWC-01-54. Presented at the International Water Conference, October 2001.
- Oshima, T., K. Sato, H. Terauchi, and M. Sato. 1997. "Physical and Chemical Modification of High-Voltage Pulse Sterilization." *J. Electrostat.* 42, 159-166.
- Ovesen, K., F. Schmidt-Jørgensen, and L. K. Bagh. 1994. "Bacterial growth in hot water systems." Danish Building Research Institute. Report No. 235. Hørsholm, Denmark; 1994 [In Danish, summary in English].
- PEFD Technical Manual. 2008. CWSTL0204. Essex, Ct.
- Pepper, I. L., P. Rusin, D. R. Quintanar, C. Haney, K.L. Josephson, and C.P. Gerba. 2004. "Tracking the concentrations of heterotrophic plate count bacteria from the source to the consumer's tap." *International Journal of Food Microbiology*. 92, 265-271.
- Phull, S.S., Newman, A.P., Lorimer, J.P., Pollet, B., and Mason, T.J. 1997. "The development and evaluation of ultrasound in the biocidal treatment of water." *Ultrasonic Sonochemistry*. Vol. 4, Pp. 157-164.
- Quinn, C. Jack, T. Craig Molden, and Charles H. Sanderson. July 1997. "Magnetic treatment of water prevents mineral build-up." *Iron and Steel Engineer*. Pp. 47-53.
- Ridgway, H.F., and B.H. Olson. 1982. "Chlorine resistance patterns of bacteria from two drinking water distribution systems." *Appl. & Eng. Microbio.* October 1982, p. 972 - 987.



- Rieder, A., T. Schwartz, K. Schön-Hölz, S.-M. Marten, J. Süß, C. Gusbeth, W. Kohnen, W. Swoboda, U. Obst, and W. Frey. 2008. "Molecular Monitoring of Inactivation Efficiencies of Bacteria During Pulsed Electric Field Treatment of Clinical Wastewater." *Journal of Appl. Microbio.* 105, 2035-2045.
- Sawant, Subhash Shivram, Arga Chandrashekar Anil, Venkat Krishnamurthy, Chetan Gaonkar, Janhavi Kolwalkar, Lidita Khandeparker, Dattesh Desai, Amit Vinod Mahulkar, Vivek Vinayak Ranade, and Aniruddha Balchandra Pandit. 2008. "Effect of Hydrodynamic Cavitation on Zooplankton: A Tool for Disinfection." *Biochem. Eng. Journal.* 42, 320-328.
- Scappatura, John. 2002. "Case History: Food Processor." HCD Manufacturer Literature.
- Sheffer, P. J., J. E. Stout, et al. (2005). "Efficacy of new point-of-use water filters for preventing exposure to Legionella and waterborne bacteria." *Amer J Infect Cont* **33**(5): S20-S25.
- Scherba, G., Weigel, R., and O'Brien, J.W.D. 1991. "Quantitative assessment of the germicidal efficacy of ultrasonic energy." *Applied Environmental Microbiology.* Vol. 57, Pp. 2079–2084.
- Stout, J. 2002. "New and Emerging Technologies for *Legionella* Control: A Multi-Step Approach to Evaluating Efficacy." IWC-02-02. Presented at the 63<sup>rd</sup> International Water Conference, October 20-24, Pittsburgh, PA.
- Thomas, W. M.; Eccles, J.; Fricker, C., Laboratory observations of biocide efficiency against *Legionella* in model cooling tower systems. *ASHRAE Transactions* **1999**, 105(2), SE-99-3-4 (RP-954).
- Tsong, T.Y. 1991. "Electroporation of Cell Membranes." *Biophys. J.* 60, 297.
- UD Operation Manual. 2008. Barendrecht, Netherlands.
- Vega-Mercado, H., O. Martin-Belloso, Q. Bai-Lin, F.J. Chang, M.M. Gongora-Nieto, G.V. Barbosa-Canovas, and B.G. Swanson. 1997. "Non-Thermal Food Preservation: Pulsed Electric Fields." *Trends in Food Science and Technology.* 8, 151-157.
- Xin, Qing, Xingwang Zhang, and Lecheng Lei. 2008. "Inactivation of Bacteria in Oil-Field Reinjection Water by Pulsed Electric Field (PEF) Process." *Ind. Eng. Chem. Res.* 47 (23), 9644-9650.
- Zhang, Weidong, and Francis A. DiGiano. 2002. "Comparison of bacterial regrowth in distribution systems using free chlorine and chloramines: a statistical study of causative factors." *Water Research.* 36: 1469-1482.

Zimmermann, U. 1986. "Electric Breakdown Electroporation and Electrofusion. *Rev. Physiol. Biochem. Pharmacol.* 105, 176.

## APPENDICES

## APPENDIX A: SCALING INDICES CALCULATION & INTERPRETATION

### LSI Equation

$$A = [\log(\text{TDS}) - 1] / 10 \quad \text{where TDS} = \text{mg/L}$$

$$B = -13.12 * [\log(\text{Temperature} + 273)] + 34.55 \quad \text{where Temperature} = ^\circ\text{C}$$

$$C = \log(\text{Calcium Hardness}) - 0.4 \quad \text{where Calcium Hardness} = \text{mg/L as CaCO}_3$$

$$D = \log(\text{Alkalinity}) \quad \text{where Alkalinity} = \text{mg/L as CaCO}_3$$

$$\text{pH}_s = (9.4 + A + B) - (C + D)$$

$$\text{LSI} = \text{pH} - \text{pH}_s \quad \text{where pH} = \text{measured pH}$$

### RSI Equation

$$\text{RSI} = 2 * \text{pH}_s - \text{pH}$$

### PSI Equation

$$\text{pH}_{\text{eq}} = 1.465 * \log(\text{Alkalinity}) - 4.54$$

$$\text{PSI} = 2 * \text{pH}_s - \text{pH}_{\text{eq}}$$

**Table A1 – LSI, RSI, and PSI values and their interpretations**

<b>LSI</b>	<b>RSI &amp; PSI</b>	<b>SCALING CONDITIONS (TENDENCY)</b>	
3.0+	3.4 - 3.0	----->	Severe Scale Formation
2.0 - 2.9	4.2 - 3.5	----->	Very Strong Scale formation
1.0 - 1.9	5.0 - 4.3	----->	Strong Scale Formation
0.5 - 0.9	5.5 - 5.1	----->	Moderate Scale Formation
0.2 - 0.4	5.8 - 5.6	----->	Slight Scale Formation
0.1 to -0.1	6.2 - 5.9	----->	Little to No Scale Formation (stable)
-0.2 to -0.4	6.6 - 6.3	----->	Slight Tendency to Dissolve Scale (corrosive)
-0.5 to -0.9	7.4 - 6.7	----->	Moderate Tendency to Dissolve Scale (corrosive)
-1.0 to -1.9	8.3 - 7.5	----->	Strong Tendency to Dissolve Scale (corrosive)
-2.0 to -2.9	9.1 - 8.4	----->	Very Strong Tendency to Dissolve Scale (corrosive)
-3.0 or <	10.0 - 9.2	----->	Severe Tendency to Dissolve Scale (corrosive)

## APPENDIX B: EXPERIMENTAL REPRODUCIBILITY

### APPENDIX B.1 – MAKE-UP WATER QUALITY






Figure B1 – Make-up water conductivity for each device trial



**Figure B2 – Make-up water pH for each device trial**



**Figure B3 – Make-up water alkalinity for each device run. Alkalinity was monitored on a monthly basis prior to PEFD Trial 2/2**




Figure B4 – Make-up water chloride concentrations for each device trial



**Table B1 – Monthly make-up water parameter measurements**

<b>Month</b>	<b>Jan.</b>	<b>Feb.</b>	<b>Mar.</b>	<b>Apr</b>	<b>May</b>	<b>June</b>	<b>July</b>	<b>Aug.</b>	<b>Sept.</b>	<b>Oct.</b>	<b>Nov.</b>
<b>Chloride (mg/L)</b>	-	38.1	42.3	45.7	33.2	33.8	34.7	31.9	38.8	36.5	33
<b>Sulfate (mg/L)</b>	36.9	32.8	31.9	45.2	44.7	37.6	48.8	51.1	36.2	42.7	39.6
<b>Phosphate (mg/L as PO<sub>4</sub>)</b>	0.72	0.84	0.79	1.15	1.13	1.43	1.21	1.85	1.17	1.12	1.25
<b>Free Chlorine (mg/L)</b>	< 0.02	0.01	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.01	0.03
<b>Total Fe (mg/L)</b>	0.08	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>Total Cu (mg/L)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>Calcium Hardness (mg/L as CaCO<sub>3</sub>)</b>	71	48.7	25.7	41.7	45.2	19.2	26	30.2	28.2	28.7	24.2
<b>Total Hardness (mg/L as CaCO<sub>3</sub>)</b>	99	69.7	41.4	65.2	76.9	48.9	55.2	57.4	50.4	49.5	41.8
<b>Total Alkalinity (mg/L as CaCO<sub>3</sub>)</b>	45.7	50	45.5	52.5	40	21	23	26	26	25	31
<b>TDS (mg/L)</b>	93	124	109	117	257	198	191	213	193	192	179
<b>Conductivity (mS/cm)</b>	0.32	0.29	0.212	0.29	0.28 9	0.30 9	0.31 2	0.29 8	0.353	0.34 3	0.32 2
<b>pH</b>	~ 8	7.64	7.54	7.62	7.71	7.27	7.15	7.11	7.3	7.53	7.48

## APPENDIX B.2 – T1 (CONTROL) WATER QUALITY







Figure B5 – T1 (Control) combined temperature differential data




**Figure B6 – T1 (Control) cumulative temperature profile**



**Figure B7 – T1 (Control) combined conductivity data**



**Figure B8 – T1 (Control) combined pH data**



**Figure B9 – T1 (Control) combined alkalinity data**




Figure B10 – T1 (Control) combined calcium hardness data




Figure B11 – T1 (Control) combined magnesium hardness data




Figure B12 – T1 (Control) combined total hardness data







Figure B13 – T1 (Control) combined total dissolved solids data



**Figure B14 – T1 (Control) combined LSI**



**Figure B15 – T1 (Control) combined RSI**



**Figure B16 – T1 (Control) combined PSI**



## APPENDIX C: MD TRIAL

### APPENDIX C.1 – EXPERIMENTAL RESULTS

NOTE: Operational problems led to periods of tower shutoff (3/29 – 4/6 and 4/11 – 4/13 for T1, 3/29 – 4/1 for T2). Data was not available for these date ranges. Continuous logging of pH and conductivity did not begin until 3/19




Figure C1 – Temperature differential for MD trial




Figure C2 – Cumulative make-up water consumption for MD trial




Figure C3 – Cumulative blowdown volume for MD trial




Figure C4 – Temperature profile for T1 (Control), MD trial




Figure C5 – Temperature profile for T2 (Device), MD trial




Figure C6 – Ambient temperature conditions.






Figure C7 – Ambient relative humidity



**Figure C8 – Continuous conductivity data for MD trial**



**Figure C9 – Continuous pH data for MD trial**




Figure C10 – Oxidation-reduction potential for MD trial







Figure C11 – Make-up water conductivity and pH for MD trial




**Figure C12 – Alkalinity data for MD trial**



**Figure C13 – Calcium hardness data for MD trial**




**Figure C14 – Magnesium hardness data for MD trial**




**Figure C15 – Total hardness data for MD trial**







**Figure C16 – Total dissolved solids for MD trial**



**Figure C17 – Langelier Saturation Index for MD trial**



**Figure C18 – Ryznar Saturation Index for MD trial**



**Figure C19 – Puckorius Scaling Index for MD trial**

**Table C1 – Chloride measurements for MD trial**

<b>Chloride (mg/L)</b>					
<b>Date</b>	<b>MU</b>	<b>T1</b>	<b>T2</b>	<b>T1 COC</b>	<b>T2 COC</b>
<b>3/13/09</b>	42.3	43.5	44.1		
<b>3/20/09</b>	41.8	148.0	155.5	3.54	3.72
<b>3/27/09</b>	39.6	207.5	219.8	5.24	5.55
<b>4/10/09</b>	45.7	237.2	252.7	5.19	5.53
<b>4/20/09</b>	42.1	234.5	245.4	5.57	5.83

## APPENDIX C.2 – STATISTICAL ANALYSES

### CHEMICAL PARAMETERS

**Table C2 – Conductivity statistical analysis for MD trial**

(Conductivity data are shown in **Figure C8**. A paired t-test was used to compare conductivity measurements taken from each of the two tower systems)

**p = 0.65**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	42	.9197857	.0375412	.2432948	.8439697	.9956017
tower 2	42	.9101905	.044922	.2911281	.8194686	1.000912
diff	42	.0095952	.0209269	.135622	-.0326675	.051858
mean(diff) = mean(conductivitypr~m - conduc2)					t =	0.4585
Ho: mean(diff) = 0				degrees of freedom =	41	
Ha: mean(diff) < 0	Ha: mean(diff) != 0		Ha: mean(diff) > 0			
Pr(T < t) = 0.6755	Pr( T  >  t ) = 0.6490		Pr(T > t) = 0.3245			

**This t-test reveals that there is no significant difference between the conductivity in T1 (Control) and T2 (Device) during this investigation**

**Table C3 – pH statistical analysis for MD trial**

(pH data are shown in **Figure C9**. A paired t-test was used to compare pH measurements taken from each of the two tower systems)

**p = 0.07**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	27	8.515185	.0331378	.1721889	8.44707	8.583301
tower 2	27	8.532593	.0397485	.2065391	8.450888	8.614297
diff	27	-.0174073	.0091145	.0473605	-.0361425	.0013278
mean(diff) = mean(ph - ph2)					t =	-1.9098
Ho: mean(diff) = 0				degrees of freedom =	26	
Ha: mean(diff) < 0	Ha: mean(diff) != 0		Ha: mean(diff) > 0			
Pr(T < t) = 0.0336	Pr( T  >  t ) = 0.0672		Pr(T > t) = 0.9664			

**The results of this t-test reveal that T1 (Control) had a slightly lower pH than T2 (Device) throughout this investigation**

**Table C4 – Alkalinity statistical analysis for MD trial**

(Alkalinity measurements taken during this investigation are shown in **Figure C12**. A paired t-test was used to compare alkalinity measurements taken from each of the two tower systems)

**p = 0.72**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	25	121.956	6.543007	32.71503	108.4519	135.4601
tower 2	25	124.2	4.801736	24.00868	114.2897	134.1103
diff	25	-2.244	6.113553	30.56777	-14.86175	10.37375
mean(diff) = mean(alkalinitymgl~3 - alkal2)					t = -0.3671	
Ho: mean(diff) = 0					degrees of freedom = 24	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.3584		Pr( T  >  t ) = 0.7168		Pr(T > t) = 0.6416		

**The results of this t-test indicate that there was no significant difference between T1 (Control) and T2 (Device) alkalinity measurements during this investigation.**

**Table C5 – Calcium hardness statistical analysis for MD trial**

(Calcium hardness measurements taken during this investigation are shown in **Figure C13**. A paired t-test was used to compare calcium measurements taken from each of the two tower systems)

**p = 0.85**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	25	217.012	36.14174	180.7087	142.4191	291.6049
tower 2	25	215.76	35.23305	176.1652	143.0426	288.4774
diff	25	1.252001	6.467251	32.33626	-12.09575	14.59975
mean(diff) = mean(calciummgla~3 - ca2)					t = 0.1936	
Ho: mean(diff) = 0					degrees of freedom = 24	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.5759		Pr( T  >  t ) = 0.8481		Pr(T > t) = 0.4241		

**The results of this t-test indicate that there was no significant difference between calcium measurements during this investigation.**

**Table C6 – Magnesium hardness statistical analysis for MD trial**

(Magnesium hardness measurements taken during this investigation are shown in **Figure C14**. A paired t-test was used to compare magnesium measurements taken from each of the two tower systems)

Excluding questionable data point [April 20, 2 PM, Device 1, Run 2 T2 (Device)]

**p = 0.32**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
magnes~3	38	67.92632	2.611395	16.09772	62.63513	73.2175
mag2	38	70	2.298803	14.17077	65.34218	74.65782
diff	38	-2.073684	2.058507	12.68949	-6.244615	2.097246
mean(diff) = mean(magnesiummglas~3 - mag2)					t =	-1.0074
Ho: mean(diff) = 0					degrees of freedom =	37
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.1601		Pr( T  >  t ) = 0.3203		Pr(T > t) = 0.8399		

**The results of this t-test indicate that magnesium measurements from T1 (Control) and T2 (Device) had no significant difference.**

**Table C7 – Total hardness statistical analysis for MD trial**

(Total hardness values collected during this investigation are shown in **Figure C15**. A paired t-test was used to compare total hardness measurements taken from each of the two tower systems)

**p = 0.61**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	39	234.8205	26.29889	164.2365	181.5812	288.0598
tower 2	39	228.7692	24.16312	150.8986	179.8536	277.6849
diff	39	6.051282	11.74136	73.32478	-17.71786	29.82043
mean(diff) = mean(totalhardnessm~3 - tothard2)					t =	0.5154
Ho: mean(diff) = 0					degrees of freedom =	38
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.6954		Pr( T  >  t ) = 0.6093		Pr(T > t) = 0.3046		

**The results of this t-test indicate that total hardness measurements from T1 (Control) and T2 (Device) had no significant difference.**

## WATER CONSUMPTION DATA

**Table C8 – Daily make-up water consumption statistical analysis for MD trial**

(Make-up water consumption data is shown in **Figure C2**. A paired t-test was used to compare make-up water consumption rates from each of the two tower systems)

**p = 0.675**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
st1make	27	112.6296	6.994126	36.34255	98.253	127.0063
st2make	27	114.8519	5.136236	26.68867	104.2942	125.4095
diff	27	-2.222222	5.245085	27.25426	-13.00365	8.559205
mean(diff) = mean(st1make - st2make)					t = -0.4237	
Ho: mean(diff) = 0					degrees of freedom = 26	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.3376		Pr( T  >  t ) = 0.6753		Pr(T > t) = 0.6624		

**The results of this t-test indicate that daily make-up water consumption rates from T1 (Control) and T2 (Device) had no significant difference.**

**Table C9 – Daily blowdown statistical analysis for MD trial**

(Daily blowdown data is shown in **Figure C3**. A paired t-test was used to compare daily blowdown rates from each of the two tower systems)

**p = 0**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
st1blow	27	12.25926	1.565832	8.136303	9.040645	15.47787
st2blow	27	18.44444	1.795319	9.328753	14.75411	22.13478
diff	27	-6.185185	1.112013	5.778189	-8.47096	-3.89941
mean(diff) = mean(st1blow - st2blow)					t = -5.5622	
Ho: mean(diff) = 0					degrees of freedom = 26	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.0000		Pr( T  >  t ) = 0.0000		Pr(T > t) = 1.0000		

**The results of this t-test indicate that daily blowdown rates from T2 (Device) were statistically higher than those from T1 (Device) by approximately 6.2 gal/day**




Figure C20 – Comparison of daily make-up and blowdown rates for MD trial



## APPENDIX C.3 - PHOTOGRAPHS OF TOWER SYSTEMS



**Figure C21 – T1 (Control) prior to MD trial.**

**Packing has been replaced and seasoned**



**Figure C22 - T2 (Device) prior to MD trial. Packing has been replaced and seasoned.**  
\*Note device placement on tower entrance stream. Device has been protected with a shield of lead to eliminate electrical interference.





**Figure C23 – T1 (Control) following MD trial**



**Figure C24 - T2 (Device) following MD trial.**

**(Note: Damage to digital camera card led to loss of more detailed photographs)**

## APPENDIX D: PEFD TRIAL 1/2

### APPENDIX D.1 – EXPERIMENTAL RESULTS

Note: Water samples for chemical and physical analysis were not taken on 5/6







Figure D1 – Temperature differential for PEFD (Trial 1/2)




**Figure D2 – Cumulative make-up water consumption for PEFD (Trial 1/2)**




**Figure D3 – Cumulative blowdown volume for PEFD (Trial 1/2)**




**Figure D4 – T1 (Control) temperature profile for PEFD (Trial 1/2)**



**Figure D5 – T2 (Device) temperature profile for PEFD (Trial 1/2)**



**Figure D6 – Ambient temperature conditions for PEFD (Trial 1/2)**



**Figure D7 – Ambient relative humidity for PEFD (Trial 1/2)**






Figure D8 – Continuous conductivity data for PEFD (Trial 1/2)






Figure D9 – Continuous pH data for PEFD (Trial 1/2)



**Figure D10 – Oxidation-reduction potential data for PEFD (Trial 1/2)**



**Figure D11 – Make-up water conductivity and pH for PEFD (Trial 1/2)**




Figure D12 – Alkalinity data for PEFD (Trial 1/2)






Figure D13 – Calcium hardness data for PEFD (Trial 1/2)



**Figure D14 – Magnesium hardness data for PEFD (Trial 1/2)**



**Figure D15 – Total hardness data for PEFD (Trial 1/2)**




Figure D16 – Total dissolved solids for PEFD (Trial 1/2)






Figure D17 – Langelier Saturation Index for PEFD (Trial 1/2)



**Figure D18 – Ryznar Stability Index for PEFD (Trial 1/2)**



**Figure D19 – Puckorius Scaling Index for PEFD (Trial 1/2)**

**Table D1 – Chloride concentrations for PEFD (Trial 1/2)**

<b>Chloride (mg/L)</b>					
	<b>Make-Up</b>	<b>T1 (Control)</b>	<b>T2 (Device)</b>	<b>T1 COC</b>	<b>T2 COC</b>
<b>5/2</b>	31.6	69.1	99.5	2.2	3.1
<b>5/9</b>	32.8	234.5	196.7	7.1	6.0
<b>5/17</b>	36.0	221.0	192.0	6.1	5.3
<b>5/23</b>	32.3	215.3	191.8	6.7	5.9
<b>5/30</b>	33.5	217.3	206.1	6.5	6.2





**Table D4 – Alkalinity statistical analysis for PEFD Trial 1/2**

(Alkalinity data are shown in **Figure D12**. A paired t-test was used to compare alkalinity within each of the two tower systems)

**p = 0**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	127.6786	3.410633	18.04737	120.6805	134.6766
tower 2	28	110	4.04047	21.38016	101.7096	118.2904
diff	28	17.67857	2.791263	14.76997	11.95137	23.40577

mean(diff) = mean(alkalinitymgl<sub>a-3</sub> - alk<sub>2</sub>) t = 6.3335  
 Ho: mean(diff) = 0 degrees of freedom = 27  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 1.0000 Pr(|T| > |t|) = 0.0000 Pr(T > t) = 0.0000

**The results of this t-test indicate that T1 (Control) maintained a higher alkalinity than T2 (Device) during the device trial.**

**Table D5 – Calcium hardness statistical analysis for PEFD Trial 1/2**

(Calcium hardness data are shown in **Figure D13**. A paired t-test was used to compare calcium concentrations within each of the two tower systems)

**p = 0.0004**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	243.2857	13.166	69.66792	216.2713	270.3001
tower 2	28	227.5	12.64247	66.89766	201.5598	253.4402
diff	28	15.78571	3.942831	20.8635	7.695693	23.87574

mean(diff) = mean(calciummgl<sub>asca-3</sub> - ca<sub>2</sub>) t = 4.0036  
 Ho: mean(diff) = 0 degrees of freedom = 27  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.9998 Pr(|T| > |t|) = 0.0004 Pr(T > t) = 0.0002

**The results of this t-test indicate that T1 (Control) maintained a higher calcium hardness concentration than T2 (Device) during the device trial.**

**Table D6 – Magnesium hardness statistical analysis for PEFD Trial 1/2**

(Magnesium hardness data are shown in **Figure D14**. A paired t-test was used to compare magnesium concentrations within each of the two tower systems)

**p = 0**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	186.8571	10.18126	53.87414	165.9669	207.7474
tower 2	28	166.7143	9.590126	50.74618	147.037	186.3916
diff	28	20.14286	3.187988	16.86925	13.60165	26.68407
mean(diff) = mean(magnesiummglas~3 - mag2)					t =	6.3184
Ho: mean(diff) = 0					degrees of freedom =	27
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 1.0000		Pr( T  >  t ) = 0.0000		Pr(T > t) = 0.0000		

**The results of this t-test indicate that T1 (Control) maintained a higher magnesium hardness concentration than T2 (Device) during the device trial.**

**Table D7 - Total hardness statistical analysis for PEFD Trial 1/2**

(Total hardness data are shown in **Figure D15**. A paired t-test was used to compare total hardness within each of the two tower systems)

**p = 0**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	430.25	22.80296	120.6619	383.4622	477.0378
tower 2	28	394.2143	21.71572	114.9088	349.6573	438.7713
diff	28	36.03571	6.850729	36.25065	21.97918	50.09225
mean(diff) = mean(totalhardnessm~3 - tothrd2)					t =	5.2601
Ho: mean(diff) = 0					degrees of freedom =	27
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 1.0000		Pr( T  >  t ) = 0.0000		Pr(T > t) = 0.0000		

**The results of this t-test indicate that T1 (Control) maintained a higher total hardness concentration than T2 (Device) during the device trial.**

**Table D8 – Total dissolved solids statistical analysis for PEFD Trial 1/2**

(Total dissolved solids data are shown in **Figure D16**. A paired t-test was used to compare total dissolved solids concentrations within each of the two tower systems)

```

p = 0
-----
Variable | Obs      Mean      Std. Err.  Std. Dev.  [95% Conf. Interval]
-----+-----
tower 1 |    29    503.5862   18.65275   100.4481   465.3778   541.7946
tower 2 |    29    446.1379   17.8431    96.08803   409.588    482.6879
-----+-----
diff    |    29    57.44828   6.034708   32.4979    45.08674   69.80981
-----
mean(diff) = mean(tdsprobemg1 - tdsp2)          t = 9.5196
Ho: mean(diff) = 0                               degrees of freedom = 28

Ha: mean(diff) < 0           Ha: mean(diff) != 0           Ha: mean(diff) > 0
Pr(T < t) = 1.0000           Pr(|T| > |t|) = 0.0000           Pr(T > t) = 0.0000

```

**The results of this t-test indicate that T1 (Control) maintained a higher total dissolved solids concentration than T2 (Device) during the device trial.**

**WATER CONSUMPTION DATA**

**Table D9 – Daily make-up water consumption statistical analysis for PEFD Trial 1/2**

(Daily make-up water consumption data are shown in **Figure D2**. A paired t-test was used to compare daily make-up water consumption rates within each of the two tower systems)

```

p = 0.541
-----
Variable | Obs      Mean      Std. Err.  Std. Dev.  [95% Conf. Interval]
-----+-----
dlt1make |    29    110.5172   4.48825    24.16996   101.3235   119.711
dlt2make |    29    108.7931   5.18224    27.90722   98.17777   119.4084
-----+-----
diff    |    29    1.724138   2.785384   14.99975   -3.981463   7.429739
-----
mean(diff) = mean(dlt1make - dlt2make)          t = 0.6190
Ho: mean(diff) = 0                               degrees of freedom = 28

Ha: mean(diff) < 0           Ha: mean(diff) != 0           Ha: mean(diff) > 0
Pr(T < t) = 0.7295           Pr(|T| > |t|) = 0.5409           Pr(T > t) = 0.2705

```

**The results of this t-test indicate that the daily make-up consumption rates in T1 (Control) and T2 (Device) had no significant difference.**

**Table D10 – Daily blowdown statistical analysis for PEFD Trial 1/2**


(Daily make-up water consumption data are shown in **Figure D3**. A paired t-test was used to compare daily make-up water consumption rates within each of the two tower systems)

**p = 0.009**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]
dlt1blow	29	19.51724	1.820532	9.803865	15.78805 23.24643
dlt2blow	29	14.93103	1.504452	8.101724	11.8493 18.01277
diff	29	4.586207	1.633634	8.797391	1.239858 7.932555

mean(diff) = mean(dlt1blow - dlt2blow)      t = 2.8074  
 Ho: mean(diff) = 0      degrees of freedom = 28  
 Ha: mean(diff) < 0      Ha: mean(diff) != 0      Ha: mean(diff) > 0  
 Pr(T < t) = 0.9955      Pr(|T| > |t|) = 0.0090      Pr(T > t) = 0.0045

**The results of this t-test indicate that the daily blowdown rate in T1 (Control) was approximately 4.6 gal/day higher than that observed in T2 (Device).**



**Figure D20 – Comparison of make-up and blowdown rates for PEFD (Trial 1/2)**

### APPENDIX D.3 – PHOTOGRAPHS OF TOWER SYSTEMS



**Figure D21 – T1 (Control) prior to PEFD Trial 1/2.  
Packing has been replaced and seasoned**





**Figure D22 – T2 (Device) prior to PEFD Trial 1/2.  
Packing has been replaced and seasoned**



**Figure D23 – PEFD installed on T2 (Device).  
Device placement is directly after pump and directly before entrance into heat bath.**





Figure D24 – T1 (Control) after PEFD Trial 1/2





**Figure D25 – Close-up of T1 (Control) packing after PEFD Trial 1/2**



**Figure D26 – T2 (Device) after PEFD Trial 1/2**





**Figure D27 – Close-up of Tower 2 packing after PEFD Trial 1/2**

## APPENDIX E: PEFD TRIAL 2/2

### APPENDIX E.1 – EXPERIMENTAL RESULTS

Note: Operational problems led to the shutdown of T2 (Device) for the date range 6/22 - 6/23




Figure E1 – Temperature differential for PEFD (Trial 2/2)




Figure E2 – Cumulative make-up water consumption for PEFD (Trial 2/2)






Figure E3 – Cumulative blowdown volume for PEFD (Trial 2/2)



**Figure E4 – T1 (Control) temperature profile for PEFD (Trial 2/2)**



**Figure E5 – T2 (Device) temperature profile for PEFD (Trial 2/2)**




Figure E6 – Ambient temperature conditions for PEFD (Trial 2/2)




Figure E7 – Ambient relative humidity for PEFD (Trial 2/2)




Figure E8 – Continuous conductivity data for PEFD (Trial 2/2)






Figure E9 – Continuous pH data for PEFD (Trial 2/2)







**Figure E10 – Oxidation-reduction potential data for PEFD (Trial 2/2)**




**Figure E11 – Make-up water conductivity and pH for PEFD (Trial 2/2)**




**Figure E12 – Alkalinity data for PEFD (Trial 2/2)**




**Figure E13 – Calcium hardness data for PEFD (Trial 2/2)**




**Figure E14 – Magnesium hardness data for PEFD (Trial 2/2)**




**Figure E15 – Total hardness data for PEFD (Trial 2/2)**




**Figure E16 – Total dissolved solids for PEFD (Trial 2/2)**



**Figure E17 – Langlier Saturation Index for PEFD (Trial 2/2)**



**Figure E18 – Ryznar Stability Index for PEFD (Trial 2/2)**



**Figure E19 – Puckorius Scaling Index for PEFD (Trial 2/2)**

**Table E1 - Chloride concentrations for PEFD (Trial 2/2)**

<b>Chloride (mg/L)</b>					
<b>Date</b>	<b>MU</b>	<b>T1 (Control)</b>	<b>T2 (Device)</b>	<b>T1 COC</b>	<b>T2 COC</b>
<b>6/12/09</b>	37.2	39.5	40.4		
<b>6/19/09</b>	38.3	172.7	179.2	4.51	4.68
<b>6/26/09</b>	34.7	256.1	257.8	7.38	7.43
<b>7/3/09</b>	36.9	298.5	290.4	8.09	7.87
<b>7/10/09</b>	38.4	311.8	308.7	8.12	8.04

## APPENDIX E.2 – STATISTICAL ANALYSES

### CHEMICAL DATA

**Table E2 – Conductivity statistical analysis for PEFD Trial 2/2**

(Conductivity data is shown in **Figure E8**. A paired t-test was used to compare conductivity measurements taken from each of the two tower systems)

**p = 0.07**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	1.779643	.0869134	.4599023	1.601311	1.957974
tower 2	28	1.7185	.0877401	.4642768	1.538472	1.898528
diff	28	.0611429	.0325919	.1724601	-.0057302	.1280159
mean(diff) = mean(conductivitypr-m - con2)					t = 1.8760	
Ho: mean(diff) = 0					degrees of freedom = 27	
Ha: mean(diff) < 0			Ha: mean(diff) != 0		Ha: mean(diff) > 0	
Pr(T < t) = 0.9642			Pr( T  >  t ) = 0.0715		Pr(T > t) = 0.0358	

**The results of this t-test indicate that T1 (Control) maintained higher conductivity levels than T2 (Device) during this device trial.**

**Table E3 – pH statistical analysis for PEFD Trial 2/2**

(pH data are shown in **Figure E9**. A paired t-test was used to compare pH measurements taken from each of the two tower systems)

**p = 0.10**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	8.626071	.0444375	.2351412	8.534893	8.71725
tower 2	28	8.646071	.0407513	.2156359	8.562457	8.729686
diff	28	-.02	.0117176	.0620036	-.0440425	.0040425
mean(diff) = mean(ph - ph2)					t = -1.7068	
Ho: mean(diff) = 0					degrees of freedom = 27	
Ha: mean(diff) < 0			Ha: mean(diff) != 0		Ha: mean(diff) > 0	
Pr(T < t) = 0.0497			Pr( T  >  t ) = 0.0993		Pr(T > t) = 0.9503	

**The results of this t-test indicate that T2 (Device) maintained a higher pH than T1 (Control) during the device trial.**

**Table E4 – Alkalinity statistical analysis for PEFD Trial 2/2**

(Alkalinity data is shown in **Figure E12**. A paired t-test was used to compare alkalinity within each of the two tower systems)

**p = 0.016**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	27	110.037	5.585258	29.02185	98.55638	121.5177
tower 2	27	103.5556	5.302887	27.55461	92.65532	114.4558
diff	27	6.481481	2.515689	13.0719	1.310409	11.65255
mean(diff) = mean(alkalinitymgl~3 - alk2)				t =	2.5764	
Ho: mean(diff) = 0				degrees of freedom =	26	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.9920		Pr( T  >  t ) = 0.0160		Pr(T > t) = 0.0080		

**The results of this t-test indicate that T1 (Control) maintained a higher alkalinity than T2 (Device) during the device trial.**

**Table E5 – Calcium hardness statistical analysis for PEFD Trial 2/2**

(Calcium hardness data is shown in **Figure E13**. A paired t-test was used to compare calcium concentrations within each of the two tower systems)

**p = 0.088**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	27	155.1852	8.35144	43.39535	138.0186	172.3518
tower 2	27	152.4444	7.914128	41.12302	136.1767	168.7122
diff	27	2.740741	1.543844	8.022049	-.4326763	5.914158
mean(diff) = mean(calciummglasca~3 - ca2)				t =	1.7753	
Ho: mean(diff) = 0				degrees of freedom =	26	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.9562		Pr( T  >  t ) = 0.0876		Pr(T > t) = 0.0438		

**The results of this t-test indicate that T1 (Control) maintained a higher calcium concentration than T2 (Device) during the device trial.**





**Table E8 – Total dissolved solids statistical analysis for PEFD Trial 2/2**

(Total dissolved solids data is shown in **Figure E16**. A paired t-test was used to compare total dissolved solids concentrations within each of the two tower systems)

**p = 0.11**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	887.1071	43.49364	230.1467	797.8656	976.3487
tower 2	28	861.25	43.89531	232.2721	771.1843	951.3157
diff	28	25.85714	15.85848	83.91518	-6.681765	58.39605
mean(diff) = mean(tdsprobemg1 - tdsp2)					t = 1.6305	
Ho: mean(diff) = 0					degrees of freedom = 27	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.9427		Pr( T  >  t ) = 0.1146		Pr(T > t) = 0.0573		

**The results of this t-test indicate that T1 (Control) maintained a higher total dissolved solids concentration than T2 (Device) during the device trial.**

## WATER CONSUMPTION DATA

**Table E9 – Daily make-up water consumption statistical analysis for PEFD Trial 2/2**

(Daily make-up water consumption data is shown in **Figure E2**. A paired t-test was used to compare daily make-up water rates within each of the two tower systems)

**p = 0.022**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
d2t1make	28	105.2143	4.319991	22.85924	96.3504	114.0782
d2t2make	28	96.03571	5.044637	26.69371	85.68497	106.3865
diff	28	9.178571	3.772658	19.96303	1.437717	16.91943
mean(diff) = mean(d2t1make - d2t2make)					t = 2.4329	
Ho: mean(diff) = 0					degrees of freedom = 27	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.9891		Pr( T  >  t ) = 0.0219		Pr(T > t) = 0.0109		

**The results of this t-test indicate that T1 (Control) maintained a higher make-up consumption rate than T2 (Device) during the device trial by approximately 9 gal/day.**

**Table E10 – Daily blowdown statistical analysis for PEFD Trial 2/2**


(Daily blowdown data is shown in **Figure E3**. A paired t-test was used to compare daily blowdown rates within each of the two tower systems)

**p = 0.880**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
d2t1blow	28	8.464286	1.044616	5.527588	6.320911	10.60766
d2t2blow	28	8.25	1.546138	8.181393	5.077587	11.42241
diff	28	.2142857	1.410802	7.465263	-2.680441	3.109013

mean(diff) = mean(d2t1blow - d2t2blow)      t = 0.1519  
 Ho: mean(diff) = 0      degrees of freedom = 27  
 Ha: mean(diff) < 0      Ha: mean(diff) != 0      Ha: mean(diff) > 0  
 Pr(T < t) = 0.5598      Pr(|T| > |t|) = 0.8804      Pr(T > t) = 0.4402

**The results of this t-test indicate that there was no significant difference between the blowdown rates of T1 (Control) and T2 (Device).**



**Figure E20 – Comparison of make-up and blowdown rates for PEFD (Trial 2/2)**

### APPENDIX E.3 – PHOTOGRAPHS OF TOWER SYSTEMS



**Figure E21 – T1 (Control) prior to PEFD (Trial 2/2).  
Packing has been replaced and seasoned**



**Figure E22 – T2 (Device) Prior to PEFD (Trial 2/2).**

**Packing has been replaced and seasoned. Note device placement on tower entrance stream**





**Figure E23 – T1 (Control) following PEFD (Trial 2/2)**



**Figure E24 – Close-up of T1 (Control) packing following PEFD (Trial 2/2)**



**Figure E25 – Close-up of T1 (Control) packing following PEFD (Trial 2/2)**





**Figure E26 – T2 (Device) following PEFD (Trial 2/2)**









**Figure E27 – Close-up of T2 (Device) packing following PEFD (Trial 2/2)**



**Figure E28 – Close-up of T2 (Device) packing following PEFD (Trial 2/2)**

## APPENDIX E.4 – BIOFILM SAMPLING COUPON COMPARISON

Table E11 – Visual comparison of biofilm coupons collected during PEFD (Trial 2/2)

Sample Date	Days Elapsed	T1	T2
7/8/09	27		
7/10/09	29		

## APPENDIX F: ED TRIAL

### APPENDIX F.1 – EXPERIMENTAL RESULTS

Note: Operational problems caused a shutdown of T2 (Device) on 8/2




Figure F1 – Temperature differential for ED trial




Figure F2 – Cumulative make-up water consumption for ED trial






Figure F3 – Cumulative blowdown volume for ED trial



**Figure F4 – T1 (Control) temperature profile for ED trial**



**Figure F5 – T2 (Device) temperature profile for ED trial**




Figure F6 – Ambient temperature conditions







Figure F7 – Ambient relative humidity




**Figure F8 – Continuous conductivity data for ED trial**



**Figure F9 – Continuous pH data for ED trial**




**Figure F10 – Oxidation-reduction potential data for ED trial**




**Figure F11 – Make-up water conductivity and pH for ED trial**





**Figure F12 – Alkalinity data for ED trial**



**Figure F13 – Calcium hardness data for ED trial**




Figure F14– Magnesium hardness data for ED trial






Figure F15 – Total hardness data for ED trial



**Figure F16 – Total dissolved solids for ED trial**



**Figure F17 – Langelier Saturation Index for ED trial**




Figure F18 – Ryznar Stability Index for ED trial




Figure F19 – Puckorius Scaling Index for ED trial

**Table F1 – Chloride concentrations for ED trial**

<b>Chloride (mg/L)</b>					
<b>Date</b>	<b>MU</b>	<b>T1 (Control)</b>	<b>T2 (Device)</b>	<b>T1 COC</b>	<b>T2 COC</b>
<b>7/18/09</b>	36.4	37.8	37.5		
<b>7/25/09</b>	39.3	160.7	164.3	4.09	4.18
<b>8/1/09</b>	39.4	222.2	227.3	5.64	5.77
<b>8/8/09</b>	35.6	195.4	199.0	5.49	5.59
<b>8/15/09</b>	32.7	197.4	199.3	6.04	6.09

## APPENDIX F.2 – STATISTICAL ANALYSES

### CHEMICAL PARAMETERS

**Table F2 – Conductivity statistical analysis for ED trial**

(Conductivity data are shown in **Figure F8**. A paired t-test was used to compare conductivity measurements taken from each of the two tower systems)

**p = 0.14**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	1.155929	.0405214	.2144189	1.072786	1.239072
tower 2	28	1.125679	.0412069	.2180466	1.041129	1.210228
diff	28	.03025	.0198528	.1050512	-.0104846	.0709846
mean(diff) = mean(conductivitypr-m - con2)					t = 1.5237	
Ho: mean(diff) = 0					degrees of freedom = 27	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.9304		Pr( T  >  t ) = 0.1392		Pr(T > t) = 0.0696		

**This t-test reveals that conductivity levels were higher in T1 (Control) than in T2 (Device) during this device trial.**

**Table F3 – pH statistical analysis for ED trial**

(pH data are shown in **Figure F9**. A paired t-test was used to compare pH levels within each of the two tower systems)

**p = 0.004**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	8.536429	.0348778	.1845558	8.464865	8.607992
tower 2	28	8.606429	.0279086	.1476787	8.549165	8.663692
diff	28	-.07	.0224846	.1189773	-.1161346	-.0238654
mean(diff) = mean(ph - ph2)					t = -3.1132	
Ho: mean(diff) = 0					degrees of freedom = 27	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.0022		Pr( T  >  t ) = 0.0043		Pr(T > t) = 0.9978		

**This t-test reveals that pH levels were significantly higher in T2 (Device) than in T1 (Control) during this investigation.**

**Table F4 – Alkalinity statistical analysis for ED trial**

(Alkalinity data are shown in **Figure F12**Figure . A paired t-test was used to compare alkalinity within each of the two tower systems)

**p = 0.56**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]		
tower 1	28	83.17857	2.968108	15.70575	77.08852	89.26863	
tower 2	28	84.53571	3.099532	16.40118	78.176	90.89543	
diff	28	-1.357143	2.299767	12.16922	-6.075874	3.361589	
mean(diff) = mean(alkalinitymgla~3 - alk2)						t =	-0.5901
Ho: mean(diff) = 0						degrees of freedom =	27
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0			
Pr(T < t) = 0.2800		Pr( T  >  t ) = 0.5600		Pr(T > t) = 0.7200			

**This t-test reveals that there was no significant difference between alkalinity measured in T1 (Control) and T2 (Device) during this investigation.**

**Table F5 - Calcium hardness statistical analysis for ED trial**

(Calcium hardness data are shown in **Figure F13**. A paired t-test was used to compare calcium concentrations within each of the two tower systems)

**p = 0.82**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]		
tower 1	28	142.5357	6.267722	33.16567	129.6754	155.396	
tower 2	28	142.1464	6.297775	33.32469	129.2245	155.0684	
diff	28	.3892829	1.71571	9.078682	-3.131063	3.909628	
mean(diff) = mean(calciummglasca~3 - ca2)						t =	0.2269
Ho: mean(diff) = 0						degrees of freedom =	27
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0			
Pr(T < t) = 0.5889		Pr( T  >  t ) = 0.8222		Pr(T > t) = 0.4111			

**This t-test reveals that there was no significant difference between calcium concentrations measured in T1 (Control) and T2 (Device) during this investigation.**





**Table F8 – Total dissolved solids statistical analysis for ED trial**

(Total dissolved solids data are shown in **Figure F16**. A paired t-test was used to compare total dissolved solids concentrations within each of the two tower systems)

**p = 0.03**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tower 1	28	770.6429	24.57492	130.0382	720.2193	821.0664
tower 2	28	736.7143	26.87345	142.2009	681.5745	791.854
diff	28	33.92857	14.68018	77.68022	3.807326	64.04982
mean(diff) = mean(tdslabmg1 - tdsl2)				t =	2.3112	
Ho: mean(diff) = 0				degrees of freedom =	27	
Ha: mean(diff) < 0	Pr(T < t) = 0.9857	Ha: mean(diff) != 0	Pr( T  >  t ) = 0.0287	Ha: mean(diff) > 0	Pr(T > t) = 0.0143	

**This t-test reveals that total dissolved solids concentrations were higher in T1 (Control) than in T2 (Device) during this device trial.**

**WATER CONSUMPTION DATA**

**Table F9 – Daily make-up water consumption statistical analysis for ED trial**

(Make-up water consumption data are shown in **Figure F2**. A paired t-test was used to compare make-up water consumption rates within each of the two tower systems)

**p = 0.016**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
ftt1make	29	116.2414	5.026201	27.06692	105.9457	126.5371
ftt2make	29	102.4483	6.610856	35.60055	88.90655	115.99
diff	29	13.7931	5.401464	29.08777	2.728706	24.8575
mean(diff) = mean(ftt1make - ftt2make)				t =	2.5536	
Ho: mean(diff) = 0				degrees of freedom =	28	
Ha: mean(diff) < 0	Pr(T < t) = 0.9918	Ha: mean(diff) != 0	Pr( T  >  t ) = 0.0164	Ha: mean(diff) > 0	Pr(T > t) = 0.0082	

**This t-test reveals that make-up water consumption rates were higher in T1 (Control) than in T2 (Device) during this device trial by approximately 13.7 gal/day.**

**Table F10 – Daily blowdown statistical analysis for ED trial**

(Blowdown data are shown in **Figure F3**. A paired t-test was used to compare blowdown rates within each of the two tower systems)


**p = 0.244**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
ftt1blow	29	19.37931	1.665658	8.969845	15.96736	22.79126
ftt2blow	29	17.51724	2.069971	11.14714	13.2771	21.75738
diff	29	1.862069	1.563692	8.42074	-1.341009	5.065147

mean(diff) = mean(ftt1blow - ftt2blow)		t =	1.1908
Ho: mean(diff) = 0		degrees of freedom =	28
Ha: mean(diff) < 0	Pr(T < t) = 0.8781	Ha: mean(diff) != 0	Pr( T  >  t ) = 0.2437
		Ha: mean(diff) > 0	Pr(T > t) = 0.1219

**This t-test reveals that there was no significant difference between blowdown rates in T1 (Control) and T2 (Device).**



**Figure F20 – Comparison of daily make-up and blowdown rates for ED trial**

## APPENDIX F.3 – PHOTOGRAPHS OF TOWER SYSTEMS




**Figure F21 – T1 (Control) prior to ED trial.**

**Packing has been replaced and seasoned**



**Figure F22 – Close-up of T1 (Control) packing prior to ED trial.**

**Note deposition of residual solids from cleaning process.**



**Figure F23 – Close-up of T1 (Control) packing prior to ED trial.**

**Note deposition of residual solids from cleaning process.**





**Figure F24 – T2 (Device) prior to test of ED trial.**

**Packing has been replaced and seasoned. Note deposition of residual solids from cleaning process.**



**Figure F25 – Close-up of T2 (Device) packing prior to ED trial.**

**Note deposition of residual solids from cleaning process.**




**Figure F26 – Close-up of T2 (Device) packing prior to ED trial**





Figure F27 – T1 (Control) after ED trial




**Figure F28 – Close-up of T1 (Control) packing after ED trial**



**Figure F29 – Close-up of T1 (Control) packing after test with ED trial**











**Figure F30 – T2 (Device) after ED trial**



**Figure F31 – Close-up of T2 (Device) packing after ED trial**

## APPENDIX F.4 – BIOFILM SAMPLING COUPON COMPARISON

Table F11 – Biofilm sampling coupon photographs taken during electrostatic device trial

Sample Date	Days Elapsed	T1	T2
7/22/09	5		
8/14/09	28		
8/23/09	37		

## APPENDIX G: UD TRIAL

### APPENDIX G.1 – EXPERIMENTAL RESULTS






Figure G1 – Temperature differential for UD trial



**Figure G2 – Cumulative make-up water consumption for UD trial**



**Figure G3 – Cumulative blowdown volume for UD trial**




Figure G4 – T1 (Control) temperature profile for UD trial







Figure G5 – T2 (Device) temperature profile for UD trial




**Figure G6 – Ambient temperature conditions**



**Figure G7 – Ambient relative humidity**




**Figure G8 – Continuous conductivity data for UD trial**




**Figure G9 – Continuous pH data for UD trial**





**Figure G10 – Oxidation-reduction potential data for UD trial**



**Figure G11 – Make-up water conductivity and pH for UD trial**






Figure G12 – Alkalinity data for UD trial






Figure G13 – Calcium hardness data for UD trial



**Figure G14 – Magnesium hardness data for UD trial**



**Figure G15 – Total hardness data for UD trial**




Figure G16 – Total dissolved solids for UD trial






Figure G17 – Langlier Saturation Index for UD trial



**Figure G18 – Ryznar Stability Index for UD trial**



**Figure G19 – Puckorius Scaling Index for UD trial**

**Table G1 – Chloride concentrations for UD trial**

<b>Chloride (mg/L)</b>					
<b>Date</b>	<b>MU</b>	<b>T1 (Control)</b>	<b>T2 (Device)</b>	<b>T1 COC</b>	<b>T2 COC</b>
<b>9/2/09</b>	33.7	36.5	36.2	1.08	1.07
<b>9/9/09</b>	35.2	193	168.7	5.48	4.79
<b>9/16/09</b>	37.9	226.6	204.9	5.98	5.41
<b>9/23/09</b>	42.8	230.4	220.7	5.38	5.16
<b>9/30/09</b>	44.5	242.2	239.9	5.44	5.39

## APPENDIX G.2 – STATISTICAL ANALYSES

### CHEMICAL PARAMETERS

**Table G2 – Conductivity statistical analysis for UD trial**

(Conductivity data are shown in **Figure G8**. A paired t-test was used to compare conductivity measurements taken from each of the two tower systems)

**p = 0.251**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
Conduc1	29	1.254069	.0534924	.2880652	1.144495	1.363643
conduc2	29	1.246276	.0548673	.2954696	1.133885	1.358666
diff	29	.0077931	.0114993	.0619259	-.0157622	.0313485
mean(diff) = mean(conductivity - conduc2)				t =	0.6777	
Ho: mean(diff) = 0				degrees of freedom =	28	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.7482		Pr( T  >  t ) = 0.5035		Pr(T > t) = 0.2518		

**This t-test reveals that conductivity levels were comparable in T1 (Control) and T2 (Device) during this device trial.**

**Table G3 – pH statistical analysis for UD trial**

(pH data are shown in **Figure G9**. A paired t-test was used to compare conductivity measurements taken from each of the two tower systems)

**p = 1.0**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
ph	29	8.647931	.0378042	.2035818	8.570493	8.725369
ph2	29	8.72069	.034623	.1864505	8.649768	8.791612
diff	29	-.0727586	.0064879	.0349383	-.0860484	-.0594688
mean(diff) = mean(ph - ph2)				t =	-11.2145	
Ho: mean(diff) = 0				degrees of freedom =	28	
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.0000		Pr( T  >  t ) = 0.0000		Pr(T > t) = 1.0000		

**This t-test reveals that pH levels were significantly higher in T2 (Device) than in T1 (Control) during this investigation.**

**Table G4 – Alkalinity statistical analysis for UD trial**

(Alkalinity data are shown in **Figure G12**. A paired t-test was used to compare alkalinity within each of the two tower systems)

**p = 0.012**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
alk	29	97.03962	3.818764	20.56467	89.21724	104.862
alk2	29	92.53714	3.509594	18.89974	85.34806	99.72621
diff	29	4.502484	1.874519	10.09459	.6627052	8.342262

mean(diff) = mean(alk - alk2) t = 2.4019  
 Ho: mean(diff) = 0 degrees of freedom = 28  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.9884 Pr(|T| > |t|) = 0.0232 Pr(T > t) = 0.0116

**This t-test reveals that alkalinity levels were higher in T1 (Control) than in T2 (Device) during this investigation.**

**Table G5 – Calcium hardness statistical analysis for UD trial**

(Calcium hardness data are shown in **Figure G13**. A paired t-test was used to compare calcium concentrations within each of the two tower systems)

**p = 0.251**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
cal	29	165.9386	6.418877	34.56671	152.7901	179.087
cal2	29	165.0086	6.778294	36.50223	151.1239	178.8934
diff	29	.9299176	1.366029	7.356289	-1.868265	3.7281

mean(diff) = mean(cal - cal2) t = 0.6807  
 Ho: mean(diff) = 0 degrees of freedom = 28  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.7492 Pr(|T| > |t|) = 0.5016 Pr(T > t) = 0.2508

**This t-test reveals that there was no significant difference between calcium concentrations measured in T1 (Control) and T2 (Device) during this investigation.**

**Table G6 – Magnesium hardness statistical analysis for UD trial**

(Magnesium hardness data are shown in **Figure G14**. A paired t-test was used to compare magnesium concentrations within each of the two tower systems)

p = 0.698

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
mag	29	115.1194	6.122379	32.97002	102.5783	127.6605
mag2	29	115.872	6.410029	34.51906	102.7417	129.0023
diff	29	-.7526001	1.431496	7.708842	-3.684887	2.179687
mean(diff) = mean(mag - mag2)					t =	-0.5257
Ho: mean(diff) = 0					degrees of freedom =	28
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.3016		Pr( T  >  t ) = 0.6032		Pr(T > t) = 0.6984		

**This t-test reveals that magnesium concentrations were comparable in T1 (Control) and T2 (Device) during this investigation.**

**Table G7 – Total hardness statistical analysis for UD trial**

(Total hardness data are shown in **Figure G15**. A paired t-test was used to compare total hardness within each of the two tower systems)

p = 0.471

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tothard	29	281.058	12.29343	66.20212	255.876	306.2399
tothard2	29	280.8806	12.95034	69.73969	254.3531	307.4082
diff	29	.1773162	2.41155	12.9866	-4.762521	5.117153
mean(diff) = mean(tothard - tothard2)					t =	0.0735
Ho: mean(diff) = 0					degrees of freedom =	28
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.5290		Pr( T  >  t ) = 0.9419		Pr(T > t) = 0.4710		

**This t-test reveals that total hardness was comparable in T1 (Control) and T2 (Device) during this investigation.**



**Table G8 - Total dissolved solids statistical analysis for UD trial**

(Total dissolved solids data are shown in **Figure G16**. A paired t-test was used to compare total dissolved solids concentrations taken from each of the two tower systems)

**p = 0.221**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tdslab	29	859.1724	38.14689	205.4273	781.0321	937.3128
tdslab2	29	851.1724	39.18109	210.9966	770.9136	931.4312
diff	29	8	10.25116	55.20417	-12.99854	28.99854

mean(diff) = mean(tdslab - tdslab2)	t = 0.7804	
Ho: mean(diff) = 0	degrees of freedom = 28	
Ha: mean(diff) < 0	Ha: mean(diff) != 0	Ha: mean(diff) > 0
Pr(T < t) = 0.7791	Pr( T  >  t ) = 0.4417	Pr(T > t) = 0.2209

**This t-test reveals that total dissolved solids concentrations were comparable in T1 (Control) and T2 (Device) during this device trial.**

### WATER CONSUMPTION DATA

**Table G9 – Daily make-up water consumption statistical analysis for UD trial**

(Daily make-up water consumption data are shown in **Figure G2**. A paired t-test was used to compare daily make-up consumption rates from each of the two tower systems)

**p = 0.215**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
sonot1~e	33	123.3939	4.622479	26.55412	113.9783	132.8096
sonot2~e	33	121.0303	4.744112	27.25285	111.3669	130.6937
diff	33	2.363636	1.866683	10.72328	-1.438672	6.165945

mean(diff) = mean(sonot1make - sonot2make)	t = 1.2662	
Ho: mean(diff) = 0	degrees of freedom = 32	
Ha: mean(diff) < 0	Ha: mean(diff) != 0	Ha: mean(diff) > 0
Pr(T < t) = 0.8927	Pr( T  >  t ) = 0.2146	Pr(T > t) = 0.1073

**This t-test reveals that make-up water consumption rates were comparable in T1 (Control) and T2 (Device) during this device trial.**

**Table G10 – Daily blowdown statistical analysis for UD trial**


(Daily blowdown data are shown in **Figure G3**. A paired t-test was used to compare daily blowdown rates from each of the two tower systems)

**p = 0.000**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
sonot1~w	33	19.09091	1.520917	8.737003	15.9929	22.18892
sonot2~w	33	24.54545	2.145331	12.32399	20.17556	28.91535
diff	33	-5.454545	1.368678	7.862454	-8.24245	-2.666641

mean(diff) = mean(sonot1blow - sonot2blow)      t = -3.9853  
 Ho: mean(diff) = 0      degrees of freedom = 32  
 Ha: mean(diff) < 0      Ha: mean(diff) != 0      Ha: mean(diff) > 0  
 Pr(T < t) = 0.0002      Pr(|T| > |t|) = 0.0004      Pr(T > t) = 0.9998

**This t-test reveals that blowdown rates were higher in T2 (Device) than in T1 (Control) during this device trial by approximately 5.6 gal/day.**



**Figure G20 – Comparison of make-up and blowdown rates for UD trial**

## APPENDIX G.3 – PHOTOGRAPHS OF TOWER SYSTEMS




**Figure G21 – T1 (Control) prior to UD trial.**

**Packing has been replaced and seasoned according to the manufacturer's specifications.**



**Figure G22 – Close-up of T1 packing prior to UD trial**



**Figure G23 – Close-up of T1 packing prior to UD trial**





**Figure G24 – T2 (Device) prior to UD trial.**

**Packing has been replaced and seasoned according to the manufacturer’s specifications.**



**Figure G25 – Close-up of T2 (Device) packing prior to ultrasonic treatment device trial**



**Figure G26 – Close-up of T2 (Device) packing prior to UD trial**





**Figure G27 – T1 (Control) after UD trial**



**Figure G28 – Close-up of T1 (Control) packing following UD trial**



**Figure G29 – Close-up of T1 (Control) packing following UD trial**





**Figure G30 – T2 (Device) following UD trial**









**Figure G31 – Close-up of T2 (Device) packing following UD trial**



**Figure G32 – Close-up of T2 (Device) packing following UD trial**

## APPENDIX G.4 – BIOFILM SAMPLING COUPON COMPARISON


Table G11 – Photographs of biofilm sampling coupons taken throughout ultrasonic treatment device trial

Sampling Date	Days Elapsed	T1	T2
9/10/09	9		
9/24/09	23		
10/1/09	30		




**APPENDIX H: HCD TRIAL**


**APPENDIX H.1 – EXPERIMENTAL RESULTS**



**Figure H1 – Temperature differential for HCD trial**



**Figure H2 – Cumulative make-up water consumption for HCD trial**



**Figure H3 – Cumulative blowdown volume for HCD trial**




Figure H4 – T1 (Control) temperature profile for HCD trial




Figure H5 – T2 (Device) temperature profile for HCD trial




Figure H6 – Ambient temperature conditions






Figure H7 – Ambient relative humidity




**Figure H8 – Continuous conductivity data for HCD trial**




**Figure H9– Continuous pH data for HCD trial**







**Figure H10 – Oxidation-reduction potential data for HCD trial**




**Figure H11 – Make-up water conductivity and pH for HCD trial**




**Figure H12 – Alkalinity data for HCD trial**




**Figure H13 – Calcium hardness data for HCD trial**




**Figure H14 – Magnesium hardness data for HCD trial**




**Figure H15 – Total hardness data for HCD trial**




**Figure H16 – Total dissolved solids data for HCD trial**



**Figure H17 – Langelier Saturation Index for HCD trial**



**Figure H18 – Ryznar Stability Index for HCD trial**



**Figure H19 – Puckorius Scaling Index for HCD trial**

**Table H1 – Chloride concentrations for HCD trial**

<b>Chloride (mg/L)</b>					
<b>Date</b>	<b>MU</b>	<b>T1 (Control)</b>	<b>T2 (Device)</b>	<b>T1 COC</b>	<b>T2 COC</b>
<b>10/27/2009</b>	36.5	37.9	38.1		
<b>11/3/2009</b>	35.9	150.1	145.8	4.18	4.06
<b>11/10/2009</b>	31.6	168.7	165.3	5.34	5.23
<b>11/17/2009</b>	32.4	158.4	178.2	4.89	5.50
<b>11/24/2009</b>	32.2	167.1	184.2	5.19	5.72

## APPENDIX H.2 – STATISTICAL ANALYSES

### CHEMICAL PARAMETERS

**Table H2 – Conductivity statistical analysis for HCD trial**

(Conductivity data are shown in **Figure H8**. A paired t-test was used to compare conductivity measurements taken from each of the two tower systems)

**p = 0.31**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
conduc	29	1.286517	.0449123	.2418603	1.194519	1.378516
conduc2	29	1.270655	.0408448	.2199561	1.186988	1.354322
diff	29	.0158621	.0152348	.0820417	-.0153449	.047069
mean(diff) = mean(conduc - conduc2)					t =	1.0412
Ho: mean(diff) = 0					degrees of freedom =	28
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.8466		Pr( T  >  t ) = 0.3067		Pr(T > t) = 0.1534		

**This t-test reveals that conductivity levels were comparable in T1 (Control) and T2 (Device) during this device trial.**

**Table H3 – pH statistical analysis for HCD trial**

(pH data are shown in **Figure H9**. A paired t-test was used to compare pH levels within each of the two tower systems)

**p = 0**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
ph	29	8.72	.0220724	.1188636	8.674787	8.765213
ph2	29	8.636896	.021266	.1145209	8.593335	8.680458
diff	29	.0831036	.0095348	.0513464	.0635725	.1026347
mean(diff) = mean(ph - ph2)					t =	8.7158
Ho: mean(diff) = 0					degrees of freedom =	28
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 1.0000		Pr( T  >  t ) = 0.0000		Pr(T > t) = 0.0000		

**This t-test reveals that pH levels were significantly higher in T1 (Control) than in T2 (Device) during this investigation.**

**Table H4 – Alkalinity statistical analysis for HCD trial**

(Alkalinity data are shown in **Figure H12**. A paired t-test was used to compare alkalinity within each of the two tower systems)

**p = 0.092**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
alk	29	113.1379	2.3774	12.80269	108.268	118.0078
alk2	29	110.4138	2.762128	14.87452	104.7558	116.0718
diff	29	2.724138	1.995004	10.74343	-1.362442	6.810718

mean(diff) = mean(alk - alk2) t = 1.3655  
 Ho: mean(diff) = 0 degrees of freedom = 28  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.9085 Pr(|T| > |t|) = 0.1830 Pr(T > t) = 0.0915

**This t-test reveals that there was no significant difference between alkalinity measured in T1 (Control) and T2 (Device) during this investigation.**

**Table H5 – Calcium hardness statistical analysis for HCD trial**

(Calcium hardness data are shown in **Figure H13**. A paired t-test was used to compare calcium concentrations within each of the two tower systems)

**P = 0.007**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
cal	29	191.5862	6.074155	32.71033	179.1439	204.0286
cal2	29	183	5.908581	31.81868	170.8968	195.1032
diff	29	8.586207	2.954298	15.90938	2.534602	14.63781

mean(diff) = mean(cal - cal2) t = 2.9063  
 Ho: mean(diff) = 0 degrees of freedom = 28  
 Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.9965 Pr(|T| > |t|) = 0.0071 Pr(T > t) = 0.0035

**This t-test reveals that calcium concentrations measured in T1 (Control) were higher than T2 (Device) during this investigation.**



**Table H6 – Magnesium hardness statistical analysis for HCD trial**

(Magnesium hardness data are shown in **Figure H14**. A paired t-test was used to compare magnesium concentrations within each of the two tower systems)

**p = 0.362**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
mag	29	97.41379	3.336807	17.96925	90.57865	104.2489
mag2	29	95.17241	2.956195	15.91959	89.11692	101.2279
diff	29	2.241379	2.416923	13.01553	-2.709462	7.192221
mean(diff) = mean(mag - mag2)					t =	0.9274
Ho: mean(diff) = 0				degrees of freedom = 28		
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.8192		Pr( T  >  t ) = 0.3617		Pr(T > t) = 0.1808		

**This t-test reveals that magnesium concentrations were comparable in T1 (Control) and T2 (Device) during this investigation.**

**Table H7 – Total hardness statistical analysis for HCD trial**

(Total hardness data are shown in **Figure H15**. A paired t-test was used to compare magnesium concentrations within each of the two tower systems)

**p = 0.02**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
tothard	29	288.931	8.948255	48.18783	270.6014	307.2607
tothard2	29	278.1379	8.503219	45.79124	260.7199	295.556
diff	29	10.7931	4.403698	23.71464	1.772536	19.81367
mean(diff) = mean(tothard - tothard2)					t =	2.4509
Ho: mean(diff) = 0				degrees of freedom = 28		
Ha: mean(diff) < 0		Ha: mean(diff) != 0		Ha: mean(diff) > 0		
Pr(T < t) = 0.9896		Pr( T  >  t ) = 0.0208		Pr(T > t) = 0.0104		

**This t-test reveals that total hardness was higher in T1 (Control) than in T2 (Device) during this investigation.**

**Table H8 – Total dissolved solids statistical analysis for HCD trial**

(Total dissolved solids data are shown in **Figure H16**. A paired t-test was used to compare total dissolved solids concentrations within each of the two tower systems)

**p = 0.392**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]
tdslab	29	880.7241	31.1632	167.819	816.8892 944.5591
tdslabb2	29	871.4828	30.36265	163.5079	809.2877 933.6778
diff	29	9.241379	10.61863	57.18307	-12.5099 30.99266

mean(diff) = mean(tdslab - tdslabb2) t = 0.8703  
 Ho: mean(diff) = 0 degrees of freedom = 28

Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.8042 Pr(|T| > |t|) = 0.3915 Pr(T > t) = 0.1958

**This t-test reveals that total dissolved solids concentrations were comparable in T1 (Control) and T2 (Device) during this device trial.**

## WATER CONSUMPTION DATA

**Table H9 – Daily make-up water consumption statistical analysis for HCD trial**

(Daily make-up water consumption data are shown in **Figure H2**. A paired t-test was used to compare daily make-up water consumption rates for each of the two tower systems)

**p = 0.000**

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]
vt1make	29	123.5517	5.033285	27.10507	113.2415 133.8619
vt2make	29	139.2414	5.958116	32.08544	127.0367 151.446
diff	29	-15.68966	2.761944	14.87352	-21.34724 -10.03207

mean(diff) = mean(vt1make - vt2make) t = -5.6807  
 Ho: mean(diff) = 0 degrees of freedom = 28

Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.0000 Pr(|T| > |t|) = 0.0000 Pr(T > t) = 1.0000

**This t-test reveals that daily make-up water consumption rates were higher in T2 (Device) than in T1 (Control) by approximately 15.7 gal/day.**

**Table H10 – Daily blowdown statistical analysis for HCD trial**

(Daily blowdown data are shown in **Figure H3**. A paired t-test was used to compare daily blowdown rates for each of the two tower systems)


Paired t test

Variable	Obs	Mean	Std. Err.	Std. Dev.	[95% Conf. Interval]	
vt1blow~t	29	22.55172	1.804883	9.719591	18.85459	26.24886
vt2blow~t	29	22.93103	1.891731	10.18729	19.056	26.80607
diff	29	-.3793103	.9906133	5.334616	-2.40849	1.649869

mean(diff) = mean(vt1blowdown - vt2blowdown) t = -0.3829  
 Ho: mean(diff) = 0 degrees of freedom = 28

Ha: mean(diff) < 0 Ha: mean(diff) != 0 Ha: mean(diff) > 0  
 Pr(T < t) = 0.3523 Pr(|T| > |t|) = 0.7047 Pr(T > t) = 0.6477

**This t-test reveals that daily blowdown rates were comparable in T1 (Control) and T2 (Device) during this device trial.**



**Figure H20 – Comparison of daily make-up and blowdown rates for HCD trial**

### APPENDIX H.3 – PHOTOGRAPHS OF TOWER SYSTEMS



Figure H21 – T1 (Control) prior to HCD trial.

Packing has been replaced and seasoned according to the manufacturer's specifications



**Figure H22 – Close-up of T1 (Control) packing prior to HCD trial**



**Figure H23 – Close-up of T1 (Control) packing prior to HCD trial**





**Figure H24 – T2 (Device) prior to HCD trial.**

**Packing has been replaced and seasoned according to the manufacturer’s specifications**



**Figure H25 – Close-up of T2 (Device) packing prior to HCD trial**




**Figure H26 – Close-up of T2 (Device) packing prior to HCD trial**





**Figure H27 – T1 (Control) following HCD trial**





**Figure H28 – Close-up of T1 (Control) following HCD trial**



**Figure H29 – Close-up of T1 (Control) following HCD trial**



**Figure H30 – T2 (Device) following HCD trial**









**Figure H31 – Close-up of T2 (Device) following HCD trial**



**Figure H32 – Close-up of T2 (Device) following HCD trial**

## APPENDIX H.4 – BIOFILM SAMPLING COUPON COMPARISON

**Table H11 - Photographs of biofilm sampling coupons taken throughout device trial**

Sampling Date	Days Elapsed	T1	T2
11/4/09	8		
11/12/09	16		
11/24/09	28	